

## **Key Deactivation Study Assumptions for: Somerset**

#### **Keith Burrell**

Manager, Transmission Studies

#### **ESPWG/TPAS**

January 23, 2020

## **Generator Summary**

### Somerset

- Zone A
- Nameplate 675 MW
- Retire



## **Deactivation Assessment Assumptions**

- The most recent base cases from the reliability planning process are those used for the 2019-2028 Comprehensive Reliability Plan (CRP) (discussed at the March 6, 2019 ESPWG/TPAS)
  - Major Assumptions from the RNA (discussed at the June 22, 2018 ESPWG/TPAS) and CRP are provided at the end of this presentation for reference
- Changes from the CRP Case reviewed at Prior Generator Deactivation Key Study Assumptions are provided as a reference



## **Deactivation Assessment Assumptions**

### The following updates are included in this assessment:

- Local Transmission Plans (presented at the October 23<sup>rd</sup> and November 18<sup>th</sup> ESPWG) were reviewed for changes compared to the assumptions used for the 2019-2028 CRP
  - RG&E Station 122 relay upgrade was removed from the model
  - NYPA Niagara 230 kV substation additional circuit breaker was added to the model (5/2020)
  - National Grid project to reconductor the Niagara-Packard #193 and #194 115 kV lines in-service date changed from summer 2020 to summer 2022
  - National Grid projects to reconductor the following lines were added to the model:
    - Niagara-Packard (#192) 115 kV (11/2021)
    - Niagara-Packard (#191) 115 kV (2/2022)
    - Walack-Huntley (#133) 115 kV (6/2023)
    - Packard-Huntley (#130) 115 kV (6/2023)



## **Deactivation Assessment Information**

- The NYISO is performing the assessment of the BPTF
- The assessment of the non-BPTF will be performed by:
  - NYSEG/RG&E, National Grid, NYPA
- The Generator Deactivation Assessment for Somerset will be completed by March 11, 2020



Changes from the CRP Case reviewed at Prior Generator Deactivation Key Study Assumptions



## Changes from the CRP Case

- The following updates are included for this assessment:
  - Load updated to match the 2019 Load and Capacity Data Report ("Gold Book") forecast
  - Transmission
    - All firm Transmission Owner Local Transmission Plans (LTPs) from the 2019 Gold Book are included with the exception of the NYSEG Coopers Corners 345/115 & 115/34.5 kV transformers (due to target I/S outside of the inclusion period)
    - Also included:
      - AC Transmission selected projects NAT/NYPA TO27 and National Grid/Transco TO19
    - NYPA Moses 230/115 kV AT2 transformer is removed for the 2020 summer peak
  - Generation Removals
    - Q#511 Ogdensburg
      - Generators that have completed their Generator Deactivation Assessments that were in-service in the CRP are provided at the end of this presentation for reference
  - Generation Additions
    - Q#505 Ball Hill Wind



## **Completed Generator Deactivation Assessments**

- The following Generators have completed their Generator Deactivation Assessments that were in-service in the CRP:
  - Monroe Livingston (Zone B, Nameplate 2.4 MW) (Retire)
  - Auburn State St (Zone C, Nameplate 7.4 MW) (Retire)
  - Steuben County LF (Zone C, Nameplate 3.2 MW) (Retire)
  - Hudson Ave 4 (Zone J, Nameplate 16.3 MW) (Retire)
  - Albany LFGE (Zone F, Nameplate 5.6 MW) (Retire)
  - Cayuga 1 (Zone C, Nameplate 155.3 MW) (Mothball)
  - Hudson Ave 3 (Zone J, Nameplate 16.3 MW) (IIFO)



## **CRP Assumptions**



## 2019-2028 CRP

- The 2019-2028 CRP re-iterates RNA's conclusion that there are no Reliability Needs on the BPTF over the 10-year Study Period
- This conclusion is based on the CRP base case, which was developed by updating the RNA Base Case:

Changes from the 2018 RNA to 2018 CRP Base Case	Zone	ΔMW (DMNC)	Notes
Add back Pilgrim I and II	К	+90	Rescission of GDA Notice (Nov 2018)
Remove Cayuga II	С	-140	ICAP Ineligible Forced Outage as of 7/1/2018
Add back Selkirk I and II	F	+360	Rescission of GDA Notice (Dec 2018)
ConEdison's B3402 & C3403 345 kV cables out of service	J	-	Long-term unavailability
By-pass the Series Reactors on 71, 72, M51, M52 for summer (with Y49, 41, 42, SR in service)	J	-	After Indian Point 2 and 3 Deactivations (2020 and 2021)
J to K (Jamaica ties) emergency limit represented in the MARS topology changed from 235 MW to 320 MW	J to K	+85*	Due to addition of Rainey- Corona 345/138 kV PAR; target I/S summer 2019



## RNA Major Assumptions



### 2018 RNA Summer Peak Load Forecast Assumptions

Topline (former Econometric), Baseline and Adjusted Summer Peak Forecast

Annual MW	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
2018 Topline* Forecast	33,763	34,099	34,367	34,554	34,727	34,946	35,132	35,442	35,750	35,982	36,154
2018 Gold Book Baseline**	32,904	32,857	32,629	32,451	32,339	32,284	32,276	32,299	32,343	32,403	32,469
+ 2018 Solar PV	440	566	689	774	843	889	928	963	989	1,017	1,038
2018 RNA RA Base Case***	33,344	33,423	33,318	33,225	33,182	33,173	33,204	33,262	33,332	33,420	33,507

#### Comparison of Base Case Peak Forecasts - 2016 & 2018 RNA (MW)

Annual MW	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
2016 RNA RA Base Case***	33,618	33,726	33,825	33,948	34,019	34,120	34,256	34,393	34,515	34,646	34,803		
2018 RNA RA Base Case***			33,344	33,423	33,318	33,225	33,182	33,173	33,204	33,262	33,332	33,420	33,507
Change from 2016 RNA			-481	-525	-701	-895	-1,074	-1,220	-1,311	-1,384	-1,471	NA	NA

#### The Gold Book 2018 contains additional details on the load forecast:

http://www.nyiso.com/public/webdocs/markets\_operations/services/planning/Documents\_and\_Resources/Planning\_Data\_and\_Reference\_Docs/Data\_and\_Reference\_Docs/2018-Load-Capacity-Data-Report-Gold-Book.pdf



<sup>\*</sup> The topline forecast will be used for the resource adequacy scenario

<sup>\*\*</sup> The transmission security power flow RNA base cases use this Gold Book baseline forecast

<sup>\*\*\*</sup>For the resource adequacy (RA) study RNA Base Case, the 2018 Gold Book baseline load forecast was modified by removing the behind-the-meter solar PV impacts in order to model the solar PV explicitly as a generation resource to account for the intermittent nature of its availability

Queue#	Project Name	Zone	CRIS Request	SP MW	Interconnection Status						
Proposed Ge	Proposed Generation Additions										
251	CPV Valley Energy Center	G	680.0	677.6	CY11						
349	Taylor Biomass	G	19.0	19.0	CY11						
395	Copenhagen Wind	E	79.9	79.9	CY15						
403	Bethlehem Energy Center Uprate	F	78.1	72.0	CY15						
387	Cassadaga Wind	А	126.0	126.0	CY17						
421	Arkwright Summit	Α	78.4	78.0	CY17						
444	Cricket Valley Energy Center II	G	1020.0	1020.0	CY17						
461	East River 1 Uprate	J	n/a	2.0	CY17						
462	East River 2 Uprate	J	n/a	2.0	CY17						
467	Shoreham Solar	K	24.9	25.0	CY17						
510	Bayonne Energy Center II	J	120.4	120.4	CY17						
511	Ogdensburg	E	79.0	79.0	CY17						
N/A	Nine Mile Point 2	С	63.4	63.4	CY17 (CRIS only)						
N/A	East River 6	J	8.0	N/A	CY17 (CRIS only)						
	MW additions from	1,598	1,588								
	Total MW ger	2,377	2,364								

# Proposed Generation Projects Included in the 2018 RNA Base Case

Also included in the 2016 RNA



## Proposed Transmission Projects Included in the 2018 RNA Base Case

- All firm LTPs from the Gold Book 2018 were included in the 2018 RNA Base Case
- The Q545A Western NY Empire State Line is also included



Owner/Operator	Plant Name	Zone	CRIS	2018 RNA Base Case Status*	2016 RN Base Cas Status	
Helix Ravenswood LLC	Ravenswood 04	J	15.2	out	out	
	Ravenswood 05	J	15.7	out	out	
	Ravenswood 06	J	16.7	out	out	
International Paper Company	Ticonderoga	F	7.6	out	in	
Niagara Generation LLC	Niagara Bio-Gen	A	50.5	out	out	
NRG Power Marketing LLC	Dunkirk 2	A	97.2	out	out	
	Huntley 67	A	196.5	out	out	
	Huntley 68	A	198.0	out	out	
	Astoria GT 05	J	16.0	out	out	
	Astoria GT 07	J	15.5	out	out	
	Astoria GT 08	J	15.3	out	out	
	Astoria GT 10	J	24.9	out	out	
	Astoria GT 11	J	23.6	out	out	
	Astoria GT 12	J	22.7	out	out	
	Astoria GT 13	J	24.0	out	out	
ReEnergy Black River LLC	Fort Drum	E	55.6	out	in	
	Chateaugay Power	D	18.6	out	out	
Binghamton BOP, LLC	Binghamton	С	43.8	out	in	
Helix Ravenswood, LLC	Ravenswood 09	J	21.7	out	in	
Entergy Nuclear Power	Indian Point 2	Н	1027.0	out	in	
Marketing, LLC	Indian Point 3	Н	1040.0	out	in	
Selkirk Cogen Partners, LP	Selkirk 1	F	82.1	out	in	
	Selkirk 2	F	291.3	out	in	
J- Power USA Generation, LP	PPL Pilgrim ST GT1	K	45.6			
Edgewood Energy, LLC	PPL Pilgrim ST GT2	K	46.2	out	in	
Helix Ravenswood, LLC	Ravenswood 2-1	J	40.4			
	Ravenswood 2-2	J	37.6			
	Ravenswood 2-3	J	39.2			
	Ravenswood 2-4	J	39.8	out	in	
	Ravenswood 3-1	J	40.5			
	Ravenswood 3-2	J	38.1			
	Ravenswood 3-4	J	35.8			
Lyonsdale Biomass, LLC	Lyonsdale (Burrows)	E	20.2	out	in	
R.E. Ginna Nuclear Power Plant LLC	Ginna	В	582.0	in	out	
Cayuga Operating Company,	Cayuga 1	С	154.1	in	out	
LLC	Cayuga 2	С	154.7	in	out	
Entergy Nuclear Power Marketing LLC	Fitzpatrick 1	С	858.9	in	out	
change in status	Changes in deactivations sin	ce 2016 RPP	1,203			
	Total 2018 RNA MW assume	d as deactivated	3,703			

# Assumed Generation Deactivations



<sup>\*</sup> Consistent with the deactivation dates

## Our mission, in collaboration with our stakeholders, is to serve the public interest and provide benefit to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policymakers, stakeholders and investors in the power system



