

# 2019 CARIS 70x30 Scenario: Review of Assumptions and Resource Mix

---

**Benjamin Cohen**

Sr. Planning Environmental Engineer

**Electric System Planning Working Group**

February 27, 2020

# Agenda

- **Background and Study Approach**
- **Scenario Assumptions**
- **Renewable Resource Mix**
- **Preliminary Relaxed Case Results**

# Background and Study Approach

# Background

- **Previously presented at ESPWG**
  - September 11
    - CARIS Preliminary 70 x 30 Scenario Development
  - October 4
    - CARIS Scenario Load Forecast Development
    - CARIS 1 70x30 Scenario ESR Modeling
  - October 23
    - CARIS 70x30 Scenario Assumptions and Calculation
  - November 18
    - Preliminary Scenario Results (High/Low Gas Prices and Loads)

# “70 by 30” Scenario

- The study will identify opportunities for transmission investment to un-bottle renewable energy to enable the state’s renewable energy production goals.
- The Climate Leadership and Community Protection Act (CLCPA) requires that a minimum of 70% of New York end-use electrical energy requirements shall be generated by renewable energy systems in 2030.

# Scenario Study Approach

- **Develop assumptions for the major drivers that could impact transmission congestion patterns**
  - Develop 70x30 Scenario Load Forecast for comparison with the Base Case Forecast
  - Add renewable generation to approximate achievement of 70% renewable energy target for each load forecast, considering renewable energy “spillage” (*i.e.*, generation exceeds load)
- **Evaluate system production under “relaxed” conditions**
  - Model the resulting resource mix in GE-MAPS without internal NYCA transmission system constraints to establish a baseline of what the system “wants to do” when there are no transmission constraints
- **Evaluate the impact of transmission constraints on renewable energy production for the assumed renewable resource mix**
  - Identify transmission constraints that cause renewable curtailments (*i.e.*, renewable generation pockets)
  - Quantify the magnitude and frequency of the curtailments for each assumed resource mix
- **Sensitivity analysis to understand impact to system production and transmission constraints**
  - Sensitivity analysis of retirement of the entire nuclear fleet
  - Sensitivity analysis of 3,000 MW of Energy Storage Resources (ESR)

# Scenario Assumptions


# Key Policy Drivers for Study Assumptions

- 70% of end-use energy shall be generated by renewable energy systems by 2030
- 6,000 MW of distributed solar by 2025
- 185 trillion Btu of end-use energy savings below the 2025 energy-use forecast
- 3,000 MW of energy storage resources (ESR) by 2030
- 9,000 MW of offshore wind (OSW) by 2035

# Emission Reductions Not Studied

- 2030 – 40% economy-wide GHG reduction
- 2040 – “zero emission” power sector
- 2050 – 85% economy-wide GHG reduction (and up to 15% additional as offsets)
  - “Sources in the electric generation sector shall not be eligible” to offset emissions

Figure 23:  
NYS Energy-Related CO<sub>2</sub> Emissions by Sector



2019 Power Trends (2016 data),  
<https://www.nysenate.gov/legislation/bills/2019/s6599>

Source: U.S. EIA

# 70x30 Scenario Adjustments

Started from the 2019 CARIS 1 base case 2028 model year

## ■ Load Forecast/Shape

- Scenario load includes zonal 8,760 hourly profiles with non-uniform distribution of energy efficiency (EE), electrification (electric vehicles and space heating), and behind-the-meter solar (BTM-PV)
- Base (2019 Gold Book) load level studied for comparison to the 70x30 Scenario load forecast

## ■ Renewable Energy (RE) Modeling, Locations and Amounts

- Land-based wind generation based on NREL shapes instead of historic actual output
- Zonal capacity distribution informed by NYSERDA RFP Awards and NYISO Interconnection Queue
- Bus assignments for added RE based on Interconnection Queue project information

## ■ Neighboring system assumptions

- Hydro-Québec (HQ) imports counted as renewable
- Additional HVDC connection included with HQ schedule to NYC



## ■ NY Fossil Fleet Operations

- All coal plants assumed retired; all GTs impacted by Peaker Rule assumed retired and replaced with new GTs consistent with 2019-2028 CRP Scenario findings

# 70x30 Scenario Load Forecast Assumptions

|  | Base Case Load Forecast  | 70x30 Scenario Load Forecast  |
|--|--|---|
| <b>EV</b>  | 1.3 million Light-duty vehicles by 2030                                      | 2.2 million Light-duty vehicles by 2030   |
| <b>Space Heating Electrification</b>   | None   | 2015 estimate of 13,600 GWh in 2015 grows by 50% by 2030 for NYCA   |
| <b>PV</b>  | 3,000 MWDC behind-the-meter by 2023  | 6,000 MWDC behind-the-meter by 2025   |
| <b>EE</b>  | 23,500 GWh of incremental savings by 2030 beyond the 11 GWh achieved by 2014 | Additional 30,000 GWh* of savings by 2025 beyond 2014 achievements plus around 2,000 GWh/year** for 2026-30 |
| * This target is based on the retail sales of investor-owned utilities implied by the 2015 Gold Book forecast for the year 2025. |  |   |
| ** This is based on the targets expressed in the Clean Energy Fund documents.  |  |   |

# 70x30 Scenario Load Forecast



The net load in 2030 is assumed to be approximately 136,000 GWh resulting from the cumulative impacts of EE (56.7 TWh), BTM-PV (9.4 TWh), DG (2.7 TWh) and EV (8.7 TWh) plus an incremental 6 TWh due to electrification of space heating (Elec).

| Annual Load (GWh)   | A      | B     | C      | D     | E     | F      | G     | H     | I     | J      | K      | NYCA    |
|---------------------|--------|-------|--------|-------|-------|--------|-------|-------|-------|--------|--------|---------|
| Base Case Load      | 14,590 | 9,695 | 15,394 | 5,337 | 7,095 | 11,312 | 9,544 | 2,807 | 5,881 | 51,749 | 19,608 | 153,012 |
| 70x30 Scenario Load | 13,034 | 7,757 | 12,626 | 5,101 | 5,694 | 9,654  | 7,911 | 2,848 | 5,952 | 46,354 | 19,026 | 135,958 |

# Renewable Resource Mix

# Renewable Additions

- Capacity additions of utility-scale solar (UPV) and land-based wind (LBW) are adjusted to achieve 70% RE
- Developed zonal capacity distribution based on UPV and LBW capacity shares by zone from the 2017 and 2018 CES REC solicitation awards and the NYISO Interconnection Queue

| <b>Nameplate Capacity Distribution</b> |             |             |
|--|-------------|-------------|
|  | <b>UPV</b>  | <b>LBW</b>  |
| <b>A</b>                               | <b>27%</b>  | <b>30%</b>  |
| <b>B</b>                               | <b>3%</b>   | <b>5%</b>   |
| <b>C</b>                               | <b>20%</b>  | <b>30%</b>  |
| <b>D</b>                               | <b>0%</b>   | <b>15%</b>  |
| <b>E</b>                               | <b>10%</b>  | <b>20%</b>  |
| <b>F</b>                               | <b>25%</b>  | <b>0%</b>   |
| <b>G</b>                               | <b>15%</b>  | <b>0%</b>   |
| <b>H</b>                               | <b>0%</b>   | <b>0%</b>   |
| <b>I</b>                               | <b>0%</b>   | <b>0%</b>   |
| <b>J</b>                               | <b>0%</b>   | <b>0%</b>   |
| <b>K</b>                               | <b>0%</b>   | <b>0%</b>   |
| <b>NYCA</b>                            | <b>100%</b> | <b>100%</b> |

# Renewable Addition Locations

- **Injection points are assumed to be the closest existing substations based on interconnection points from the NYISO Interconnection Queue**
- **Study Assumptions:**
  - UPV: 73 sites, injecting at various voltage levels from 345 kV – 115 kV
  - LBW: 30 sites, injecting at various voltage levels from 345 kV – 115 kV
  - OSW: 7 sites, injecting at 345 kV in Zone J and 138 kV – 69 kV in Zone K
  - Hydro imports: 1 site, injecting at 345 kV in Zone J (generic 1310 MW HVDC)

# Initial Annual 70x30 Input Calculation

- RE = Wind + Solar + Hydro + Hydro Imports
- Assume, %RE = RE / Gross Load

|                             | OSW    | LBW    | UPV    | BTM-PV | Hydro  | Hydro Imports | RE      | Net Load | Gross Load | %RE |
|-----------------------------|--------|--------|--------|--------|--------|---------------|---------|----------|------------|-----|
| <b>Base MW</b>              | 0      | 2,212  | 77     | 4,011  |        |               |         |          |            |     |
| <b>Additional MW</b>        | 6,098  | 1,641  | 6,345  | 3,531  |        |               |         |          |            |     |
| <b>2030 MW</b>              | 6,098  | 3,853  | 6,422  | 7,542  |        |               |         |          |            |     |
| <b>2030 Capacity Factor</b> | 44%    | 30%    | 18%    | 14%    |        |               |         |          |            |     |
| <b>2030 Calculated GWh</b>  | 23,344 | 10,126 | 10,126 | 9,366  | 28,832 | 19,941        | 101,735 | 135,970  | 145,335    | 70% |


Net Load accounts for BTM-PV; Gross Load does not.

# 70x30 Renewable Capacity Calculation

- **Initial input calculation of annual RE does not consider hourly coincidence between RE production and load levels**
- **Use hourly input production and NYCA load profiles to account for spillage and define 70x30 case RE capacity mix**
  - For each hour, compare projected nuclear and renewable generation to NYCA gross load.
  - “Spillage” occurs when generation exceeds NYCA gross load.
  - For the purposes of this scenario, spillage is not counted towards 70% RE attainment.
- **This method is used as a simple benchmark to establish RE capacity levels**



# Hourly Input Profile Calculation Illustration

NYCA Hourly Input Energy Relative to Load in 2030:  
70x30 Scenario Load Case





- Compare hourly gross load (black line) to nuclear (yellow) and renewable energy (green) input generation profiles
- Spillage (red) occurs when renewable generation exceeds load
- Renewable energy target assumed to be attained when total renewable generation (green) equals 70% of total gross load on an annual basis

# Hourly Input profiles: Peak loads



# Hourly Input profiles: Minimum Load



# 70x30 Renewable Capacity Calculation

- For the purpose of determining how much renewable capacity to model for both load shapes/levels (70x30 Scenario load and base load forecasts), renewable energy is calculated as:

$$\%RE = ( RE_{Input} - Spillage ) / Gross Load$$

- The initial capacity mix results in approximately 4,800 GWh of spillage in the scenario load and 5,200 GWh of spillage in the base load
- Increased LBW and UPV capacity until 70% RE attained based on hourly input profiles

| Input (GWh)          | OSW    | LBW    | UPV    | BTM-PV | Hydro  | Hydro Imports | RE <sub>Input</sub> | Spillage | Gross Load | %RE |
|----------------------|--------|--------|--------|--------|--------|---------------|---------------------|----------|------------|-----|
| <b>Scenario Load</b> | 23,359 | 16,874 | 16,651 | 9,366  | 28,702 | 19,941        | 114,892             | 12,605   | 145,324    | 70% |
| <b>Base Load</b>     | 23,359 | 23,233 | 23,264 | 9,366  | 28,702 | 19,941        | 127,864             | 13,524   | 162,378    | 70% |

# Resulting Zonal Wind and Solar MW Capacity

70x30 Scenario Load

| 2030 MW     | OSW          | LBW          | UPV           | BTM-PV       |
|-------------|--------------|--------------|---------------|--------------|
| A           |              | 1,640        | 3,162         | 995          |
| B           |              | 207          | 361           | 298          |
| C           |              | 1,765        | 1,972         | 836          |
| D           |              | 1,383        |               | 76           |
| E           |              | 1,482        | 1,247         | 901          |
| F           |              |              | 2,563         | 1,131        |
| G           |              |              | 1,450         | 961          |
| H           |              |              |               | 89           |
| I           |              |              |               | 130          |
| J           | 4,320        |              |               | 950          |
| K           | 1,778        |              | 77            | 1,176        |
| <b>NYCA</b> | <b>6,098</b> | <b>6,476</b> | <b>10,831</b> | <b>7,542</b> |

Base Load

| 2030 MW     | OSW          | LBW          | UPV           | BTM-PV       |
|-------------|--------------|--------------|---------------|--------------|
| A           |              | 2,286        | 4,432         | 995          |
| B           |              | 314          | 505           | 298          |
| C           |              | 2,411        | 2,765         | 836          |
| D           |              | 1,762        |               | 76           |
| E           |              | 2,000        | 1,747         | 901          |
| F           |              |              | 3,592         | 1,131        |
| G           |              |              | 2,032         | 961          |
| H           |              |              |               | 89           |
| I           |              |              |               | 130          |
| J           | 4,320        |              |               | 950          |
| K           | 1,778        |              | 77            | 1,176        |
| <b>NYCA</b> | <b>6,098</b> | <b>8,772</b> | <b>15,150</b> | <b>7,542</b> |

# Preliminary Relaxed Case Results


# Preliminary Relaxed Case MAPS Output

- “Relaxed” case: no transmission constraints modeled inside NYCA
- Curtailments are due to (1) transmission constraints with neighboring regions, or (2) excess generation compared to system-wide load

| Output (GWh)  | OSW    | LBW    | UPV    | BTM-PV | Hydro  | Hydro Imports | RE      | Nuclear | Fossil | Other | *Net Exports | Curtailments | Gross Load |
|---------------|--------|--------|--------|--------|--------|---------------|---------|---------|--------|-------|--------------|--------------|------------|
| Scenario Load | 22,775 | 13,960 | 14,764 | 9,269  | 28,082 | 19,803        | 108,653 | 27,435  | 26,390 | 2,164 | 18,821       | 6,239        | 144,948    |
| Base Load     | 22,656 | 19,243 | 21,782 | 9,302  | 27,974 | 19,780        | 120,736 | 27,436  | 31,268 | 2,158 | 18,736       | 7,128        | 161,934    |

\* Net Exports between NYISO and IESO, ISO-NE, and PJM

# Hourly Output Profile Illustration



- Displays output energy production by type from MAPS simulations
- RE curtailments occur due to excess generation or external transmission constraints
- “Relaxed”: No transmission constraints are modeled inside NYCA



“Other” includes Methane (Biogas), Refuse (Solid Waste), and Wood fuel-fired generators

“Imports” includes imports from IESO, ISO-NE, and PJM

# Modeling of Fossil Generation

- **Reasons why fossil generation runs in the model:**
  - Serve load in the absence of sufficient renewable resources
  - Meet locational reserve requirements
  - Meet Local Reliability Rules
  - Serve steam contracts
  - Operational limitations such as min. gen levels and min. runtime
- **Operational considerations not modeled in MAPS:**
  - Ramp rates and real-time sub-hourly variations
  - Energy and Ancillary Service co-optimization
  - Fuel availability or gas system constraints

# Sample comparison of CARIS Base Case and Scenario Base Load Case





CARIS Base Case chart is for 2028 and Scenario Base Load Case chart is for 2030.

“Other” includes Methane (Biogas), Refuse (Solid Waste), and Wood fuel-fired generators

“Imports” includes imports from IESO, ISO-NE, and PJM

# Sample comparison of CARIS Base Case and Scenario Base Load Case: Peak Loads





CARIS Base Case chart is for 2028 and Scenario Base Load Case chart is for 2030.

“Other” includes Methane (Biogas), Refuse (Solid Waste), and Wood fuel-fired generators

“Imports” includes imports from IESO, ISO-NE, and PJM



# Sample Scenario Output Profiles: Peak Loads



“Other” includes Methane (Biogas), Refuse (Solid Waste), and Wood fuel-fired generators

“Imports” includes imports from IESO, ISO-NE, and PJM

# Sample Scenario Output Profiles: Minimum Load



“Other” includes Methane (Biogas), Refuse (Solid Waste), and Wood fuel-fired generators  
“Imports” includes imports from IESO, ISO-NE, and PJM

# Next Steps

- Discuss transmission system constraint modeling and review production results reflecting NYCA transmission constraints
- Review sensitivity analysis of nuclear retirements and energy storage
- Review model results for fossil fuel-fired fleet
- Identify transmission constraints that cause renewable curtailments (*i.e.*, renewable generation pockets)
- For each pocket, quantify the magnitude and frequency of the curtailments for each assumed resource mix

# Questions?

# Our mission, in collaboration with our stakeholders, is to serve the public interest and provide benefit to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policymakers, stakeholders and investors in the power system

