

# **NYISO'S Comprehensive Reliability Planning Process**

## **2008 RNA Results and Review of Inputs**

NYISO Management Committee


Agenda Item 4

November 14, 2007

# Presentation Topics

- Process Overview
- Review of Input Assumptions
- Summary of Results
- Scenarios
- Recommendation

# NYISO Reliability Planning Process



# Review of Input Assumptions

- 2007 Load and Capacity Report
- Lovett 5, Russell 1-4, and Poletti Retired by 1/31/2010
- Gilboa Uprate, Prattsburgh Wind and Caithness Installed
- Updated External Representations
- Resource Adequacy Analysis Database Starts from the Latest IRM Database
- Neptune modeled as Emergency Assistance in the Study case, and Firm Capacity in Zone K in a Sensitivity case
- Besicorp 635 MW Net Generation Analyzed as Scenario

# RNA 2008 Load & Resource Table


Year	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017
<b>Peak Load</b>										
NYCA	33,871	34,300	34,734	35,141	35,566	35,962	36,366	36,749	37,141	37,631
Zone J	11,975	12,150	12,325	12,480	12,645	12,780	12,915	13,030	13,140	13,360
Zone K	5,485	5,541	5,607	5,664	5,730	5,791	5,855	5,919	6,002	6,076
<b>Resources</b>										
NYCA										
"- Capacity"	38,917	39,257	38,396	38,396	38,396	38,284	38,284	38,284	38,284	38,284
"- SCR"	1323	1323	1323	1323	1323	1323	1323	1323	1323	1323
Total	40,240	40,580	39,719	39,719	39,719	39,607	39,607	39,607	39,607	39,607
<b>Zone J</b>										
"- Capacity"	10,019	10,019	9,128	9,128	9,128	9,015	9,015	9,015	9,015	9,015
"- SCR"	468.7	468.7	468.7	468.7	468.7	468.7	468.7	468.7	468.7	468.7
Total	10,487	10,487	9,596	9,596	9,596	9,484	9,484	9,484	9,484	9,484
<b>Zone K</b>										
"- Capacity"	5,612	5,922	5,922	5,922	5,922	5,922	5,922	5,922	5,922	5,922
"- SCR"	159.5	159.5	159.5	159.5	159.5	159.5	159.5	159.5	159.5	159.5
Total	5,772	6,082	6,082	6,082	6,082	6,082	6,082	6,082	6,082	6,082
<b>NYCA Resource Margin % (1)</b>	118.8%	118.3%	114.4%	113.0%	111.7%	110.1%	108.9%	107.8%	106.6%	105.3%
<b>Zons J Res./Load/ Ratio</b>	87.6%	86.3%	77.9%	76.9%	75.9%	74.2%	73.4%	72.8%	72.2%	71.0%
<b>Zons K Res./Load Ratio</b>	105.2%	109.8%	108.5%	107.4%	106.1%	105.0%	103.9%	102.7%	101.3%	100.1%

Note: LIPA Edge program of about 40MW not accounted in Zone K; impact to LOLE is not observable

New York Control Area  
 Transmission System Representation  
 For 2008 IRM Study  
 Summer Ratings

Draft 10/17/2007

Figure A-10




\* $(K \text{ to } I) + (K \text{ to } J) + 0.4(K \text{ to } \text{PJM East})$

# Summary of Study Case Results

- Initial year of need is 2012 for 500 MW in J or 250 MW each in F, G (or H and I), and J
  - *Same For Study, Thermal, and Free Flow (within lumpiness)*
  - *Initial year of need changes to 2013 if Neptune has Firm Capacity Contract in PJM*
  - *Transmission upgrades have brought transfer limits closer to thermal limits for key interfaces*
- Approximately 2750 MW of compensatory MW will be needed by 2017
  - *Load growth is nearly 1000MW above 2007 RNA (comparing 2017 with 2016)*

## Summary of the LOLE Results for the RNA Study Case, Thermal and “Free Flowing” Sensitivities





	<u>Year of Need</u>	<u>LOLE 2012</u>	<u>LOLE 2017</u>
<b>Study Case</b>	2012	0.19	0.90
Neptune Sensitivity	2013	0.09	0.72
<b>Scenarios</b>			
1. High Economic Growth	2010	0.73	2.21
2.1. NOx ("HEDD") Initiative	2009	0.33	2.86
2.2. CO2 RGGI (52 million tons Allowances required in 2010 for LOLE $\leq$ 0.1 day/year)			
3. The 15x15 Conservation	<i>None</i>	0.01	0.03
4. Besicorp 635 MW Net Generation	2012	0.16	0.79
5. In-City 500 MW Generation	2013	0.10	0.62
6. External Capacity	2012	0.13	0.75

# Scenario: HEDD in 2009

- Reliability criteria are violated in 2009, if 50.8ton/day reduction is required
- Additional options will need to be developed in order to simultaneously achieve the necessary NOx reductions while satisfying reliability criteria
  - *Emission control retrofits where feasible*
  - *Flexible source averaging plans*
  - *Timely permitting and construction of new low emitting generation*
  - *Focused and measurable energy efficiency and demand response programs*

Table 4.12: HEDD Scenario LOLE Results

Area/Year	2009	2010	2011	2012	2013	2014	2015	2016	2017
AREA-A									
AREA-B	0.06	0.10	0.13	0.21	0.27	0.40	0.60	0.80	0.96
AREA-C									
AREA-D					0.00	0.00	0.00	0.00	0.00
AREA-E	0.02	0.06	0.06	0.12	0.16	0.26	0.41	0.54	0.64
AREA-F				0.00	0.00	0.00	0.00	0.00	0.00
AREA-G	0.03	0.11	0.11	0.20	0.28	0.38	0.53	0.66	0.62
AREA-H									
AREA-I	0.27	0.74	0.63	1.05	1.39	1.75	2.15	2.50	2.60
AREA-J	0.29	0.79	0.66	1.08	1.42	1.77	2.22	2.62	2.75
AREA-K	0.11	0.14	0.13	0.28	0.39	0.53	0.70	0.93	1.00
NYCA	0.33	0.83	0.71	1.15	1.52	1.90	2.34	2.75	2.86

# Scenarios: CO2 or “RGGI” Case

- NYS cap: 64 million tons of CO2
- Year 2010 was analyzed
  - *Poletti retired*
  - *1250 MW of additional carbon intensive units restricted*
- Analysis was performed to determine the minimum number of allowances needed to meet reliability criteria.
  - *Result: 52 million tons.*
  - *Risk to reliability if allowances are restricted below this level*
  - *RPS could reduce this amount by 3.1 million tons in 2013*

# Recommendation

- Draft RNA Report was reviewed at four joint ESPWG/TPAS meetings and stakeholder comments have been incorporated
- Board member comments have also been reflected
- IMA comments have been posted
- OC concurred with the findings of the 2008 RNA Report at the November 6, 2007 Meeting
- Recommendation (See Motion):
  - *Recommend concurrence by the MC*
  - *Recommend approval by the NYISO Board*