

APPENDIX ?

Agreement Between ISO NE And NYISO For Recognizing Assistance Available Under The Shared Activation Of Ten Minute Reserve Procedure

This Appendix describes an agreement between ISO NE and NYISO for the mutual utilization of the assistance available from the Shared Activation of Ten Minute Reserve Procedure (SAR).

Pre-contingency, both **Areas** shall ensure that sufficient resources are committed to meet the reserve requirements prescribed by NPCC Document A-6 – Operating Reserve Criteria without relying on available SAR energy. Post-contingency, the contingent **Area** may count the SAR energy available from the other **Area** towards its reserve requirements temporarily to assist in reserve restoration within the time specified by A-6.

The terms of the agreement are described below.

1. Post-contingency, the contingent **Area** shall limit the SAR assistance contribution to its reserve requirements to 300 MW.
2. Post-contingency, the contingent **Area** must meet the reserve requirements specified in A-6 within the time frame specified in A-6, including the SAR assistance stipulated in (1).
3. Post-contingency, the contingent **Area** may use SAR assistance available to meet its A-6 reserve requirements for up to 4 hours.
4. Unless the system of the contingent **Area** is stressed severely, the contingent **Area** shall not use SAR assistance available to meet A-6 reserve requirements after an initial contingency if the size of the initial contingency is less than the reportable event threshold.