

Persistent Dragging

April 6, 2004

NYISO Market Structures Working Group

Generation Issues Task Force Meeting

Brad Kranz/Bob Thompson

Discussion Outline

- **Background**
- **Survey Objectives and Process Description**
- **Current Conditions Summary**
- **Recommendations**
 - *Short term (legacy)*
 - *Long term (SMD2)*

Background

- **Refer to 8/29/03 Generators Meeting Presentation on Persistent Dragging**
- **Primary Causes**
 - *Gen failure to respond to dispatch instructions*
 - *Gen failure to ramp at defined response rate*
- **Problem most severe during high load months**
- **ISO survey of generation to assess causes and inform potential solutions**

Survey Objectives and Process Description

➤ Objectives

- *Focus on real-time plant operation and management issues.*
- *Assess communications integrity*
- *Understand operational considerations affecting generation response to ISO dispatch instructions*

Survey Objectives and Process Description

➤ Survey Process

- *NYISO Staff visited 12 plants – majority on-dispatch units*
- *Located in 7 TO operating areas*
- *Utilized a common question template – (attached)*
- *Interviewed plant managers and operators in the generator control rooms*
- *Assessed actual real-time on-line communications integrity during visits*

Survey Results

- **No silver bullet discovered**
- **No systematic problem with ISO/TO/Gen plant telemetric controls process**
- **However, feedback indicates SMD (RTS) will provide a most helpful ingredient**
 - *Forecast advisory dispatch of each individual generators operating profile.*

Survey Results

- **Operators note that units are at times being dispatched in an apparently choppy manner**
 - *Is inconsistent with efficient plant operation*
 - *Difficult to manage plant operational constraints*
 - *Likely a SCD reaction to GT (block unit) starts and stops and/or sluggish ramping of steam.*
- **Potential exists for improvements in specification of ramp rates**
 - *Inclusion of multiple ramp rates*
 - *Adjustment of current rates to more consistently achievable levels*

Survey Results

➤ **Plant response is effected by operator consideration of:**

- *Environmental performance requirements*
- *Operating requirements affecting efficiency*
- *Hold points to verify basepoint directional consistency*
 - ▶ Mill points and gun insertion points
 - ▶ Avoiding rough operating regions
- *Inconsistency between fuel contract provisions and electric system demands.*

Recommendations

(Short Term – Legacy)

- **Ramp performance evaluation and adjustment to meet unit achieved performance**
 - *Daily dragging unit evaluation and response/rate update*
- **Necessity for units to communicate short term operational constraints (stopping points or operating issues) to the ISO**
 - *Units inform the TO*
 - *TO to inform the ISO*
 - *Units communicate release from the temporary condition*

Recommendations

(Long Term – SMD)

- **RTS forecast features will be the greatest benefit to plant operators**
 - *Provides information to proactively operate plants and follow basepoints*
 - *Need to ensure that owners setup access to the displays for the plant operators.*
- **RTD forward optimization horizon should improve the smoothness of the dispatch.**
 - *Need to monitor testing and initial operation to assess level of improvements in smoothing the 5 minute dispatch.*

Recommendations

(Long Term – SMD)

➤ **Other potential actions for further consideration:**

- *Evaluate the 15-minute dispatch as an alternative for less responsive units*
- *Enhanced modeling to include definition of forbidden zones for dispatch*
- *Improve plant flexibility by grouping steam units (a la GTs) and providing desired net output*
- *Examine opportunities to improve consistency between gas contracts and electric system market requirements*