

Autumn 2008 TCC Auction - Existing Transmission Capacity for Native Load Nominations

ETCNL - Attachment M Table 2

	Holder of ETCNL	Name of Set of ETCNL	Point of Injection	Point of Withdrawal	Transmission Capacity (MW)	ETCNL Sold in Previous Auctions (MW)	ETCNL Reduction to ensure feasibility (MW)	Remaining ETCNL Capacity (MW)	ETCNL Reservation (5%) Based on Total ETCNL Capacity	TO Nominations of ETCNL Reservations (MW)
1	Con Edison	Native Load-Bowline	Bowline	Millwood Zone	33	8	0	25	1	0
2	Con Edison	Native Load-Bowline	Bowline	Dunwoodie Zone	184	46	2	136	9	0
3	Con Edison	Native Load-Bowline	Bowline	NYC Zone	584	146	248	190	29	29
4	Con Edison	Native Load- HQ	Pleasant Valley 345kV	Millwood Zone	8	4	0	4	0	0
5	Con Edison	Native Load- HQ	Pleasant Valley 345kV	Dunwoodie Zone	48	23	1	24	2	0
6	Con Edison	Native Load- HQ	Pleasant Valley 345kV	NYC Zone	152	73	53	26	7	7
7	Con Edison	Native Load - Gilboa	Pleasant Valley 345kV	Millwood Zone	5	1	0	4	0	0
8	Con Edison	Native Load - Gilboa	Pleasant Valley 345kV	Dunwoodie Zone	29	7	0	22	1	0
9	Con Edison	Native Load - Gilboa	Pleasant Valley 345kV	NYC Zone	91	22	31	38	4	4
10	Con Edison	Native Load - Roseton	Roseton-#1	Millwood Zone	19	4	0	15	0	0
11	Con Edison	Native Load - Roseton	Roseton-#1	Dunwoodie Zone	110	27	2	81	5	0
12	Con Edison	Native Load - Roseton	Roseton-#1	NYC Zone	351	87	148	116	17	17
13	Con Edison	Native Load - Corinth	Pleasant Valley 345kV	Millwood Zone	5	1	0	4	0	0
14	Con Edison	Native Load - Corinth	Pleasant Valley 345kV	Dunwoodie Zone	31	7	0	24	1	0
15	Con Edison	Native Load - Corinth	Pleasant Valley 345kV	NYC Zone	98	24	42	32	4	4
16	Con Edison	Native Load - Sithe	Pleasant Valley 345kV	Millwood Zone	34	8	0	26	1	0
17	Con Edison	Native Load - Sithe	Pleasant Valley 345kV	Dunwoodie Zone	192	48	1	143	9	0
18	Con Edison	Native Load - Sithe	Pleasant Valley 345kV	NYC Zone	611	152	258	201	30	30
19	Con Edison	Native Load - Selkirk	Pleasant Valley 345kV	Millwood Zone	11	2	0	9	0	0
20	Con Edison	Native Load - Selkirk	Pleasant Valley 345kV	Dunwoodie Zone	61	15	0	46	3	0
21	Con Edison	Native Load - Selkirk	Pleasant Valley 345kV	NYC Zone	193	48	82	63	9	9
22	Con Edison	Native Load - IP2	Indian Pt 2	Dunwoodie Zone	214	53	1	160	10	0
23	Con Edison	Native Load - IP2	Indian Pt 2	NYC Zone	679	169	288	222	33	33
24	Con Edison	Native Load - IP3	Indian Pt 3	Dunwoodie Zone	26	6	0	20	1	0
25	Con Edison	Native Load - IP3	Indian Pt 3	NYC Zone	82	20	35	27	4	4
26	Con Edison	Native Load - IP Gas	Indian Pt.-GT	Dunwoodie Zone	12	3	0	9	0	0
27	Con Edison	Native Load - IP Gas	Indian Pt.-GT	NYC Zone	36	9	16	11	1	1
28	NMPC	Native Load - NMP1	Nine Mile Pt. #1	Capital Zone	610	152	0	458	30	30
29	NMPC	Native Load - NMP2	Nine Mile Pt. #2	Capital Zone	460	115	0	345	23	23
30	NMPC	Native Load - Hydro	Colton Hydro	Capital Zone	110	27	0	83	5	5
31	NYSEG	Native Load - Homer	PJM Proxy Bus	Central Zone	863	215	0	648	43	0
32	NYSEG	Native Load - Homer	PJM Proxy Bus	West Zone	100	25	0	75	5	0
33	NYSEG	Native Load -	PJM Proxy Bus	Central Zone	37	9	0	28	1	0
34	NYSEG	Native Load - BCLP	PJM Proxy Bus	Central Zone	80	20	0	60	4	0
35	NYSEG	Native Load - LEA	Gardenville 115kV	Central Zone	100	25	0	75	5	0
36	NYSEG	Native Load - Gilboa	Gilboa	Capital Zone	99	24	0	75	4	0

Total 6358 1625 1208 3525 301 196