

Tie Meter Stats for 2004 November 9, 2005

| Type | Mask ID | Total Annual Flow (GWhr) | Avg Change 4M T/U (%) | Max Change 4M T/U (%) | # 4M Changes | Avg Change 12M T/U (%) | Max Change 12M T/U (%) | # 12M Changes | Avg PTS Error (%) | Max PTS Error (%) | Meets RMRM |
|-------------|----------------|---------------------------------|------------------------------|------------------------------|---------------------|-------------------------------|-------------------------------|----------------------|--------------------------|--------------------------|-------------------|
| TIE | 1003 | 3,305.38 | 0.00% | 0.00% | 1 | 0.00% | 0.00% | 0 | 0.06% | 0.14% | N |
| TIE | 1011 | 1,103.10 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 7.36% | 11.57% | Y |
| TIE | 1012 | 29.38 | 0.01% | 0.13% | 1 | 0.00% | 0.00% | 0 | 7.37% | 14.08% | N |
| TIE | 1013 | 0.04 | 0.00% | 0.00% | 0 | 1.47% | 13.27% | 1 | 0.00% | 0.00% | Y |
| TIE | 1025 | 3.80 | 16.67% | 199.99% | 1 | 22.57% | 203.14% | 1 | 0.00% | 0.00% | Y |
| TIE | 1030 | 2,356.44 | 0.00% | 0.00% | 1 | 0.00% | 0.00% | 0 | 0.20% | 0.41% | Y |
| TIE | 1033 | 8.24 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | . | . | N |
| TIE | 1034 | 0.36 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1036 | 1,087.70 | 0.00% | 0.05% | 3 | 0.00% | 0.00% | 0 | 50.72% | 55.32% | N |
| TIE | 1038 | 89.48 | 0.22% | 2.03% | 2 | 0.01% | 0.12% | 1 | 0.30% | 1.82% | N |
| TIE | 1039 | 56.43 | 0.03% | 0.17% | 2 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1040 | 0.00 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | N |
| TIE | 1043 | 0.00 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | N |
| TIE | 1047 | 340.17 | 0.00% | 0.01% | 1 | 0.00% | 0.02% | 1 | 0.13% | 0.70% | N |
| TIE | 1056 | 90.79 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 15.84% | 61.70% | Y |
| TIE | 1063 | 58.21 | 0.54% | 6.19% | 4 | 0.00% | 0.00% | 0 | 5.87% | 30.94% | N |
| TIE | 1065 | 0.43 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1067 | 222.84 | 0.14% | 1.60% | 4 | 0.00% | 0.00% | 0 | 25.32% | 205.26% | Y |
| TIE | 1070 | 566.81 | 0.01% | 0.07% | 4 | 0.00% | 0.00% | 0 | 2.25% | 5.76% | N |
| TIE | 1073 | 506.63 | 0.00% | 0.01% | 1 | 0.00% | 0.00% | 0 | 3.29% | 6.62% | N |
| TIE | 1075 | 4.38 | 8.65% | 71.84% | 11 | 0.00% | 0.00% | 0 | 336.85% | 918.32% | Y |
| TIE | 1076 | 646.64 | 0.00% | 0.05% | 2 | 0.03% | 0.24% | 3 | 0.02% | 0.05% | N |
| TIE | 1079 | 91.49 | 0.00% | 0.01% | 1 | 0.00% | 0.00% | 0 | 0.96% | 4.13% | N |
| TIE | 1080 | 95.64 | 3.15% | 27.12% | 5 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1085 | 794.93 | 0.00% | 0.02% | 3 | 0.00% | 0.00% | 0 | 1.33% | 4.70% | Y |
| TIE | 1096 | 843.27 | 0.00% | 0.02% | 3 | 0.00% | 0.00% | 0 | 0.81% | 4.49% | Y |
| TIE | 1097 | 792.83 | 0.00% | 0.01% | 3 | 0.00% | 0.00% | 0 | 1.15% | 4.68% | Y |
| TIE | 1100 | 3,886.43 | 0.00% | 0.02% | 1 | 0.00% | 0.01% | 1 | 1.51% | 4.29% | Y |

Tie Meter Stats for 2004 November 9, 2005

| Type | Mask ID | Total Annual Flow (GWhr) | Avg Change 4M T/U (%) | Max Change 4M T/U (%) | # 4M Changes | Avg Change 12M T/U (%) | Max Change 12M T/U (%) | # 12M Changes | Avg PTS Error (%) | Max PTS Error (%) | Meets RMRM |
|-------------|----------------|---------------------------------|------------------------------|------------------------------|---------------------|-------------------------------|-------------------------------|----------------------|--------------------------|--------------------------|-------------------|
| TIE | 1103 | 13.50 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 1.20% | 3.95% | N |
| TIE | 1105 | 232.72 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.30% | 0.70% | Y |
| TIE | 1112 | 1,251.54 | 0.01% | 0.09% | 3 | 0.00% | 0.00% | 0 | 0.22% | 0.80% | N |
| TIE | 1120 | 354.54 | 0.01% | 0.06% | 1 | 0.00% | 0.00% | 0 | 5.23% | 21.36% | N |
| TIE | 1126 | 48.86 | 100.00% | 100.01% | 12 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | N |
| TIE | 1129 | 356.11 | 0.00% | 0.01% | 1 | 0.00% | 0.00% | 0 | 0.31% | 0.41% | Y |
| TIE | 1131 | 605.26 | 0.11% | 1.33% | 1 | 0.34% | 2.73% | 2 | 3.16% | 11.17% | Y |
| TIE | 1137 | 745.64 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | . | . | N |
| TIE | 1143 | 14.56 | 9.75% | 58.19% | 7 | 0.29% | 2.06% | 2 | 22.48% | 137.96% | N |
| TIE | 1145 | 0.00 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | N |
| TIE | 1151 | 69.73 | 0.35% | 4.17% | 1 | 0.78% | 7.02% | 1 | 5.71% | 17.38% | N |
| TIE | 1153 | 111.32 | 0.01% | 0.03% | 3 | 0.00% | 0.00% | 0 | 0.78% | 4.39% | Y |
| TIE | 1160 | 4,984.61 | 0.00% | 0.03% | 1 | 0.00% | 0.00% | 3 | 0.02% | 0.14% | N |
| TIE | 1162 | 1.13 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1164 | 89.19 | 0.06% | 0.30% | 4 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1167 | 3,819.83 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 1 | 0.52% | 0.64% | Y |
| TIE | 1171 | 126.94 | 0.02% | 0.16% | 4 | 0.00% | 0.00% | 0 | 3.19% | 10.32% | N |
| TIE | 1172 | 539.27 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.05% | 0.32% | N |
| TIE | 1173 | 0.30 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1175 | 4.95 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1176 | 1,327.85 | 0.06% | 0.46% | 2 | 0.03% | 0.20% | 2 | 0.49% | 1.50% | Y |
| TIE | 1183 | 194.82 | 0.05% | 0.15% | 4 | 0.00% | 0.00% | 0 | 4.63% | 12.81% | N |
| TIE | 1190 | 515.78 | 0.00% | 0.00% | 1 | 0.00% | 0.00% | 0 | 0.33% | 0.44% | Y |
| TIE | 1195 | 212.44 | 0.01% | 0.15% | 1 | 0.00% | 0.00% | 0 | 0.59% | 1.18% | N |
| TIE | 1199 | 905.74 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.90% | 5.47% | Y |
| TIE | 1202 | 365.80 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.44% | 1.89% | Y |
| TIE | 1210 | 27.27 | 2.33% | 21.80% | 8 | 0.91% | 4.33% | 2 | . | . | N |

Tie Meter Stats for 2004 November 9, 2005

| Type | Mask ID | Total Annual Flow (GWhr) | Avg Change 4M T/U (%) | Max Change 4M T/U (%) | # 4M Changes | Avg Change 12M T/U (%) | Max Change 12M T/U (%) | # 12M Changes | Avg PTS Error (%) | Max PTS Error (%) | Meets RMRM |
|------|---------|--------------------------|-----------------------|-----------------------|--------------|------------------------|------------------------|---------------|-------------------|-------------------|------------|
| TIE | 1212 | 26.45 | 0.02% | 0.14% | 2 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1216 | 405.44 | 0.00% | 0.04% | 1 | 0.00% | 0.00% | 0 | 1.06% | 2.45% | N |
| TIE | 1222 | 280.41 | 0.01% | 0.08% | 2 | 0.00% | 0.00% | 0 | 6.58% | 14.45% | N |
| TIE | 1230 | 637.67 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.02% | 0.04% | N |
| TIE | 1231 | 232.97 | 0.01% | 0.14% | 1 | 0.00% | 0.00% | 0 | 16.30% | 132.12% | Y |
| TIE | 1233 | 749.82 | 0.01% | 0.07% | 1 | 0.00% | 0.00% | 0 | 1.05% | 1.11% | Y |
| TIE | 1239 | 478.73 | 0.00% | 0.03% | 1 | 0.00% | 0.00% | 0 | 0.54% | 1.03% | Y |
| TIE | 1243 | 201.89 | 0.01% | 0.09% | 3 | 0.00% | 0.00% | 0 | 2.96% | 12.05% | Y |
| TIE | 1245 | 610.03 | 0.00% | 0.01% | 5 | 0.00% | 0.00% | 2 | 0.51% | 4.01% | N |
| TIE | 1254 | 0.00 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | N |
| TIE | 1256 | 5,103.18 | 0.00% | 0.02% | 1 | 0.20% | 0.40% | 6 | 0.01% | 0.04% | N |
| TIE | 1258 | 5,185.52 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 2.39% | 2.73% | Y |
| TIE | 1259 | 4,388.15 | 0.00% | 0.00% | 3 | 0.00% | 0.00% | 0 | 0.37% | 0.98% | Y |
| TIE | 1261 | 88.66 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 32.49% | 70.62% | N |
| TIE | 1263 | 94.80 | 0.00% | 0.01% | 1 | 0.00% | 0.00% | 0 | 0.21% | 0.43% | Y |
| TIE | 1269 | 3,643.25 | 0.00% | 0.01% | 3 | 0.00% | 0.00% | 1 | 0.02% | 0.06% | N |
| TIE | 1273 | 411.23 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 6.55% | 16.55% | Y |
| TIE | 1278 | 5,141.79 | 0.00% | 0.01% | 2 | 0.00% | 0.00% | 1 | 1.42% | 2.12% | N |
| TIE | 1281 | 14.24 | 0.30% | 3.60% | 1 | 0.00% | 0.00% | 0 | . | . | N |
| TIE | 1284 | 77.58 | 0.01% | 0.13% | 1 | 0.00% | 0.00% | 0 | 1.73% | 2.19% | Y |
| TIE | 1297 | 123.34 | 0.02% | 0.12% | 4 | 0.00% | 0.00% | 0 | 1.13% | 4.10% | Y |
| TIE | 1298 | 567.67 | 0.00% | 0.05% | 1 | 0.00% | 0.00% | 0 | 0.77% | 0.88% | Y |
| TIE | 1299 | 323.61 | 0.01% | 0.09% | 2 | 0.00% | 0.00% | 0 | 0.48% | 0.91% | Y |
| TIE | 1300 | 2,539.75 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.74% | 1.68% | Y |
| TIE | 1302 | 66.04 | 0.04% | 0.17% | 3 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1304 | 1,226.31 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.83% | 1.18% | Y |
| TIE | 1313 | 14.41 | 1.09% | 6.57% | 3 | 0.00% | 0.00% | 0 | . | . | Y |

Tie Meter Stats for 2004 November 9, 2005

| Type | Mask ID | Total Annual Flow (GWhr) | Avg Change 4M T/U (%) | Max Change 4M T/U (%) | # 4M Changes | Avg Change 12M T/U (%) | Max Change 12M T/U (%) | # 12M Changes | Avg PTS Error (%) | Max PTS Error (%) | Meets RMRM |
|-------------|----------------|---------------------------------|------------------------------|------------------------------|---------------------|-------------------------------|-------------------------------|----------------------|--------------------------|--------------------------|-------------------|
| TIE | 1315 | 373.13 | 0.00% | 0.01% | 1 | 0.00% | 0.00% | 0 | 0.27% | 0.41% | Y |
| TIE | 1317 | 0.00 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | N |
| TIE | 1323 | 6,372.55 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.61% | 1.49% | Y |
| TIE | 1327 | 567.58 | 0.00% | 0.02% | 1 | 0.00% | 0.00% | 0 | 0.95% | 2.97% | Y |
| TIE | 1334 | 6.99 | 43.07% | 100.00% | 9 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | N |
| TIE | 1335 | 0.02 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1342 | 79.05 | 0.02% | 0.18% | 3 | 0.00% | 0.00% | 0 | 18.34% | 88.04% | Y |
| TIE | 1344 | 2,656.23 | 0.00% | 0.04% | 2 | 0.00% | 0.00% | 0 | 0.07% | 0.09% | Y |
| TIE | 1346 | 305.62 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.17% | 0.49% | N |
| TIE | 1351 | 4,946.59 | 0.00% | 0.00% | 0 | 0.00% | 0.02% | 1 | 0.01% | 0.04% | N |
| TIE | 1356 | 5,083.71 | 0.00% | 0.03% | 1 | 0.00% | 0.01% | 3 | 0.01% | 0.08% | N |
| TIE | 1362 | 63.09 | 0.04% | 0.33% | 4 | 0.00% | 0.00% | 0 | 22.14% | 96.59% | Y |
| TIE | 1366 | 246.50 | 0.00% | 0.00% | 1 | 0.00% | 0.00% | 0 | 1.54% | 6.97% | Y |
| TIE | 1367 | 3,494.12 | 0.00% | 0.01% | 1 | 0.00% | 0.00% | 0 | 0.71% | 3.11% | N |
| TIE | 1370 | 55.97 | 0.15% | 0.49% | 8 | 0.00% | 0.00% | 0 | . | . | N |
| TIE | 1379 | 507.28 | 0.02% | 0.17% | 2 | 0.00% | 0.00% | 0 | 0.13% | 0.66% | N |
| TIE | 1380 | 486.72 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.65% | 1.07% | Y |
| TIE | 1385 | 585.89 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.60% | 3.38% | Y |
| TIE | 1388 | 557.61 | 0.00% | 0.03% | 1 | 0.00% | 0.00% | 0 | 1.18% | 10.69% | Y |
| TIE | 1389 | 244.60 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.15% | 0.23% | Y |
| TIE | 1396 | 598.65 | 0.01% | 0.08% | 1 | 0.00% | 0.00% | 0 | 0.22% | 0.31% | N |
| TIE | 1397 | 1,133.99 | 0.14% | 1.64% | 1 | 0.00% | 0.00% | 0 | 49.96% | 63.20% | Y |
| TIE | 1398 | 1.82 | 193.18% | 2255.56% | 5 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1401 | 120.68 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.55% | 2.51% | N |
| TIE | 1403 | 134.60 | 0.02% | 0.21% | 1 | 0.00% | 0.00% | 0 | 0.80% | 2.03% | Y |
| TIE | 1405 | 403.66 | 0.01% | 0.13% | 1 | 0.00% | 0.03% | 2 | 0.15% | 0.73% | N |
| TIE | 1410 | 145.63 | 0.04% | 0.16% | 4 | 0.00% | 0.00% | 0 | . | . | Y |

Tie Meter Stats for 2004 November 9, 2005

| Type | Mask ID | Total Annual Flow (GWhr) | Avg Change 4M T/U (%) | Max Change 4M T/U (%) | # 4M Changes | Avg Change 12M T/U (%) | Max Change 12M T/U (%) | # 12M Changes | Avg PTS Error (%) | Max PTS Error (%) | Meets RMRM |
|-------------|----------------|---------------------------------|------------------------------|------------------------------|---------------------|-------------------------------|-------------------------------|----------------------|--------------------------|--------------------------|-------------------|
| TIE | 1416 | 0.00 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1424 | 244.27 | 0.00% | 0.02% | 2 | 0.00% | 0.00% | 0 | 1.35% | 4.02% | Y |
| TIE | 1427 | 60.76 | 0.42% | 2.83% | 8 | 0.00% | 0.00% | 0 | 6.98% | 43.95% | N |
| TIE | 1428 | 71.16 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 3.84% | 14.21% | Y |
| TIE | 1430 | 135.28 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.25% | 1.08% | Y |
| TIE | 1442 | 481.42 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 73.36% | 79.08% | N |
| TIE | 1447 | 518.47 | 0.00% | 0.02% | 2 | 0.00% | 0.01% | 2 | 5.52% | 49.62% | N |
| TIE | 1450 | 171.52 | 0.34% | 3.22% | 8 | 0.00% | 0.00% | 0 | 6.05% | 51.88% | N |
| TIE | 1455 | 98.34 | 0.09% | 1.08% | 1 | 0.03% | 0.25% | 1 | 0.36% | 2.55% | N |
| TIE | 1457 | 2.87 | 42.42% | 100.04% | 9 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | N |
| TIE | 1459 | 1,095.80 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 4.46% | 15.72% | Y |
| TIE | 1461 | 5,525.26 | 0.76% | 9.06% | 2 | 0.00% | 0.01% | 2 | 0.02% | 0.08% | N |
| TIE | 1463 | 0.00 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1465 | 182.18 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 1.05% | 5.10% | N |
| TIE | 1471 | 1,199.45 | 0.01% | 0.05% | 4 | 0.00% | 0.00% | 0 | 1.22% | 3.13% | Y |
| TIE | 1484 | 2.85 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1487 | 266.40 | 0.01% | 0.07% | 4 | 0.00% | 0.00% | 0 | 1.38% | 8.80% | Y |
| TIE | 1489 | 1,659.65 | 0.00% | 0.00% | 1 | 0.00% | 0.00% | 1 | 0.02% | 0.15% | N |
| TIE | 1491 | 23.69 | 0.02% | 0.20% | 1 | 0.00% | 0.00% | 0 | 8.92% | 15.69% | N |
| TIE | 1495 | 5,152.03 | 0.01% | 0.03% | 10 | 0.00% | 0.00% | 0 | 3.48% | 3.82% | N |
| TIE | 1497 | 121.57 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 17.75% | 82.39% | N |
| TIE | 1500 | 827.12 | 0.00% | 0.00% | 1 | 0.00% | 0.00% | 0 | 15.06% | 81.60% | Y |
| TIE | 1502 | 448.23 | 0.00% | 0.04% | 3 | 0.03% | 0.24% | 1 | 1.70% | 4.05% | Y |
| TIE | 1503 | 346.99 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.47% | 1.41% | Y |
| TIE | 1507 | 279.91 | 0.03% | 0.20% | 7 | 0.00% | 0.00% | 0 | 2.95% | 11.55% | N |
| TIE | 1509 | 3,450.55 | 1.03% | 7.31% | 5 | 0.00% | 0.01% | 2 | 2.08% | 12.21% | Y |
| TIE | 1513 | 38.54 | 0.09% | 0.39% | 5 | 0.00% | 0.00% | 0 | . | . | Y |

Tie Meter Stats for 2004 November 9, 2005

| Type | Mask ID | Total Annual Flow (GWhr) | Avg Change 4M T/U (%) | Max Change 4M T/U (%) | # 4M Changes | Avg Change 12M T/U (%) | Max Change 12M T/U (%) | # 12M Changes | Avg PTS Error (%) | Max PTS Error (%) | Meets RMRM |
|-------------|----------------|---------------------------------|------------------------------|------------------------------|---------------------|-------------------------------|-------------------------------|----------------------|--------------------------|--------------------------|-------------------|
| TIE | 1518 | 547.42 | 0.00% | 0.01% | 2 | 0.01% | 0.06% | 2 | 1.90% | 22.61% | N |
| TIE | 1521 | 0.06 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1536 | 482.98 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 5.02% | 27.42% | N |
| TIE | 1552 | 0.36 | 91.60% | 100.67% | 11 | 11.22% | 101.01% | 1 | 0.00% | 0.00% | N |
| TIE | 1556 | 7,366.01 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.29% | 1.81% | Y |
| TIE | 1560 | 5,760.91 | 0.00% | 0.03% | 2 | 0.00% | 0.02% | 1 | 0.50% | 0.91% | Y |
| TIE | 1565 | 0.00 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | N |
| TIE | 1569 | 5,749.13 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 43.91% | 48.03% | Y |
| TIE | 1570 | 92.85 | 0.04% | 0.16% | 3 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1585 | 1,488.83 | 0.00% | 0.00% | 1 | 0.00% | 0.00% | 0 | 0.50% | 5.81% | N |
| TIE | 1591 | 44.30 | 100.00% | 100.01% | 12 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | N |
| TIE | 1595 | 201.71 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.56% | 3.21% | N |
| TIE | 1597 | 61.73 | 0.00% | 0.04% | 1 | 0.00% | 0.00% | 0 | 1.21% | 5.53% | N |
| TIE | 1599 | 20.64 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | . | . | N |
| TIE | 1600 | 501.91 | 0.01% | 0.07% | 1 | 0.00% | 0.00% | 0 | 1.42% | 1.60% | Y |
| TIE | 1603 | 131.82 | 0.28% | 3.36% | 1 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1607 | 4,076.68 | 0.08% | 0.54% | 3 | 0.10% | 0.33% | 4 | 0.39% | 0.83% | Y |
| TIE | 1613 | 2,419.22 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 3.71% | 21.14% | Y |
| TIE | 1618 | 230.96 | 0.18% | 2.14% | 1 | 0.00% | 0.00% | 0 | 5.30% | 17.94% | Y |
| TIE | 1625 | 99.67 | 0.00% | 0.02% | 1 | 0.00% | 0.00% | 0 | 125.94% | 1207.23% | Y |
| TIE | 1626 | 152.18 | 1.16% | 3.93% | 5 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1627 | 48.82 | 0.02% | 0.24% | 1 | 0.00% | 0.00% | 0 | 2.21% | 15.33% | N |
| TIE | 1630 | 0.77 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | N |
| TIE | 1644 | 1.91 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1645 | 2.63 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1649 | 150.08 | 0.05% | 0.17% | 4 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1650 | 779.52 | 0.00% | 0.05% | 1 | 0.00% | 0.00% | 0 | 0.81% | 0.99% | Y |

Tie Meter Stats for 2004 November 9, 2005

| Type | Mask ID | Total Annual Flow (GWhr) | Avg Change 4M T/U (%) | Max Change 4M T/U (%) | # 4M Changes | Avg Change 12M T/U (%) | Max Change 12M T/U (%) | # 12M Changes | Avg PTS Error (%) | Max PTS Error (%) | Meets RMRM |
|------|---------|--------------------------|-----------------------|-----------------------|--------------|------------------------|------------------------|---------------|-------------------|-------------------|------------|
| TIE | 1651 | 4,499.66 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.35% | 0.65% | Y |
| TIE | 1654 | 2,981.90 | 0.00% | 0.01% | 2 | 0.00% | 0.00% | 0 | 0.08% | 0.22% | Y |
| TIE | 1655 | 634.65 | 0.00% | 0.00% | 5 | 0.00% | 0.00% | 2 | 0.06% | 0.09% | N |
| TIE | 1660 | 376.12 | 0.00% | 0.01% | 1 | 0.00% | 0.00% | 0 | 1.34% | 5.33% | N |
| TIE | 1661 | 604.88 | 0.00% | 0.05% | 1 | 0.03% | 0.23% | 3 | 3.55% | 42.43% | N |
| TIE | 1662 | 1,037.77 | 0.00% | 0.02% | 1 | 0.00% | 0.00% | 0 | 0.37% | 0.56% | Y |
| TIE | 1663 | 108.20 | 0.18% | 1.01% | 3 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1671 | 61.87 | 0.00% | 0.03% | 1 | 0.00% | 0.00% | 0 | 0.34% | 0.65% | Y |
| TIE | 1677 | 3.50 | 59.37% | 199.69% | 6 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | N |
| TIE | 1684 | 403.54 | 1.12% | 4.27% | 4 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1686 | 41.39 | 1.13% | 6.51% | 4 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1695 | 366.39 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.07% | 0.43% | N |
| TIE | 1702 | 4,798.65 | 0.00% | 0.01% | 4 | 0.00% | 0.00% | 0 | 0.15% | 0.39% | Y |
| TIE | 1705 | 1.40 | 8.33% | 100.00% | 1 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1706 | 1.32 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | Y |
| TIE | 1711 | 2,706.00 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.83% | 1.00% | Y |
| TIE | 1712 | 54.77 | 0.17% | 1.15% | 4 | 0.00% | 0.00% | 0 | 10.22% | 24.07% | N |
| TIE | 1714 | 397.50 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.54% | 0.85% | N |
| TIE | 1718 | 1,625.07 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 0.09% | 0.18% | Y |
| TIE | 1719 | 4.73 | 0.33% | 3.82% | 2 | 0.00% | 0.00% | 0 | 1.53% | 9.52% | N |
| TIE | 1721 | 476.44 | 0.00% | 0.03% | 1 | 0.00% | 0.00% | 0 | 0.55% | 0.81% | Y |
| TIE | 1723 | 3,610.84 | 0.00% | 0.01% | 2 | 0.00% | 0.00% | 2 | 0.02% | 0.10% | N |
| TIE | 1725 | 505.72 | 0.00% | 0.01% | 1 | 0.00% | 0.00% | 0 | 11.58% | 22.37% | N |
| TIE | 1728 | 1.52 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 41.60% | 100.00% | N |
| TIE | 1729 | 5,187.84 | 0.00% | 0.01% | 1 | 0.00% | 0.00% | 0 | 0.60% | 4.18% | N |
| TIE | 1730 | 41.19 | 0.04% | 0.17% | 3 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1732 | 1,688.10 | 0.00% | 0.00% | 3 | 0.00% | 0.00% | 0 | 2.25% | 9.32% | Y |

Tie Meter Stats for 2004 November 9, 2005

| Type | Mask ID | Total Annual Flow (GWhr) | Avg Change 4M T/U (%) | Max Change 4M T/U (%) | # 4M Changes | Avg Change 12M T/U (%) | Max Change 12M T/U (%) | # 12M Changes | Avg PTS Error (%) | Max PTS Error (%) | Meets RMRM |
|-------------|----------------|---------------------------------|------------------------------|------------------------------|---------------------|-------------------------------|-------------------------------|----------------------|--------------------------|--------------------------|-------------------|
| TIE | 1736 | 344.53 | 0.00% | 0.02% | 1 | 0.00% | 0.00% | 0 | 1.33% | 4.70% | Y |
| TIE | 1738 | 128.36 | 0.19% | 1.88% | 2 | 0.01% | 0.05% | 1 | 0.29% | 1.84% | N |
| TIE | 1741 | 781.58 | 0.00% | 0.03% | 4 | 0.00% | 0.00% | 0 | 1.36% | 4.46% | Y |
| TIE | 1743 | 144.12 | 8.35% | 100.00% | 5 | 44.87% | 100.00% | 5 | 46.63% | 88.07% | Y |
| TIE | 1746 | 6.18 | 50.00% | 100.00% | 6 | 55.56% | 100.05% | 5 | 0.00% | 0.00% | Y |
| TIE | 1753 | 0.85 | 2.18% | 26.19% | 1 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | N |
| TIE | 1755 | 265.50 | 0.01% | 0.07% | 4 | 0.00% | 0.00% | 0 | 1.33% | 9.14% | Y |
| TIE | 1756 | 0.31 | 33.40% | 200.09% | 3 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | N |
| TIE | 1764 | 1,375.45 | 0.01% | 0.10% | 2 | 0.00% | 0.00% | 0 | 1.35% | 5.10% | N |
| TIE | 1766 | 363.17 | 0.02% | 0.20% | 4 | 0.00% | 0.00% | 0 | 2.43% | 13.02% | N |
| TIE | 1775 | 100.37 | 0.04% | 0.41% | 4 | 0.00% | 0.00% | 0 | 13.23% | 120.21% | N |
| TIE | 1776 | 628.38 | 1.11% | 13.36% | 1 | 0.00% | 0.00% | 0 | 7.20% | 24.65% | Y |
| TIE | 1779 | 134.60 | 0.07% | 0.30% | 4 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1783 | 879.20 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 1.02% | 2.37% | Y |
| TIE | 1784 | 3.62 | 1.38% | 6.58% | 3 | 0.00% | 0.00% | 0 | . | . | Y |
| TIE | 1809 | 228.15 | 0.00% | 0.00% | 0 | 0.00% | 0.00% | 0 | 1.78% | 2.63% | Y |