



Heat Wave Operations June 20-22, 2012

Management Committee Meeting July 25, 2012










^{*}Demand response reflects backcasting methodology





Wednesday - June 20, 2012

✓ Statewide System Demand:

- Actual peak NYCA system load was 31,296 MW
- EDRP/SCR estimated value as provided by RIPs was 616 MW
- ISO Day-Ahead load forecast was 31,700 MW

✓ Transmission Operations:

- HQ Chateauguay Massena 765kV Interconnection forced out from 6/19 HB17 through 6/20 HB13
- PJM Neptune HVdc Interconnection forced out


✓ Generation Operations:

- Over 1,100 MW of Southeast NY (SENY) capacity was unavailable for operation resulting in the need for SENY Demand Response at lower statewide demand levels than prior years
- ISO SRE of Danskammer 1&2 for SENY transmission security
- ISO SRE of Oswego 6 for statewide capacity needs following forced outage of HQ Chateauguay-Massena 765kV Interconnection

Demand Response Operations:

- EDRP and SCR resources were activated in Zones G-J from HB14 through HB17
 - Activated for SENY transmission security (requirement to restore system power flows to within normal operating limits within 30 minutes)
- EDRP and SCR resources were activated in Zone C from HB14 through HB17







Thursday - June 21, 2012

✓ Statewide System Demand:

- Actual peak NYCA system load was 32,127 MW
- EDRP/SCR estimated value as provided by RIPs was 1,703 MW
- ISO Day-Ahead load forecast was 33,700 MW

✓ Transmission Operations:

- HQ Chateauguay Massena 765kV Interconnection forced out from 6/21 HB10 through 6/21 HB14
- PJM Neptune HVdc Interconnection forced out

✓ Generation Operations:

- Over 1,100 MW of Southeast NY capacity was unavailable for operation at peak
- ISO SRE of Oswego 6 and Kintigh for statewide capacity needs
 - Day-Ahead SREs in response to unknown return of HQ 765kV interconnection on 6/20 and start-up notification requirement


✓ <u>Demand Response Operations:</u>

- EDRP and SCR resources were activated in Zones G–K from HB13 through HB17

 - ∑one J activated beginning at HB12 at Con Edison's request
- EDRP/SCR resources were activated for Zones A-F from HB13 through HB17

 - Activated Zone A, D, E, F for statewide capacity requirements in response to the loss of over 800 MW of upstate generating capacity







Friday - June 22, 2012

Statewide System Demand:

- Actual peak NYCA system load was 29,932 MW
- EDRP/SCR estimated value as provided by RIPs was 656 MW
- ISO Day-Ahead load forecast was 30,500 MW
- Thunderstorms developed earlier than forecasted and reduced SENY load

✓ Transmission Operations:

PJM Neptune HVdc Interconnection forced out

✓ Generation Operations:

- Over 1,500 MW of Southeast NY capacity was unavailable for operation at peak
- ISO SRE of Roseton 1 for SENY transmission security

Demand Response Operations:

- EDRP and SCR resources were activated in Zones G–K from HB13 through HB17
 - △ Activated for Zones G-K for forecasted reserve shortages needed to maintain transmission security operations

