

Interface Name	PTID	Limit Change Flag	Summer FWD Limit	Summer RVR Limit	Winter FWD Limit	Winter RVR Limit	Outage PTID1	Outage Name	Outage PTID2	Outage Name	Outage PTID3	Outage Name	Outage PTID4	Outage Name
Cent-East_4-46_O/S [3621]	23313	B	2850	-9999	2850	-9999	25049	LAFAYTTE-CLRKSCRN_345_4-46	0		0		0	
Cent-East_14_O/S [3621]	23313	B	2050	-9999	2050	-9999	25170	EDIC____-N.SCTLND_345_14-EN	0		0		0	
Cent-East_18_O/S [3621]	23313	B	2050	-9999	2050	-9999	25276	MARCY____-N.SCTLND_345_18	0		0		0	
Cent-East_32_O/S [3621]	23313	B	3000	-9999	3000	-9999	25235	OAKDALE_-FRASER____345_32	0		0		0	
Cent-East_36_O/S [3621]	23313	B	2850	-9999	2850	-9999	325726	CLRKSCRN-OAKDALE____345_36	0		0		0	
Cent-East_ALI [3621]	23313	B	3050	-9999	3050	-9999	0		0		0		0	
Cent-East_MSU-1_O/S [3621]	23313	B	2650	-9999	2650	-9999	25224	MASSENA_-MARCY____765_MSU1	0		0		0	
Cent-East_VC_14_O/S [3_Osw]	23330	B	2240	-9999	2240	-9999	25170	EDIC____-N.SCTLND_345_14-EN	0		0		0	
Cent-East_VC_18_O/S [3_Osw]	23330	B	2090	-9999	2090	-9999	25276	MARCY____-N.SCTLND_345_18	0		0		0	
Cent-East_VC_30_O/S [3_Osw]	23330	B	2805	-9999	2805	-9999	25173	PORTER_-ROTTRDAM_230_30-PR	0		0		0	
Cent-East_VC_31_O/S [3_Osw]	23330	B	2805	-9999	2805	-9999	25194	PORTER_-ROTTRDAM_230_31-PR	0		0		0	
Cent-East_VC_ALI [3_Osw]	23330	B	2975	-9999	2975	-9999	0		0		0		0	
Cent-East_VC_FE-1_O/S [3_Osw]	23330	B	2825	-9999	2825	-9999	25077	FITZPTRK-EDIC____345_FE1	0		0		0	
Cent-East_VC_Inghams_PAR_O/S	23330	I	75	0	75	0	25242	INGHAM_C_115_115_PAR 2	0		0		0	
Cent-East_VC_MSU-1_O/S [3_Osw]	23330	B	2315	-9999	2315	-9999	25224	MASSENA_-MARCY____765_MSU1	0		0		0	
Cent-East_VC_PV20_O/S	23330	I	75	0	75	0	25027	S HERO_-PLATSBRG_115_PV20	0		0		0	
Cent-East_VC_VU-19_O/S [3_Osw]	23330	B	2825	-9999	2825	-9999	25345	VOLNEY_-MARCY____345_19	0		0		0	
Dysinger-East_60_O/S	23326	B	2650	-9999	2650	-9999	325604	MEYER____-CANANDGA_230_60	0		0		0	
Dysinger-East_67_O/S	23326	B	2650	-9999	2650	-9999	25064	STOLLERD-HISHELDN_230_67	0		0		0	
Dysinger-East_68_O/S	23326	B	2650	-9999	2650	-9999	25176	CANANDGA-STONYRDG_230_68	0		0		0	
Dysinger-East_72_O/S	23326	B	2650	-9999	2650	-9999	325810	STONYRDG-HILLSIDE_230_72	0		0		0	
Dysinger-East_81_O/S	23326	B	2650	-9999	2650	-9999	325622	HISHELDN-STONCREK_230_81	0		0		0	
Dysinger-East_83_O/S	23326	B	2650	-9999	2650	-9999	325973	STONCREK-WETHSRFD_230_83	0		0		0	
Dysinger-East_85_O/S	23326	B	2650	-9999	2650	-9999	325623	WETHSRFD-MEYER____230_85/87	0		0		0	
Dysinger-East_ALI	23326	B	2850	-9999	2850	-9999	0		0		0		0	
Dysinger-East_NR-2_O/S	23326	B	2350	-9999	2350	-9999	25084	NIAGARA_-ROCHESTR_345_NR2	0		0		0	
Dysinger-East_RP-1_O/S	23326	B	2300	-9999	2300	-9999	25192	ROCHESTR-PANNELL____345_RP1	0		0		0	
Dysinger-East_RP-2_O/S	23326	B	2300	-9999	2300	-9999	25172	ROCHESTR-PANNELL____345_RP2	0		0		0	
Dysinger-East_SR1-39_O/S	23326	B	2350	-9999	2350	-9999	25073	KINTIGH_-ROCHESTR_345_SR1-39	0		0		0	
HQ-NY_7040_O/S	325053	B	0	0	0	0	25301	CHATGUAY-MASSENA_765_7040	0		0		0	
HQ-NY_ALI	325053	B	1800	-1000	1800	-1000	0		0		0		0	
HQ-NY_MSU_TRANSFER_TRIP_O/S	325053	B	650	-1000	650	-1000	325581	MSU_TRANSFER_TRIP	0		0		0	
HQ-NY_MSU-1_O/S	325053	B	475	-1000	475	-1000	25224	MASSENA_-MARCY____765_MSU1	0		0		0	
HQ-NY_Pole1_O/S	325053	B	1650	-500	1650	-500	23748	CHAT_DC_GC1	0		0		0	
HQ-NY_Pole1+Pole2_O/S	325053	B	1370	0	1370	0	23748	CHAT_DC_GC1	23749	CHAT_DC_GC2	0		0	
HQ-NY_Pole2_O/S	325053	B	1650	-500	1650	-500	23749	CHAT_DC_GC2	0		0		0	
IMO-NY_ALI	325055	B	2500	-2500	2500	-2500	0		0		0		0	
IMO-NY_BP76_O/S	325055	B	2300	-2300	2300	-2300	25024	BECK____-PACKARD_230_BP76	0		0		0	
IMO-NY_BP76+PA27_O/S	325055	B	1900	-2300	1900	-2300	25024	BECK____-PACKARD_230_BP76	25025	BECK____-NIAGARA_230_PA27	0		0	
IMO-NY_L33P_O/S	325055	B	2300	-2300	2300	-2300	25026	STLAWRNC-MOSES____230_L33P	0		0		0	
IMO-NY_L34P_O/S	325055	B	2300	-2300	2300	-2300	25037	STLAWRNC-MOSES____230_L34P	0		0		0	
IMO-NY_PA27_O/S	325055	B	2300	-2300	2300	-2300	25025	BECK____-NIAGARA_230_PA27	0		0		0	
IMO-NY_PA301_O/S	325055	B	2300	-2300	2300	-2300	25040	BECK____-NIAGARA_345_PA301	0		0		0	
IMO-NY_PA301+PA302_O/S	325055	B	800	-500	800	-500	25040	BECK____-NIAGARA_345_PA301	25041	BECK____-NIAGARA_345_PA302	0		0	
IMO-NY_PA302_O/S	325055	B	2300	-2300	2300	-2300	25041	BECK____-NIAGARA_345_PA302	0		0		0	
Mos-Sou_AC-13_O/S	23319	B	2450	-1600	2450	-1600	325233	ADIRNDCK-CHASLAKE_230_13	0		0		0	
Mos-Sou_Alcoa_R8105_O/S	23319	B	2600	-1600	2600	-1600	325291	ILCTLMT_115KV_ALCOA_R8105_TIE_B	0		0		0	
Mos-Sou_ALI	23319	B	2900	-1600	2900	-1600	0		0		0		0	
Mos-Sou_AP-12_O/S	23319	B	2450	-1600	2450	-1600	25082	ADIRNDCK-PORTER____230_12-AP	0		0		0	
Mos-Sou_CP-11_O/S	23319	B	2450	-1600	2450	-1600	25051	CHASLAKE-PORTER____230_11	0		0		0	
Mos-Sou_MA-1_O/S	23319	B	2450	-1600	2450	-1600	25269	MOSES____-ADIRNDCK_230_MA1	0		0		0	
Mos-Sou_MA-2_O/S	23319	B	2450	-1600	2450	-1600	25270	MOSES____-ADIRNDCK_230_MA2	0		0		0	
Mos-Sou_MSU_TRANSFER_TRIP_O/S	23319	B	1100	-1100	1100	-1100	325581	MSU_TRANSFER_TRIP	0		0		0	
Mos-Sou_MSU-1_O/S	23319	B	675	-1100	675	-1100	25224	MASSENA_-MARCY____765_MSU1	0		0		0	
Mos-Sou_MSU-1+AC-13_O/S	23319	B	500	-9999	500	-9999	25224	MASSENA_-MARCY____765_MSU1	325233	ADIRNDCK-CHASLAKE_230_13	0		0	
Mos-Sou_MSU-1+AP-12_O/S	23319	B	500	-9999	500	-9999	25082	ADIRNDCK-PORTER____230_12-AP	25224	MASSENA_-MARCY____765_MSU1	0		0	
Mos-Sou_MSU-1+CP-11_O/S	23319	B	500	-9999	500	-9999	25051	CHASLAKE-PORTER____230_11	25224	MASSENA_-MARCY____765_MSU1	0		0	
Mos-Sou_MSU-1+MA-1_O/S	23319	B	500	-9999	500	-9999	25224	MASSENA_-MARCY____765_MSU1	25269	MOSES____-ADIRNDCK_230_MA1	0		0	
Mos-Sou_MSU-1+MA-2_O/S	23319	B	500	-9999	500	-9999	25224	MASSENA_-MARCY____765_MSU1	25270	MOSES____-ADIRNDCK_230_MA2	0		0	
Mos-Sou_Pole1_O/S	23319	B	2150	-9999	2150	-9999	23748	CHAT_DC_GC1	0		0		0	
Mos-Sou_Pole1+Pole2_O/S	23319	B	2000	-9999	2000	-9999	23748	CHAT_DC_GC1	23749	CHAT_DC_GC2	0		0	
Mos-Sou_Pole2_O/S	23319	B	2150	-9999	2150	-9999	23749	CHAT_DC_GC2	0		0		0	

Interface Name	PTID	Limit Change Flag	Summer FWD Limit	Summer RVR Limit	Winter FWD Limit	Winter RVR Limit	Outage PTID1	Outage Name	Outage PTID2	Outage Name	Outage PTID3	Outage Name	Outage PTID4	Outage Name
NE-NY_2_O/S	325054	B	2150	-2150	2150	-2150	25217	N.SCTLND-ALPS_345_2-AN	0		0		0	
NE-NY_312_O/S	325054	B	1950	-1950	1950	-1950	25366	BERKSHIR-NORTHFLD_345_312	0		0		0	
NE-NY_329_O/S	325054	B	2100	-2100	2100	-2100	25364	FROST_BR-SOUTHNGT_345_329	0		0		0	
NE-NY_352_O/S	325054	B	1850	-1850	1850	-1850	25363	FROST_BR-LONG_MTN_345_352	0		0		0	
NE-NY_393_O/S	325054	B	1600	-1600	1600	-1600	25034	BERKSHIR-ALPS_345_393	0		0		0	
NE-NY_393+312_O/S	325054	B	1500	-1500	1500	-1500	25034	BERKSHIR-ALPS_345_393	25366	BERKSHIR-NORTHFLD_345_312	0		0	
NE-NY_398_O/S	325054	B	1150	-1150	1150	-1150	25033	LONG_MTN-PLSNTVLY_345_398	0		0		0	
NE-NY_ALI	325054	B	2200	-2200	2200	-2200	0		0		0		0	
OSWEGO EXPORT_1-16_O/S	325596	B	4850	-9999	4850	-9999	25200	CLAY_-EDIC_345_1-16	0		0		0	
OSWEGO EXPORT_11-OV_O/S	325596	B	5250	-9999	5250	-9999	25199	OSWEGO_-VOLNEY_345_11-OV	0		0		0	
OSWEGO EXPORT_12-OV_O/S	325596	B	5250	-9999	5250	-9999	25201	OSWEGO_-VOLNEY_345_12-OV	0		0		0	
OSWEGO EXPORT_17-EO_O/S	325596	B	5250	-9999	5250	-9999	25234	OSWEGO_-ELBRIDGE_345_17-EO	0		0		0	
OSWEGO EXPORT_17-LE_O/S	325596	B	5250	-9999	5250	-9999	25149	ELBRIDGE-LAFAYTTE_345_17-LE	0		0		0	
OSWEGO EXPORT_19_O/S	325596	B	4900	-9999	4900	-9999	25345	VOLNEY_-MARCY_345_19	0		0		0	
OSWEGO EXPORT_20-SV_O/S	325596	B	5250	-9999	5250	-9999	25204	SCRIBA_-VOLNEY_345_20-SV	0		0		0	
OSWEGO EXPORT_2-15_O/S	325596	B	4850	-9999	4850	-9999	25169	CLAY_-EDIC_345_2-15	0		0		0	
OSWEGO EXPORT_21-SV_O/S	325596	B	5250	-9999	5250	-9999	25314	SCRIBA_-VOLNEY_345_21-SV	0		0		0	
OSWEGO EXPORT_25_O/S	325596	B	5250	-9999	5250	-9999	25859	INDPDNCE-SCRIBA_345_25	0		0		0	
OSWEGO EXPORT_26_O/S	325596	B	5000	-9999	5000	-9999	25858	CLAY_-INDPDNCE_345_26	0		0		0	
OSWEGO EXPORT_6-CV_O/S	325596	B	5250	-9999	5250	-9999	25198	VOLNEY_-CLAY_345_6-CV	0		0		0	
OSWEGO EXPORT_8-NC_O/S	325596	B	5150	-9999	5150	-9999	25167	NINEMILE-CLAY_345_8-NC	0		0		0	
OSWEGO EXPORT_ALI	325596	B	5250	-9999	5250	-9999	0		0		0		0	
OSWEGO EXPORT_FE-1_O/S	325596	B	4800	-9999	4800	-9999	25077	FITZPTRK-EDIC_345_FE1	0		0		0	
OSWEGO EXPORT_UE1-7_O/S	325596	B	5250	-9999	5250	-9999	25229	MARCY_-EDIC_345_UE1-7	0		0		0	
SCH-HQ_CEDARS_12-AD_O/S	325274	B	70	-40	100	-9999	25227	ALCOA_-DENNISON_115_12-AD	0		0		0	
SCH-HQ_CEDARS_1-BH_O/S	325274	B	100	-9999	130	-9999	26078	BROWNFLS-HIGLEY_115_1-BH	0		0		0	
SCH-HQ_CEDARS_1-CR_O/S	325274	B	95	-9999	95	-9999	26083	CEDARS_-ROSEMNTA_115_1-CR	0		0		0	
SCH-HQ_CEDARS_1-HC_O/S	325274	B	100	-9999	130	-9999	26087	COLTON_-HIGLEY_115_1-HC	0		0		0	
SCH-HQ_CEDARS_1-RD_O/S	325274	B	95	-9999	95	-9999	25523	DENNISON-ROSEMNTA_115_1-RD	0		0		0	
SCH-HQ_CEDARS_2-CF_O/S	325274	B	100	-9999	130	-9999	26088	COLTON_-FLATROCK_115_2-CF	0		0		0	
SCH-HQ_CEDARS_2-CR_O/S	325274	B	95	-9999	95	-9999	26082	CEDARS_-ROSEMNTB_115_2-CR	0		0		0	
SCH-HQ_CEDARS_2-FBF_O/S	325274	B	100	-9999	130	-9999	26079	FLATROCK-BROWNFLS_115_2-FBF	0		0		0	
SCH-HQ_CEDARS_2-RD_O/S	325274	B	95	-9999	95	-9999	25524	DENNISON-ROSEMNTB_115_2-RD	0		0		0	
SCH-HQ_CEDARS_3-BT_O/S	325274	B	70	-9999	100	-9999	26076	BROWNFLS-TAYLORVL_115_3-BT	0		0		0	
SCH-HQ_CEDARS_4-BT_O/S	325274	B	70	-9999	100	-9999	26077	BROWNFLS-TAYLORVL_115_4-BT	0		0		0	
SCH-HQ_CEDARS_4-DA_O/S	325274	B	145	-9999	145	-9999	25225	DENNISON-NORFOLK_115_4-DA	0		0		0	
SCH-HQ_CEDARS_4-NS_O/S	325274	B	145	-9999	145	-9999	26111	NORFOLK_-SANDSTON_115_4-NS	0		0		0	
SCH-HQ_CEDARS_4-SC_O/S	325274	B	145	-9999	145	-9999	26084	SANDSTON-COLTON_115_4-SC	0		0		0	
SCH-HQ_CEDARS_5-DS_O/S	325274	B	145	-9999	145	-9999	25226	DENNISON-SANDSTON_115_5-DS	0		0		0	
SCH-HQ_CEDARS_5-LB_O/S	325274	B	130	-9999	195	-9999	26075	LOWVILLE-BOONVLE_115_5-LB	0		0		0	
SCH-HQ_CEDARS_5-SC_O/S	325274	B	145	-9999	145	-9999	26085	SANDSTON-COLTON_115_5-SC	0		0		0	
SCH-HQ_CEDARS_5-TL_O/S	325274	B	130	-9999	195	-9999	26107	TAYLORVL-LOWVILLE_115_5-TL	0		0		0	
SCH-HQ_CEDARS_6-BB_O/S	325274	B	130	-9999	195	-9999	325265	BULYMO_-BOONVLE_115_6	0		0		0	
SCH-HQ_CEDARS_6-TB_O/S	325274	B	130	-9999	195	-9999	26070	TAYLORVL-BULYMO_115_6	0		0		0	
SCH-HQ_CEDARS_ALCOA_BUS_O/S	325274	B	70	0	100	-60	25227	ALCOA_-DENNISON_115_12-AD	25230	ALCOA_-NOGDNBRG_115_13-ANO	0		0	
SCH-HQ_CEDARS_ALCOA_R8105_O/S	325274	B	70	0	100	-60	325291	ILCTLIMIT_115KV_ALCOA_R8105_TIE_B	0		0		0	
SCH-HQ_CEDARS_ALI	325274	B	190	-40	199	-100	0		0		0		0	
SCH-HQ_CEDARS_COLTON_BUS_A_O/S	325274	B	80	-40	110	-60	26084	SANDSTON-COLTON_115_4-SC	26086	PYRITES_-COLTON_115_7-PC	26087	COLTON_-HIGLEY_115_1-HC	0	
SCH-HQ_CEDARS_COLTON_BUS_B_O/S	325274	B	80	-40	110	-60	25241	PARISHVL-COLTON_115_3-CP	25514	MCINTYRE-COLTON_115_8-MC	26085	SANDSTON-COLTON_115_5-SC	26088	COLTON_-FLATROCK_115_2-CF
SCH-HQ_CEDARS_DENNSN_BUS_A_O/S	325274	B	70	-40	100	-9999	25227	ALCOA_-DENNISON_115_12-AD	25524	DENNISON-ROSEMNTB_115_2-RD	25525	WOOD_ST_-MILLWOOD_345_W81	0	
SCH-HQ_CEDARS_DENNSONI_R8105_O/S	325274	B	60	-9999	60	-9999	325292	ILCTLIMIT_115KV_DENNI_R8105_TIE_B	0		0		0	
SCH-HQ_CEDARS_TAYLR_BUS_BL_O/S	325274	B	80	-9999	120	-9999	26076	BROWNFLS-TAYLORVL_115_3-BT	26107	TAYLORVL-LOWVILLE_115_5-TL	26431	CLIMAX_-TAYLORVL_115_8-CT	0	
SCH-HQ_CEDARS_TAYLR_BUS_WH_O/S	325274	B	80	-9999	120	-9999	26070	TAYLORVL-BULYMO_115_6	26077	BROWNFLS-TAYLORVL_115_4-BT	26090	FORTDRUM-TAYLORVL_115_2	0	
SCH-HQ-NY_7040_O/S	23324	B	0	0	0	0	25301	CHATGUAY-MASSENA_765_7040	0		0		0	
SCH-HQ-NY_ALI	23324	B	1500	-1000	1500	-1000	0		0		0		0	
SCH-HQ-NY_BP76+PA301_O/S	23324	B	1500	-500	1500	-500	25024	BECK_-PACKARD_230_BP76	25040	BECK_-NIAGARA_345_PA301	0		0	
SCH-HQ-NY_BP76+PA302_O/S	23324	B	1500	-500	1500	-500	25024	BECK_-PACKARD_230_BP76	25041	BECK_-NIAGARA_345_PA302	0		0	
SCH-HQ-NY_MSU_TRANSFER_TRIP_O/S	23324	B	650	-1000	650	-1000	325581	MSU_TRANSFER_TRIP	0		0		0	
SCH-HQ-NY_MSU-1_O/S	23324	B	475	-1000	475	-1000	25224	MASSENA_-MARCY_765_MSU1	0		0		0	
SCH-HQ-NY_PA301+PA302_O/S	23324	B	1500	-500	1500	-500	25040	BECK_-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302	0		0	
SCH-HQ-NY_Pole1_O/S	23324	B	1650	-500	1650	-500	23748	CHAT_DC_GC1	0		0		0	
SCH-HQ-NY_Pole1+Pole2_O/S	23324	B	1370	0	1370	0	23748	CHAT_DC_GC1	23749	CHAT_DC_GC2	0		0	

Interface Name	PTID	Limit Change Flag	Summer FWD Limit	Summer RVR Limit	Winter FWD Limit	Winter RVR Limit	Outage PTID1	Outage Name	Outage PTID2	Outage Name	Outage PTID3	Outage Name	Outage PTID4	Outage Name
SCH-HQ-NY_Pole2_O/S	23324	B	1650	-500	1650	-500	23749	CHAT_DC_GC2	0		0		0	
SCH-IMO-NY_ALI	23317	B	1900	-1900	1900	-1900	0		0		0		0	
SCH-IMO-NY_BP76_L33P_O/S	23317	B	1750	-1100	1750	-1100	25024	BECK____-PACKARD_230_BP76	25026	STLAWRNC-MOSES____230_L33P	0		0	
SCH-IMO-NY_BP76_L34P_O/S	23317	B	1750	-1100	1750	-1100	25024	BECK____-PACKARD_230_BP76	25037	STLAWRNC-MOSES____230_L34P	0		0	
SCH-IMO-NY_BP76_NIAG_CB_3002_O/S	23317	B	1300	-1200	1300	-1200	25024	BECK____-PACKARD_230_BP76	325587	SCH-NYISO-IMO_NIAGARA_CB_3002	0		0	
SCH-IMO-NY_BP76_NIAG_CB_3008_O/S	23317	B	1600	-1200	1600	-1200	25024	BECK____-PACKARD_230_BP76	325723	SCH-NYISO-IMO_NIAGARA_CB_3008	0		0	
SCH-IMO-NY_BP76_NIAG_CB_3022_O/S	23317	B	1300	-1200	1300	-1200	25024	BECK____-PACKARD_230_BP76	325585	SCH-NYISO-IMO_NIAGARA_CB_3022	0		0	
SCH-IMO-NY_BP76_NIAG_CB_3102_O/S	23317	B	1600	-1200	1600	-1200	25024	BECK____-PACKARD_230_BP76	325722	SCH-NYISO-IMO_NIAGARA_CB_3102	0		0	
SCH-IMO-NY_BP76_NIAG_CB_3108_O/S	23317	B	1800	-1200	1800	-1200	25024	BECK____-PACKARD_230_BP76	325586	SCH-NYISO-IMO_NIAGARA_CB_3108	0		0	
SCH-IMO-NY_BP76_NIAG_CB_3122_O/S	23317	B	1600	-1200	1600	-1200	25024	BECK____-PACKARD_230_BP76	325721	SCH-NYISO-IMO_NIAGARA_CB_3122	0		0	
SCH-IMO-NY_BP76_O/S	23317	B	1750	-1200	1750	-1200	25024	BECK____-PACKARD_230_BP76	0		0		0	
SCH-IMO-NY_BP76+PA301_O/S	23317	B	300	-300	300	-300	25024	BECK____-PACKARD_230_BP76	25040	BECK____-NIAGARA_345_PA301	0		0	
SCH-IMO-NY_BP76+PA302_O/S	23317	B	300	-300	300	-300	25024	BECK____-PACKARD_230_BP76	25041	BECK____-NIAGARA_345_PA302	0		0	
SCH-IMO-NY_L33P_O/S	23317	B	1750	-1750	1800	-1850	25026	STLAWRNC-MOSES____230_L33P	0		0		0	
SCH-IMO-NY_L34P_O/S	23317	B	1750	-1750	1800	-1850	25037	STLAWRNC-MOSES____230_L34P	0		0		0	
SCH-IMO-NY_NIAG_BK4_O/S	23317	B	1900	-1900	1900	-1700	25449	NIAGARA_345_230_BK 4	0		0		0	
SCH-IMO-NY_NIAG_CB_3002_O/S	23317	B	1600	-1450	1600	-1500	325587	SCH-NYISO-IMO_NIAGARA_CB_3002	0		0		0	
SCH-IMO-NY_NIAG_CB_3008_O/S	23317	B	1200	-1100	1950	-1900	325723	SCH-NYISO-IMO_NIAGARA_CB_3008	0		0		0	
SCH-IMO-NY_NIAG_CB_3022_O/S	23317	B	1600	-1450	1600	-1500	325585	SCH-NYISO-IMO_NIAGARA_CB_3022	0		0		0	
SCH-IMO-NY_NIAG_CB_3102_O/S	23317	B	1650	-1850	1800	-1850	325722	SCH-NYISO-IMO_NIAGARA_CB_3102	0		0		0	
SCH-IMO-NY_NIAG_CB_3108_O/S	23317	B	1950	-1950	1950	-1950	325586	SCH-NYISO-IMO_NIAGARA_CB_3108	0		0		0	
SCH-IMO-NY_NIAG_CB_3122_O/S	23317	B	1350	-1850	1800	-1850	325721	SCH-NYISO-IMO_NIAGARA_CB_3122	0		0		0	
SCH-IMO-NY_NIAG_CB_3122_W/BB	23317	B	1700	-1850	1700	-1850	326056	SCH_IMO_NY_NIAG_CB_3122_W/BB	0		0		0	
SCH-IMO-NY_NIAG_CB_3202_W/BB	23317	B	1200	-1100	1200	-1100	326057	SCH_IMO_NY_NIAG_CB_3202_O/S	0		0		0	
SCH-IMO-NY_NIAG_NORTH_BUS_O/S	23317	B	1200	-1100	1250	-1150	325583	SCH-NYISO-IMO_NIAGARA_NORTH_BUS	0		0		0	
SCH-IMO-NY_NIAG_NORTH_BUS_W/BB	23317	B	1600	-1500	1600	-1500	326058	SCH_IMO_NY_NIAG_NRTH_BUS_W/BB	0		0		0	
SCH-IMO-NY_NIAG_SOUTH_BUS_O/S	23317	B	1200	-1100	1250	-1150	325584	SCH-NYISO-IMO_NIAGARA_SOUTH_BUS	0		0		0	
SCH-IMO-NY_NIAG_SOUTH_BUS_W/BB	23317	B	1600	-1500	1600	-1500	326059	SCH_IMO_NY_NIAG_SOUTH_BUS_W/BB	0		0		0	
SCH-IMO-NY_PA27_O/S	23317	B	1900	-1900	1950	-2000	25025	BECK____-NIAGARA_230_PA27	0		0		0	
SCH-IMO-NY_PA301_O/S	23317	B	1200	-1100	1200	-1100	25040	BECK____-NIAGARA_345_PA301	0		0		0	
SCH-IMO-NY_PA301+PA302_O/S	23317	B	300	-300	300	-300	25040	BECK____-NIAGARA_345_PA301	25041	BECK____-NIAGARA_345_PA302	0		0	
SCH-IMO-NY_PA302_O/S	23317	B	1200	-1100	1200	-1100	25041	BECK____-NIAGARA_345_PA302	0		0		0	
SCH-NE-NY_2_O/S	23318	B	750	-1350	750	-1550	25217	N.SCTLND-ALPS_345_2-AN	0		0		0	
SCH-NE-NY_312_O/S	23318	B	1050	-1200	1300	-1200	25366	BERKSHIR-NORTHFLD_345_312	0		0		0	
SCH-NE-NY_352_O/S	23318	B	1150	-1600	1150	-1600	25363	FROST_BR-LONG_MTN_345_352	0		0		0	
SCH-NE-NY_393_O/S	23318	B	950	-1000	1200	-1000	25034	BERKSHIR-ALPS_345_393	0		0		0	
SCH-NE-NY_393+312_O/S	23318	B	950	-1000	1200	-1000	25034	BERKSHIR-ALPS_345_393	25366	BERKSHIR-NORTHFLD_345_312	0		0	
SCH-NE-NY_398_O/S	23318	B	300	-1300	850	-1400	25033	LONG_MTN-PLSNTVLY_345_398	0		0		0	
SCH-NE-NY_ALI	23318	B	1400	-1600	1400	-1600	0		0		0		0	
SCH-NE-NY_E205W+398_O/S	23318	B	350	-1150	600	-1100	25030	BEAR SWP-ROTTDRAM_230_E205W	25033	LONG_MTN-PLSNTVLY_345_398	0		0	
SCH-NPX_1385_2-AN_601_O/S	325277	B	0	0	0	0	25217	N.SCTLND-ALPS_345_2-AN	325597	NRTH1385-NOR HBR_138_601	0		0	
SCH-NPX_1385_2-AN_602_O/S	325277	B	0	0	0	0	25217	N.SCTLND-ALPS_345_2-AN	325598	NRTH1385-NOR HBR_138_602	0		0	
SCH-NPX_1385_2-AN_603_O/S	325277	B	0	0	0	0	25217	N.SCTLND-ALPS_345_2-AN	325599	NRTH1385-NOR HBR_138_603	0		0	
SCH-NPX_1385_2-AN_O/S	325277	B	100	-100	100	-100	25217	N.SCTLND-ALPS_345_2-AN	0		0		0	
SCH-NPX_1385_312_601_O/S	325277	B	0	0	0	0	25366	BERKSHIR-NORTHFLD_345_312	325597	NRTH1385-NOR HBR_138_601	0		0	
SCH-NPX_1385_312_602_O/S	325277	B	0	0	0	0	25366	BERKSHIR-NORTHFLD_345_312	325598	NRTH1385-NOR HBR_138_602	0		0	
SCH-NPX_1385_312_603_O/S	325277	B	0	0	0	0	25366	BERKSHIR-NORTHFLD_345_312	325599	NRTH1385-NOR HBR_138_603	0		0	
SCH-NPX_1385_312_O/S	325277	B	100	-100	100	-100	25366	BERKSHIR-NORTHFLD_345_312	0		0		0	
SCH-NPX_1385_329_601_O/S	325277	B	0	0	0	0	25364	FROST_BR-SOUTHNGT_345_329	325597	NRTH1385-NOR HBR_138_601	0		0	
SCH-NPX_1385_329_602_O/S	325277	B	0	0	0	0	25364	FROST_BR-SOUTHNGT_345_329	325598	NRTH1385-NOR HBR_138_602	0		0	
SCH-NPX_1385_329_603_O/S	325277	B	0	0	0	0	25364	FROST_BR-SOUTHNGT_345_329	325599	NRTH1385-NOR HBR_138_603	0		0	
SCH-NPX_1385_352_601_O/S	325277	B	0	0	0	0	25363	FROST_BR-LONG_MTN_345_352	325597	NRTH1385-NOR HBR_138_601	0		0	
SCH-NPX_1385_352_602_O/S	325277	B	0	0	0	0	25363	FROST_BR-LONG_MTN_345_352	325598	NRTH1385-NOR HBR_138_602	0		0	
SCH-NPX_1385_352_603_O/S	325277	B	0	0	0	0	25363	FROST_BR-LONG_MTN_345_352	325599	NRTH1385-NOR HBR_138_603	0		0	
SCH-NPX_1385_393_601_O/S	325277	B	0	0	0	0	25034	BERKSHIR-ALPS_345_393	325597	NRTH1385-NOR HBR_138_601	0		0	
SCH-NPX_1385_393_602_O/S	325277	B	0	0	0	0	25034	BERKSHIR-ALPS_345_393	325598	NRTH1385-NOR HBR_138_602	0		0	
SCH-NPX_1385_393_603_O/S	325277	B	0	0	0	0	25034	BERKSHIR-ALPS_345_393	325599	NRTH1385-NOR HBR_138_603	0		0	
SCH-NPX_1385_393_O/S	325277	B	100	-100	100	-100	25034	BERKSHIR-ALPS_345_393	0		0		0	
SCH-NPX_1385_398_601_O/S	325277	B	0	0	0	0	25033	LONG_MTN-PLSNTVLY_345_398	325597	NRTH1385-NOR HBR_138_601	0		0	
SCH-NPX_1385_398_602_O/S	325277	B	0	0	0	0	25033	LONG_MTN-PLSNTVLY_345_398	325598	NRTH1385-NOR HBR_138_602	0		0	
SCH-NPX_1385_398_603_O/S	325277	B	0	0	0	0	25033	LONG_MTN-PLSNTVLY_345_398	325599	NRTH1385-NOR HBR_138_603	0		0	
SCH-NPX_1385_398_O/S	325277	B	100	-100	100	-100	25033	LONG_MTN-PLSNTVLY_345_398	0		0		0	

Interface Name	PTID	Limit Change Flag	Summer FWD Limit	Summer RVR Limit	Winter FWD Limit	Winter RVR Limit	Outage PTID1	Outage Name	Outage PTID2	Outage Name	Outage PTID3	Outage Name	Outage PTID4	Outage Name
SCH-NPX_1385_601_602_O/S	325277	B	0	0	0	0	325597	NRTH1385-NOR HBR_138_601	325598	NRTH1385-NOR HBR_138_602	0		0	
SCH-NPX_1385_601_603_O/S	325277	B	0	0	0	0	325597	NRTH1385-NOR HBR_138_601	325599	NRTH1385-NOR HBR_138_603	0		0	
SCH-NPX_1385_601_O/S	325277	B	100	-100	100	-100	325597	NRTH1385-NOR HBR_138_601	0		0		0	
SCH-NPX_1385_602_603_O/S	325277	B	0	0	0	0	325598	NRTH1385-NOR HBR_138_602	325599	NRTH1385-NOR HBR_138_603	0		0	
SCH-NPX_1385_602_O/S	325277	B	100	-100	100	-100	325598	NRTH1385-NOR HBR_138_602	0		0		0	
SCH-NPX_1385_603_O/S	325277	B	100	-100	100	-100	325599	NRTH1385-NOR HBR_138_603	0		0		0	
SCH-NPX_1385_ALI	325277	B	200	-200	200	-200	0		0		0		0	
SCH-PJM-NY_30_O/S	23316	B	2200	-2200	2500	-2500	25018	HOMER C_-WATRCURE_345_30	0		0		0	
SCH-PJM-NY_31_O/S	23316	B	2400	-2700	2700	-2650	25178	WATRCURE-OAKDALE_345_31	0		0		0	
SCH-PJM-NY_37_O/S	23316	B	2300	-2700	2600	-2650	25036	HOMER C_-STOLLERD_345_37	0		0		0	
SCH-PJM-NY_5018_O/S	23316	B	1900	-1850	1900	-1850	25019	HOPATCON-RAMAPO_500_5018	0		0		0	
SCH-PJM-NY_5060_O/S	23316	B	1900	-1850	1900	-1850	101017672	BRANCHBG-HOPATCON_500_5060	0		0		0	
SCH-PJM-NY_A2253_O/S	23316	B	2300	-2300	2600	-2600	25017	LINDEN_-GOETHALS_230_A2253	0		0		0	
SCH-PJM-NY_A2253+B3402_O/S	23316	B	2300	-2200	2500	-2500	25017	LINDEN_-GOETHALS_230_A2253	25020	HUDSONP_-FARRAGUT_345_B3402	0		0	
SCH-PJM-NY_A2253+C3403_O/S	23316	B	2300	-2200	2500	-2500	25017	LINDEN_-GOETHALS_230_A2253	25038	HUDSONP_-FARRAGUT_345_C3403	0		0	
SCH-PJM-NY_ALI	23316	B	2450	-1300	2450	-1300	0		0		0		0	
SCH-PJM-NY_B3402_O/S	23316	B	2300	-2300	2600	-2600	25020	HUDSONP_-FARRAGUT_345_B3402	0		0		0	
SCH-PJM-NY_B3402+C3403_O/S	23316	B	2300	-2200	2500	-2500	25020	HUDSONP_-FARRAGUT_345_B3402	25038	HUDSONP_-FARRAGUT_345_C3403	0		0	
SCH-PJM-NY_BP76+PA301_O/S	23316	B	1300	-1500	1300	-1500	25024	BECK_-PACKARD_230_BP76	25040	BECK_-NIAGARA_345_PA301	0		0	
SCH-PJM-NY_BP76+PA302_O/S	23316	B	1300	-1500	1300	-1500	25024	BECK_-PACKARD_230_BP76	25041	BECK_-NIAGARA_345_PA302	0		0	
SCH-PJM-NY_C3403_O/S	23316	B	2300	-2300	2600	-2600	25038	HUDSONP_-FARRAGUT_345_C3403	0		0		0	
SCH-PJM-NY_PA301+PA302_O/S	23316	B	1300	-1500	1300	-1500	25040	BECK_-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302	0		0	
SCH-PJM-NY_PAR3500_O/S	23316	B	2400	-2350	2400	-2350	25370	RAMAPO_345_345_PAR3500	0		0		0	
SCH-PJM-NY_PAR4500_O/S	23316	B	2400	-2350	2400	-2350	25371	RAMAPO_345_345_PAR4500	0		0		0	
SCH-PJM-NY_WATRCURE_BK1_O/S	23316	B	2450	-2350	2450	-2650	25402	WATRCURE_345_230_BK1	0		0		0	
Sprain/Dunwd-South_ALI	23320	B	4600	-9999	4600	-9999	0		0		0		0	
Sprain/Dunwd-South_REACTORS_I/S	23320	B	4350	-9999	4350	-9999	325295	ILCTLIMT_345KV_DUNWOD_R71_REACTR	325296	ILCTLIMT_345KV_DUNWOD_R72_REACTR	325297	ILCTLIMT_345KV_SPRNBK_4S3_REACTR	325298	ILCTLIMT_345KV_SPRNBK_5S3_REACTR
Tot-East_5018_O/S	23314	B	6400	-9999	6400	-9999	25019	HOPATCON-RAMAPO_500_5018	0		0		0	
Tot-East_5018+Fraser_SVC_O/S	23314	B	6300	-9999	6300	-9999	25019	HOPATCON-RAMAPO_500_5018	31328	FRASER_345_FRASER SVC	0		0	
Tot-East_5018+Leeds_SVC_O/S	23314	B	6300	-9999	6300	-9999	25019	HOPATCON-RAMAPO_500_5018	31327	LEEDS_345_LEEDS SVC	0		0	
Tot-East_5060_O/S	23314	B	6400	-9999	6400	-9999	101017672	BRANCHBG-HOPATCON_500_5060	0		0		0	
Tot-East_5060+Fraser_SVC_O/S	23314	B	6300	-9999	6300	-9999	101017672	BRANCHBG-HOPATCON_500_5060	31328	FRASER_345_FRASER SVC	0		0	
Tot-East_5060+Leeds_SVC_O/S	23314	B	6300	-9999	6300	-9999	101017672	BRANCHBG-HOPATCON_500_5060	31327	LEEDS_345_LEEDS SVC	0		0	
Tot-East_ALI	23314	B	6500	-9999	6500	-9999	0		0		0		0	
UPNY-CE_5018_O/S	23315	B	4000	-9999	4000	-9999	25019	HOPATCON-RAMAPO_500_5018	0		0		0	
UPNY-CE_5060_O/S	23315	B	4000	-9999	4000	-9999	101017672	BRANCHBG-HOPATCON_500_5060	0		0		0	
UPNY-CE_ALI	23315	B	5100	-9999	5100	-9999	0		0		0		0	
UPNY-CE_REACTORS_I/S	23315	B	4850	-9999	4850	-9999	325295	ILCTLIMT_345KV_DUNWOD_R71_REACTR	325296	ILCTLIMT_345KV_DUNWOD_R72_REACTR	325297	ILCTLIMT_345KV_SPRNBK_4S3_REACTR	325298	ILCTLIMT_345KV_SPRNBK_5S3_REACTR
UPNY-CE_RFK-305_O/S	23315	B	4100	-9999	4100	-9999	25108	ROSETON_-EFISHKIL_345_305	0		0		0	
UPNY-CE_Y88_O/S	23315	B	4150	-9999	4150	-9999	25185	LADENTWN-BUCHAN_S_345_Y88	0		0		0	
UPNY-CE_Y94_O/S	23315	B	4150	-9999	4150	-9999	25184	RAMAPO_-BUCHAN_N_345_Y94	0		0		0	
West-Cent_ALI	23312	B	2250	-9999	2250	-9999	0		0		0		0	
West-Cent_NR-2_O/S	23312	B	1750	-9999	1750	-9999	25084	NIAGARA_-ROCHESTR_345_NR2	0		0		0	
West-Cent_PC-1_O/S	23312	B	1300	-9999	1300	-9999	25058	PANNELL_-CLAY_345_PC1	0		0		0	
West-Cent_PC-2_O/S	23312	B	1300	-9999	1300	-9999	25050	PANNELL_-CLAY_345_PC2	0		0		0	
West-Cent_RP-1_O/S	23312	B	1900	-9999	1900	-9999	25192	ROCHESTR-PANNELL_345_RP1	0		0		0	
West-Cent_RP-2_O/S	23312	B	1900	-9999	1900	-9999	25172	ROCHESTR-PANNELL_345_RP2	0		0		0	
West-Cent_SR-1_O/S	23312	B	1700	-9999	1700	-9999	25073	KINTIGH_-ROCHESTR_345_SR1-39	0		0		0	
WESTERN_EXP_ALI	23327	B	8100	-9999	8100	-9999	0		0		0		0	
WESTERN_EXP_BP76	23327	B	6350	-9999	6350	-9999	25024	BECK_-PACKARD_230_BP76	0		0		0	
WESTERN_EXP_NR2	23327	B	7700	-9999	7700	-9999	25084	NIAGARA_-ROCHESTR_345_NR2	0		0		0	
WESTERN_EXP_NS1-38	23327	B	7700	-9999	7700	-9999	25074	NIAGARA_-KINTIGH_345_NS1-38	0		0		0	
WESTERN_EXP_PA27	23327	B	6350	-9999	6350	-9999	25025	BECK_-NIAGARA_230_PA27	0		0		0	
WESTERN_EXP_PA301	23327	B	4600	-9999	4600	-9999	25040	BECK_-NIAGARA_345_PA301	0		0		0	
WESTERN_EXP_PA301_BP76	23327	B	1100	-9999	1100	-9999	25024	BECK_-PACKARD_230_BP76	25040	BECK_-NIAGARA_345_PA301	0		0	
WESTERN_EXP_PA301_BP76_NR2	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25040	BECK_-NIAGARA_345_PA301	25084	NIAGARA_-ROCHESTR_345_NR2	0	
WESTERN_EXP_PA301_BP76_NS1-38	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25040	BECK_-NIAGARA_345_PA301	25074	NIAGARA_-KINTIGH_345_NS1-38	0	
WESTERN_EXP_PA301_BP76_PC1	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25040	BECK_-NIAGARA_345_PA301	25058	PANNELL_-CLAY_345_PC1	0	
WESTERN_EXP_PA301_BP76_PC2	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25040	BECK_-NIAGARA_345_PA301	25050	PANNELL_-CLAY_345_PC2	0	
WESTERN_EXP_PA301_BP76_RP1	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25040	BECK_-NIAGARA_345_PA301	25192	ROCHESTR-PANNELL_345_RP1	0	
WESTERN_EXP_PA301_BP76_RP2	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25040	BECK_-NIAGARA_345_PA301	25172	ROCHESTR-PANNELL_345_RP2	0	
WESTERN_EXP_PA301_BP76_SR1-39	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25040	BECK_-NIAGARA_345_PA301	25073	KINTIGH_-ROCHESTR_345_SR1-39	0	

Interface Name	PTID	Limit Change Flag	Summer FWD Limit	Summer RVR Limit	Winter FWD Limit	Winter RVR Limit	Outage PTID1	Outage Name	Outage PTID2	Outage Name	Outage PTID3	Outage Name	Outage PTID4	Outage Name
WESTERN_EXP_PA301_PA27_BP76	23327	B	1100	-9999	1100	-9999	25024	BECK_-PACKARD_230_BP76	25025	BECK_-NIAGARA_230_PA27	25040	BECK_-NIAGARA_345_PA301	0	
WESTERN_EXP_PA301_PA27_NR2	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25040	BECK_-NIAGARA_345_PA301	25084	NIAGARA_-ROCHESTR_345_NR2	0	
WESTERN_EXP_PA301_PA27_NS1-38	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25040	BECK_-NIAGARA_345_PA301	25074	NIAGARA_-KINTIGH_345_NS1-38	0	
WESTERN_EXP_PA301_PA27_PC1	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25040	BECK_-NIAGARA_345_PA301	25058	PANNELL_-CLAY_345_PC1	0	
WESTERN_EXP_PA301_PA27_PC2	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25040	BECK_-NIAGARA_345_PA301	25050	PANNELL_-CLAY_345_PC2	0	
WESTERN_EXP_PA301_PA27_RP1	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25040	BECK_-NIAGARA_345_PA301	25192	ROCHESTR-PANNELL_345_RP1	0	
WESTERN_EXP_PA301_PA27_RP2	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25040	BECK_-NIAGARA_345_PA301	25172	ROCHESTR-PANNELL_345_RP2	0	
WESTERN_EXP_PA301_PA27_SR1-39	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25040	BECK_-NIAGARA_345_PA301	25073	KINTIGH_-ROCHESTR_345_SR1-39	0	
WESTERN_EXP_PA301_PA302	23327	B	1100	-9999	1100	-9999	25040	BECK_-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302	0		0	
WESTERN_EXP_PA301_PA302_BP76	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25040	BECK_-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302	0	
WESTERN_EXP_PA301_PA302_NR2	23327	B	700	-9999	700	-9999	25040	BECK_-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302	25084	NIAGARA_-ROCHESTR_345_NR2	0	
WESTERN_EXP_PA301_PA302_NS1-38	23327	B	700	-9999	700	-9999	25040	BECK_-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302	25074	NIAGARA_-KINTIGH_345_NS1-38	0	
WESTERN_EXP_PA301_PA302_PA27	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25040	BECK_-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302	0	
WESTERN_EXP_PA301_PA302_PC1	23327	B	700	-9999	700	-9999	25040	BECK_-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302	25058	PANNELL_-CLAY_345_PC1	0	
WESTERN_EXP_PA301_PA302_PC2	23327	B	700	-9999	700	-9999	25040	BECK_-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302	25050	PANNELL_-CLAY_345_PC2	0	
WESTERN_EXP_PA301_PA302_RP1	23327	B	700	-9999	700	-9999	25040	BECK_-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302	25192	ROCHESTR-PANNELL_345_RP1	0	
WESTERN_EXP_PA301_PA302_RP2	23327	B	700	-9999	700	-9999	25040	BECK_-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302	25172	ROCHESTR-PANNELL_345_RP2	0	
WESTERN_EXP_PA301_PA302_SR1-39	23327	B	700	-9999	700	-9999	25040	BECK_-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302	25073	KINTIGH_-ROCHESTR_345_SR1-39	0	
WESTERN_EXP_PA302	23327	B	4600	-9999	4600	-9999	25041	BECK_-NIAGARA_345_PA302	0		0		0	
WESTERN_EXP_PA302_BP76	23327	B	1100	-9999	1100	-9999	25024	BECK_-PACKARD_230_BP76	25041	BECK_-NIAGARA_345_PA302	0		0	
WESTERN_EXP_PA302_BP76_NR2	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25041	BECK_-NIAGARA_345_PA302	25084	NIAGARA_-ROCHESTR_345_NR2	0	
WESTERN_EXP_PA302_BP76_NS1-38	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25041	BECK_-NIAGARA_345_PA302	25074	NIAGARA_-KINTIGH_345_NS1-38	0	
WESTERN_EXP_PA302_BP76_PC1	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25041	BECK_-NIAGARA_345_PA302	25058	PANNELL_-CLAY_345_PC1	0	
WESTERN_EXP_PA302_BP76_PC2	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25041	BECK_-NIAGARA_345_PA302	25050	PANNELL_-CLAY_345_PC2	0	
WESTERN_EXP_PA302_BP76_RP1	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25041	BECK_-NIAGARA_345_PA302	25192	ROCHESTR-PANNELL_345_RP1	0	
WESTERN_EXP_PA302_BP76_RP2	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25041	BECK_-NIAGARA_345_PA302	25172	ROCHESTR-PANNELL_345_RP2	0	
WESTERN_EXP_PA302_BP76_SR1-39	23327	B	700	-9999	700	-9999	25024	BECK_-PACKARD_230_BP76	25041	BECK_-NIAGARA_345_PA302	25073	KINTIGH_-ROCHESTR_345_SR1-39	0	
WESTERN_EXP_PA302_PA27_BP76	23327	B	1100	-9999	1100	-9999	25024	BECK_-PACKARD_230_BP76	25025	BECK_-NIAGARA_230_PA27	25041	BECK_-NIAGARA_345_PA302	0	
WESTERN_EXP_PA302_PA27_NR2	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25041	BECK_-NIAGARA_345_PA302	25084	NIAGARA_-ROCHESTR_345_NR2	0	
WESTERN_EXP_PA302_PA27_NS1-38	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25041	BECK_-NIAGARA_345_PA302	25074	NIAGARA_-KINTIGH_345_NS1-38	0	
WESTERN_EXP_PA302_PA27_PC1	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25041	BECK_-NIAGARA_345_PA302	25058	PANNELL_-CLAY_345_PC1	0	
WESTERN_EXP_PA302_PA27_PC2	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25041	BECK_-NIAGARA_345_PA302	25050	PANNELL_-CLAY_345_PC2	0	
WESTERN_EXP_PA302_PA27_RP1	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25041	BECK_-NIAGARA_345_PA302	25192	ROCHESTR-PANNELL_345_RP1	0	
WESTERN_EXP_PA302_PA27_RP2	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25041	BECK_-NIAGARA_345_PA302	25172	ROCHESTR-PANNELL_345_RP2	0	
WESTERN_EXP_PA302_PA27_SR1-39	23327	B	700	-9999	700	-9999	25025	BECK_-NIAGARA_230_PA27	25041	BECK_-NIAGARA_345_PA302	25073	KINTIGH_-ROCHESTR_345_SR1-39	0	
WESTERN_EXP_PC1	23327	B	7700	-9999	7700	-9999	25058	PANNELL_-CLAY_345_PC1	0		0		0	
WESTERN_EXP_PC2	23327	B	7700	-9999	7700	-9999	25050	PANNELL_-CLAY_345_PC2	0		0		0	
WESTERN_EXP_RP1	23327	B	7700	-9999	7700	-9999	25192	ROCHESTR-PANNELL_345_RP1	0		0		0	
WESTERN_EXP_RP2	23327	B	7700	-9999	7700	-9999	25172	ROCHESTR-PANNELL_345_RP2	0		0		0	
WESTERN_EXP_SR-1	23327	B	7700	-9999	7700	-9999	25073	KINTIGH_-ROCHESTR_345_SR1-39	0		0		0	

Note 1: "ALI" Denotes "All Lines In Service"

Note 2: The values in this table do not include Transmission Reliability Margin (TRM)