

Interface Name	PTID	Limit Change Flag	Forward Limit	Reverse Limit	Outage 1 PTID	Outage 1	Outage 2	Outage 2	Outage 3	Outage 3
						Name	PTID	Name	PTID	Name
Cent-East_4-46_O/S [3621]	23313	B	2850	-9999	25049	LAFAYTTE-CLRKSCRN_345_4-46	0		0	
Cent-East_14_O/S [3621]	23313	B	2050	-9999	25170	EDIC_PTR-N.SCTLND_345_14-EN	0		0	
Cent-East_18_O/S [3621]	23313	B	2050	-9999	25276	MARCY_-N.SCTLND_345_18	0		0	
Cent-East_32_O/S [3621]	23313	B	3000	-9999	25235	OAKDALE_-FRASER_345_32	0		0	
Cent-East_36_O/S [3621]	23313	B	2850	-9999	325726	CLRKSCRN-OAKDALE_345_36	0		0	
Cent-East_ALI [3621]	23313	B	3050	-9999	0		0		0	
Cent-East_MSU-1_O/S [3621]	23313	B	2650	-9999	25224	MASSENA_-MARCY_765_MSU1	0		0	
Cent-East_VC_14_O/S [3621]	23330	B	1985	-9999	25170	EDIC_PTR-N.SCTLND_345_14-EN	0		0	
Cent-East_VC_18_O/S [3621]	23330	B	1985	-9999	25276	MARCY_-N.SCTLND_345_18	0		0	
Cent-East_VC_30_O/S [3621]	23330	B	2750	-9999	25173	EDIC_PTR-ROTRDAM_230_30-PR	0		0	
Cent-East_VC_31_O/S [3621]	23330	B	2750	-9999	25194	EDIC_PTR-ROTRDAM_230_31-PR	0		0	
Cent-East_VC_ALI [3621]	23330	B	2895	-9999	0		0		0	
Cent-East_VC_FE-1_O/S [3621]	23330	B	2810	-9999	25077	FITZPTRK-EDIC_PTR_345_FE1	0		0	
Cent-East_VC_MSU-1_O/S [3621]	23330	B	2385	-9999	25224	MASSENA_-MARCY_765_MSU1	0		0	
Cent-East_VC_VU-19_O/S [3621]	23330	B	2800	-9999	25345	VOLNEY_-MARCY_345_19	0		0	
Dysinger-East_60_O/S	23326	B	2650	-9999	325604	MEYER_-CANANDGA_230_60	0		0	
Dysinger-East_67_O/S	23326	B	2650	-9999	25064	STOLLERD-HISHELD_N_230_67	0		0	
Dysinger-East_68_O/S	23326	B	2650	-9999	25176	CANANDGA-STONYRDG_230_68	0		0	
Dysinger-East_72_O/S	23326	B	2650	-9999	325810	STONYRDG-HILLSIDE_230_72	0		0	
Dysinger-East_81_O/S	23326	B	2650	-9999	325622	HISHELD-N-WETHSRFD_230_81	0		0	
Dysinger-East_85_O/S	23326	B	2650	-9999	325623	WETHSRFD-MEYER_230_85	0		0	
Dysinger-East_ALI	23326	B	2850	-9999	0	EFISHKCH_345_115_BK_1_XS	0		0	
Dysinger-East_NR-2_O/S	23326	B	1700	-9999	25084	NIAGARA_-ROCHESTR_345_NR2	0		0	
Dysinger-East_SR-1_O/S	23326	B	1700	-9999	25073	KINTIGH_-ROCHESTR_345_SR-1	0		0	
Dysinger-East_RP-1_O/S	23326	B	2300	-9999	25192	ROCHESTR-PANNELL_345_RP1	0		0	
Dysinger-East_RP-2_O/S	23326	B	2300	-9999	25172	ROCHESTR-PANNELL_345_RP2	0		0	
HQ-NY_7040_O/S	325053	B	0	0	25301	CHATGUAY-MASSENA_765_7040	0		0	
HQ-NY_ALI	325053	B	1800	-1000	0		0		0	
HQ-NY_MSU TRANSFER_TRIP_O/S	325053	B	650	-1000	325581	MSU TRANSFER_TRIP	0		0	
HQ-NY_MSU-1_O/S	325053	B	475	-1000	25224	MASSENA_-MARCY_765_MSU1	0		0	
HQ-NY_Pole1_O/S	325053	B	1650	-500	23748	CHAT_DC_GC1	0		0	
HQ-NY_Pole1+Pole2_O/S	325053	B	1370	0	23748	CHAT_DC_GC1	23749	CHAT_DC_GC2	0	
HQ-NY_Pole2_O/S	325053	B	1650	-500	23749	CHAT_DC_GC2	0		0	
IMO-NY_ALI	325055	B	2500	-2500	0		0		0	
IMO-NY_BP76_O/S	325055	B	2300	-2300	25024	BECK_-PACKARD_230_BP76	0		0	
IMO-NY_BP76+PA27_O/S	325055	B	1900	-2300	25024	BECK_-PACKARD_230_BP76	25025	BECK_-NIAGARA_230_PA27	0	
IMO-NY_L33P_O/S	325055	B	2300	-2300	25026	STLAWRNC-MOSES_230_L33P	0		0	
IMO-NY_L34P_O/S	325055	B	2300	-2300	25037	STLAWRNC-MOSES_230_L34P	0		0	
IMO-NY_PA27_O/S	325055	B	2300	-2300	25025	BECK_-NIAGARA_230_PA27	0		0	
IMO-NY_PA301_O/S	325055	B	2300	-2300	25040	BECK_-NIAGARA_345_PA301	0		0	
IMO-NY_PA301+PA302_O/S	325055	B	800	-500	25040	BECK_-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302	0	
IMO-NY_PA302_O/S	325055	B	2300	-2300	25041	BECK_-NIAGARA_345_PA302	0		0	
Mos-Sou_AC-13_O/S	23319	B	2450	-1600	325233	ADIRNDCK-CHASLAKE_230_13	0		0	
Mos-Sou_Alcoa_R8105_O/S	23319	B	2600	-1600	325291	ILTLIMIT_115KV_ALCOA_R8105_TIE_B	0		0	
Mos-Sou_ALI	23319	B	2900	-1600	0		0		0	
Mos-Sou_AP-12_O/S	23319	B	2450	-1600	25082	ADIRNDCK-EDIC_PTR_230_12-AP	0		0	
Mos-Sou_CP-11_O/S	23319	B	2450	-1600	25051	CHASLAKE-EDIC_PTR_230_11	0		0	
Mos-Sou_MA-1_O/S	23319	B	2450	-1600	25269	MOSES_-ADIRNDCK_230_MA1	0		0	
Mos-Sou_MA-2_O/S	23319	B	2450	-1600	25270	MOSES_-ADIRNDCK_230_MA2	0		0	
Mos-Sou_MSU TRANSFER_TRIP_O/S	23319	B	1100	-1100	325581	MSU TRANSFER_TRIP	0		0	
Mos-Sou_MSU-1_O/S	23319	B	675	-1100	25224	MASSENA_-MARCY_765_MSU1	0		0	
Mos-Sou_MSU-1+AC-13_O/S	23319	B	500	-1100	25224	MASSENA_-MARCY_765_MSU1	325233	ADIRNDCK-CHASLAKE_230_13	0	
Mos-Sou_MSU-1+AP-12_O/S	23319	B	500	-1100	25082	ADIRNDCK-EDIC_PTR_230_12-AP	25224	MASSENA_-MARCY_765_MSU1	0	
Mos-Sou_MSU-1+CP-11_O/S	23319	B	500	-1100	25051	CHASLAKE-EDIC_PTR_230_11	25224	MASSENA_-MARCY_765_MSU1	0	
Mos-Sou_MSU-1+MA-1_O/S	23319	B	500	-1100	25224	MASSENA_-MARCY_765_MSU1	25269	MOSES_-ADIRNDCK_230_MA1	0	
Mos-Sou_MSU-1+MA-2_O/S	23319	B	500	-1100	25224	MASSENA_-MARCY_765_MSU1	25270	MOSES_-ADIRNDCK_230_MA2	0	
Mos-Sou_Pole1_O/S	23319	B	2150	-1600	23748	CHAT_DC_GC1	0		0	
Mos-Sou_Pole1+Pole2_O/S	23319	B	2000	-1600	23748	CHAT_DC_GC1	23749	CHAT_DC_GC2	0	
Mos-Sou_Pole2_O/S	23319	B	2150	-1600	23749	CHAT_DC_GC2	0		0	
NE-NY_2_O/S	325054	B	2150	-2150	25217	N.SCTLND-ALPS_345_2-AN	0		0	
NE-NY_312_O/S	325054	B	1950	-1950	25366	BERKSHIR-NORTHFLD_345_312	0		0	
NE-NY_329_O/S	325054	B	2100	-2100	25364	FROST_BR-SOUTHNGT_345_329	0		0	
NE-NY_352_O/S	325054	B	1850	-1850	25363	FROST_BR-LONG_MTN_345_352	0		0	
NE-NY_393_O/S	325054	B	1600	-1600	25034	BERKSHIR-ALPS_345_393	0		0	
NE-NY_393+312_O/S	325054	B	1500	-1500	25034	BERKSHIR-ALPS_345_393	25366	BERKSHIR-NORTHFLD_345_312	0	
NE-NY_398_O/S	325054	B	1150	-1150	25033	LONG_MTN-PLSNVTLY_345_398	0		0	
NE-NY_ALI	325054	B	2200	-2200	0		0		0	
Osw-Complex_1-16_O/S	325596	B	4950	0	25200	CLAY_-EDIC_PTR_345_1-16	0		0	
Osw-Complex_11-OV_O/S	325596	B	5350	0	25199	OSWEGO_-VOLNEY_345_11-OV	0		0	
Osw-Complex_12-OV_O/S	325596	B	5350	0	25201	OSWEGO_-VOLNEY_345_12-OV	0		0	
Osw-Complex_17-EO_O/S	325596	B	5350	0	25234	OSWEGO_-ELBRIDGE_345_17-EO	0		0	
Osw-Complex_17-LE_O/S	325596	B	5350	0	25149	ELBRIDGE-LAFAYTTE_345_17-LE	0		0	
Osw-Complex_19_O/S	325596	B	5000	0	25345	VOLNEY_-MARCY_345_19	0		0	
Osw-Complex_20-SV_O/S	325596	B	5350	0	25204	SCRIBA_-VOLNEY_345_20-SV	0		0	
Osw-Complex_2-15_O/S	325596	B	4950	0	25169	CLAY_-EDIC_PTR_345_2-15	0		0	

Interface Name	PTID	Limit Change Flag	Forward Limit	Reverse Limit	Outage 1 PTID	Outage 1	Outage 2	Outage 2	Outage 3	Outage 3
						Name	PTID	Name	PTID	Name
Osw-Complex_21-SV_O/S	325596	B	5350	0	25314	SCRIBA -VOLNEY 345_21-SV	0			
Osw-Complex_25_O/S	325596	B	5350	0	25859	INDPDNCE-SCRIBA 345_25	0			
Osw-Complex_26_O/S	325596	B	5100	0	25858	CLAY -INDPDNCE 345_26	0			
Osw-Complex_6-CV_O/S	325596	B	5350	0	25198	VOLNEY -CLAY 345_6-CV	0			
Osw-Complex_8-NC_O/S	325596	B	5250	0	25167	NINEMILE-CLAY 345_8-NC	0			
Osw-Complex_ALI	325596	B	5350	0	0		0			
Osw-Complex_FE-1_O/S	325596	B	4900	0	25077	FITZPTRK-EDIC_PTR 345_FE1	0			
Osw-Complex_UE1-7_O/S	325596	B	5350	0	25229	MARCY -EDIC_PTR 345_UE1-7	0			
SCH-HQ_CEDARS_12-AD_O/S	325274	B	245	-200	25227	ALCOA -DENNISON 115_12-AD	0			
SCH-HQ_CEDARS_1-CR_O/S	325274	B	195	-195	26083	CEDARS -ROSEMNTA 115_1-CR	0			
SCH-HQ_CEDARS_1-RD_O/S	325274	B	195	-195	25523	DENNISON-ROSEMNTA 115_1-RD	0			
SCH-HQ_CEDARS_2-CR_O/S	325274	B	195	-195	26082	CEDARS -ROSEMNTB 115_2-CR	0			
SCH-HQ_CEDARS_2-RD_O/S	325274	B	195	-195	25524	DENNISON-ROSEMNTB 115_2-RD	0			
SCH-HQ_CEDARS_4-DA_O/S	325274	B	245	-200	25225	DENNISON-NORFOLK 115_4-DA	0			
SCH-HQ_CEDARS_4-NS_O/S	325274	B	245	-200	26111	NORFOLK -SANDSTON 115_4-NS	0			
SCH-HQ_CEDARS_4-SC_O/S	325274	B	245	-200	26084	SANDSTON-COLTON 115_4-SC	0			
SCH-HQ_CEDARS_5-DS_O/S	325274	B	245	-200	25226	DENNISON-SANDSTON 115_5-DS	0			
SCH-HQ_CEDARS_5-SC_O/S	325274	B	245	-200	26085	SANDSTON-COLTON 115_5-SC	0			
SCH-HQ_CEDARS_ALCOA_R8105_O/S	325274	B	195	-195	325291	ILCTLIMIT_115KV_ALCOA_R8105_TIE_B	0			
SCH-HQ_CEDARS_ALI	325274	B	290	-200	0		0			
SCH-HQ_CEDARS_DENNISONI_R8105_O/S	325274	B	160	-160	325292	ILCTLIMIT_115KV_DENNI_R8105_TIE_B	0			
SCH-HQ-NY_7040_O/S	23324	B	100	-100	25301	CHATGUAY-MASSENA 765_7040	0			
SCH-HQ-NY_ALI	23324	B	1600	-1100	0		0			
SCH-HQ-NY_BP76+PA301_O/S	23324	B	1600	-600	25024	BECK -PACKARD 230_BP76	25040	BECK -NIAGARA 345_PA301	0	
SCH-HQ-NY_BP76+PA302_O/S	23324	B	1600	-600	25024	BECK -PACKARD 230_BP76	25041	BECK -NIAGARA 345_PA302	0	
SCH-HQ-NY_MSU_TRANSFER_TRIP_O/S	23324	B	750	-1100	325581	MSU_TRANSFER_TRIP	0			
SCH-HQ-NY_MSU-1_O/S	23324	B	575	-1100	25224	MASSENA-MARCY 765_MSU1	0			
SCH-HQ-NY_PA301+PA302_O/S	23324	B	1600	-600	25040	BECK -NIAGARA 345_PA301	25041	BECK -NIAGARA 345_PA302	0	
SCH-HQ-NY_Pole1_O/S	23324	B	1750	-600	23748	CHAT_DC_GC1	0			
SCH-HQ-NY_Pole1+Pole2_O/S	23324	B	1470	-100	23748	CHAT_DC_GC1	23749	CHAT_DC_GC2	0	
SCH-HQ-NY_Pole2_O/S	23324	B	1750	-600	23749	CHAT_DC_GC2	0			
SCH-IMO-NY_ALI	23317	B	2000	-1750	0		0			
SCH-IMO-NY_BP76_L33P_O/S	23317	B	1550	-900	25024	BECK -PACKARD 230_BP76	25026	STLAWRNC-MOSES 230_L33P	0	
SCH-IMO-NY_BP76_L34P_O/S	23317	B	1550	-900	25024	BECK -PACKARD 230_BP76	25037	STLAWRNC-MOSES 230_L34P	0	
SCH-IMO-NY_BP76_NIAG_CB_3002_O/S	23317	B	1100	-1000	25024	BECK -PACKARD 230_BP76	325587	SCH-NYISO-IMO_NIAGARA_CB_3002	0	
SCH-IMO-NY_BP76_NIAG_CB_3008_O/S	23317	B	1400	-1000	25024	BECK -PACKARD 230_BP76	325723	SCH-NYISO-IMO_NIAGARA_CB_3008	0	
SCH-IMO-NY_BP76_NIAG_CB_3022_O/S	23317	B	1100	-1000	25024	BECK -PACKARD 230_BP76	325585	SCH-NYISO-IMO_NIAGARA_CB_3022	0	
SCH-IMO-NY_BP76_NIAG_CB_3102_O/S	23317	B	1400	-1000	25024	BECK -PACKARD 230_BP76	325722	SCH-NYISO-IMO_NIAGARA_CB_3102	0	
SCH-IMO-NY_BP76_NIAG_CB_3108_O/S	23317	B	1600	-1000	25024	BECK -PACKARD 230_BP76	325586	SCH-NYISO-IMO_NIAGARA_CB_3108	0	
SCH-IMO-NY_BP76_NIAG_CB_3122_O/S	23317	B	1400	-1000	25024	BECK -PACKARD 230_BP76	325721	SCH-NYISO-IMO_NIAGARA_CB_3122	0	
SCH-IMO-NY_BP76_O/S	23317	B	1650	-1000	25024	BECK -PACKARD 230_BP76	0			
SCH-IMO-NY_BP76+PA301_O/S	23317	B	100	-100	25024	BECK -PACKARD 230_BP76	25040	BECK -NIAGARA 345_PA301	0	
SCH-IMO-NY_BP76+PA302_O/S	23317	B	100	-100	25024	BECK -PACKARD 230_BP76	25041	BECK -NIAGARA 345_PA302	0	
SCH-IMO-NY_L33P_O/S	23317	B	1950	-1550	25026	STLAWRNC-MOSES 230_L33P	0			
SCH-IMO-NY_L34P_O/S	23317	B	1950	-1550	25037	STLAWRNC-MOSES 230_L34P	0			
SCH-IMO-NY_NIAG_BK4_O/S	23317	B	1600	-1300	25449	NIAGARA 345_230_BK4	0			
SCH-IMO-NY_NIAG_CB_3002_O/S	23317	B	1600	-1200	325587	SCH-NYISO-IMO_NIAGARA_CB_3002	0			
SCH-IMO-NY_NIAG_CB_3022_O/S	23317	B	1600	-1200	325585	SCH-NYISO-IMO_NIAGARA_CB_3022	0			
SCH-IMO-NY_NIAG_CB_3108_O/S	23317	B	2000	-1700	325586	SCH-NYISO-IMO_NIAGARA_CB_3108	0			
SCH-IMO-NY_NIAG_NORTH_BUS_O/S	23317	B	1300	-1200	325583	SCH-NYISO-IMO_NIAGARA_NORTH_BUS	0			
SCH-IMO-NY_NIAG_SOUTH_BUS_O/S	23317	B	1300	-1200	325584	SCH-NYISO-IMO_NIAGARA_SOUTH_BUS	0			
SCH-IMO-NY_PA27_O/S	23317	B	1950	-1750	25025	BECK -NIAGARA 230_PA27	0			
SCH-IMO-NY_PA301_O/S	23317	B	1100	-1200	25040	BECK -NIAGARA 345_PA301	0			
SCH-IMO-NY_PA301+PA302_O/S	23317	B	100	-100	25040	BECK -NIAGARA 345_PA301	25041	BECK -NIAGARA 345_PA302	0	
SCH-IMO-NY_PA302_O/S	23317	B	1100	-1200	25041	BECK -NIAGARA 345_PA302	0			
SCH-NE-NY_2_O/S	23318	B	650	-1450	25217	N.SCTLND-ALPS 345_2-AN	0			
SCH-NE-NY_312_O/S	23318	B	1200	-1100	25366	BERKSHIR-NORTHFLD 345_312	0			
SCH-NE-NY_352_O/S	23318	B	1050	-1500	25363	FROST_BR-LONG_MTN 345_352	0			
SCH-NE-NY_393_O/S	23318	B	1100	-900	25034	BERKSHIR-ALPS 345_393	0			
SCH-NE-NY_393+312_O/S	23318	B	1100	-900	25034	BERKSHIR-ALPS 345_393	25366	BERKSHIR-NORTHFLD 345_312	0	
SCH-NE-NY_398_O/S	23318	B	650	-1300	25033	LONG_MTN-PLSNTVLY 345_398	0			
SCH-NE-NY_ALI	23318	B	1300	-1500	0		0			
SCH-NE-NY_E205W+398_O/S	23318	B	500	-1000	25030	BEAR SWP-ROTTDRAM 230_E205W	25033	LONG_MTN-PLSNTVLY 345_398	0	
SCH-NPX_1385_2-AN_601_O/S	325277	B	100	-100	25217	N.SCTLND-ALPS 345_2-AN	325597	NRTH1385-NOR_HBR 138_601	0	
SCH-NPX_1385_2-AN_602_O/S	325277	B	100	-100	25217	N.SCTLND-ALPS 345_2-AN	325598	NRTH1385-NOR_HBR 138_602	0	
SCH-NPX_1385_2-AN_603_O/S	325277	B	100	-100	25217	N.SCTLND-ALPS 345_2-AN	325599	NRTH1385-NOR_HBR 138_603	0	
SCH-NPX_1385_2-AN_O/S	325277	B	200	-200	25217	N.SCTLND-ALPS 345_2-AN	0			
SCH-NPX_1385_312_601_O/S	325277	B	100	-100	25366	BERKSHIR-NORTHFLD 345_312	325597	NRTH1385-NOR_HBR 138_601	0	
SCH-NPX_1385_312_602_O/S	325277	B	100	-100	25366	BERKSHIR-NORTHFLD 345_312	325598	NRTH1385-NOR_HBR 138_602	0	
SCH-NPX_1385_312_603_O/S	325277	B	100	-100	25366	BERKSHIR-NORTHFLD 345_312	325599	NRTH1385-NOR_HBR 138_603	0	
SCH-NPX_1385_312_O/S	325277	B	200	-200	25366	BERKSHIR-NORTHFLD 345_312	0			
SCH-NPX_1385_329_601_O/S	325277	B	100	-100	25364	FROST_BR-SOUTHNGT 345_329	325597	NRTH1385-NOR_HBR 138_601	0	
SCH-NPX_1385_329_602_O/S	325277	B	100	-100	25364	FROST_BR-SOUTHNGT 345_329	325598	NRTH1385-NOR_HBR 138_602	0	
SCH-NPX_1385_329_603_O/S	325277	B	100	-100	25364	FROST_BR-SOUTHNGT 345_329	325599	NRTH1385-NOR_HBR 138_603	0	
SCH-NPX_1385_352_601_O/S	325277	B	100	-100	25363	FROST_BR-LONG_MTN 345_352	325597	NRTH1385-NOR_HBR 138_601	0	

Interface Name	PTID	Limit Change Flag	Forward Limit	Reverse Limit	Outage 1 PTID	Outage 1 Name	Outage 2 PTID	Outage 2 Name	Outage 3 PTID	Outage 3 Name
SCH-NPX 1385_352_602_O/S	325277	B	100	-100	25363	FROST_BR-LONG MTN 345_352	325598	FROST_BR-LONG MTN 345_352	0	
SCH-NPX 1385_352_603_O/S	325277	B	100	-100	25363	FROST_BR-LONG MTN 345_352	325599	FROST_BR-LONG MTN 345_352	0	
SCH-NPX 1385_393_601_O/S	325277	B	100	-100	25034	BERKSHIR-ALPS 345_393	325597	BERKSHIR-ALPS 345_393	0	
SCH-NPX 1385_393_602_O/S	325277	B	100	-100	25034	BERKSHIR-ALPS 345_393	325598	BERKSHIR-ALPS 345_393	0	
SCH-NPX 1385_393_603_O/S	325277	B	100	-100	25034	BERKSHIR-ALPS 345_393	325599	BERKSHIR-ALPS 345_393	0	
SCH-NPX 1385_398_601_O/S	325277	B	200	-200	25034	BERKSHIR-ALPS 345_398	0		0	
SCH-NPX 1385_398_601_O/S	325277	B	100	-100	25033	LONG_MTN-PLSNTVLY 345_398	325597	LONG_MTN-PLSNTVLY 345_398	0	
SCH-NPX 1385_398_602_O/S	325277	B	100	-100	25033	LONG_MTN-PLSNTVLY 345_398	325598	LONG_MTN-PLSNTVLY 345_398	0	
SCH-NPX 1385_398_603_O/S	325277	B	100	-100	25033	LONG_MTN-PLSNTVLY 345_398	325599	LONG_MTN-PLSNTVLY 345_398	0	
SCH-NPX 1385_398_O/S	325277	B	200	-200	25033	LONG_MTN-PLSNTVLY 345_398	0		0	
SCH-NPX 1385_601_602_O/S	325277	B	100	-100	325597	NRTH1385-NOR HBR 138_601	325598	NRTH1385-NOR HBR 138_601	0	
SCH-NPX 1385_601_603_O/S	325277	B	100	-100	325597	NRTH1385-NOR HBR 138_601	325599	NRTH1385-NOR HBR 138_601	0	
SCH-NPX 1385_601_O/S	325277	B	200	-200	325597	NRTH1385-NOR HBR 138_601	0		0	
SCH-NPX 1385_602_603_O/S	325277	B	100	-100	325598	NRTH1385-NOR HBR 138_602	325599	NRTH1385-NOR HBR 138_602	0	
SCH-NPX 1385_602_O/S	325277	B	200	-200	325598	NRTH1385-NOR HBR 138_602	0		0	
SCH-NPX 1385_603_O/S	325277	B	200	-200	325599	NRTH1385-NOR HBR 138_603	0		0	
SCH-NPX 1385_ALI	325277	B	300	-300	0		0		0	
SCH-PJM-NY 30_O/S	23316	B	2300	-2300	25018	HOMER_C -WATRCURE 345_30	0		0	
SCH-PJM-NY 31_O/S	23316	B	2500	-2450	25178	WATRCURE-OAKDALE 345_31	0		0	
SCH-PJM-NY 37_O/S	23316	B	2400	-2450	25036	HOMER_C -STOLLERD 345_37	0		0	
SCH-PJM-NY 5018_O/S	23316	B	1700	-1650	25019	BRANCHBG-RAMAPO 500_5018	0		0	
SCH-PJM-NY A2253_O/S	23316	B	2400	-2400	25017	LINDENP -GOETHALS 230_A2253	0		0	
SCH-PJM-NY A2253+B3402_O/S	23316	B	2300	-2300	25017	LINDENP -GOETHALS 230_A2253	25020	HUDSONP -FARRAGUT 345_B3402	0	
SCH-PJM-NY A2253+C3403_O/S	23316	B	2300	-2300	25017	LINDENP -GOETHALS 230_A2253	25038	HUDSONP -FARRAGUT 345_C3403	0	
SCH-PJM-NY ALI	23316	B	2750	-2450	0		0		0	
SCH-PJM-NY B3402_O/S	23316	B	2400	-2400	25020	HUDSONP -FARRAGUT 345_B3402	0		0	
SCH-PJM-NY B3402+C3403_O/S	23316	B	2300	-2300	25020	HUDSONP -FARRAGUT 345_B3402	25038	HUDSONP -FARRAGUT 345_C3403	0	
SCH-PJM-NY BP76+PA301_O/S	23316	B	1100	-1300	25024	BECK -PACKARD 230_BP76	25040	BECK -NIAGARA 345_PA301	0	
SCH-PJM-NY BP76+PA302_O/S	23316	B	1100	-1300	25024	BECK -PACKARD 230_BP76	25041	BECK -NIAGARA 345_PA302	0	
SCH-PJM-NY C3403_O/S	23316	B	2400	-2400	25038	HUDSONP -FARRAGUT 345_C3403	0		0	
SCH-PJM-NY PA301+PA302_O/S	23316	B	1100	-1300	25040	BECK -NIAGARA 345_PA301	25041	BECK -NIAGARA 345_PA302	0	
SCH-PJM-NY PAR3500_O/S	23316	B	2200	-2150	25370	RAMAPO 345_345_PAR3500	0		0	
SCH-PJM-NY PAR4500_O/S	23316	B	2200	-2150	25371	RAMAPO 345_345_PAR4500	0		0	
SCH-PJM-NY WATRCURE BK1_O/S	23316	B	2750	-2450	25402	WATRCURE 345_230_BK 1	0		0	
Sprain/Dunwd-South_ALI	23320	B	4600	-9999	0		0		0	
Sprain/Dunwd-South_REACTORS_A_I/	23320	B	4350	-9999	325295	ILCTLIMIT 345KV_DUNWOD_R71_REACTR	325296	ILCTLIMIT 345KV_DUNWOD_R72_REACTR	325297	ILCTLIMIT 345KV_SPRNBK_4S3_REACTR
Sprain/Dunwd-South_REACTORS_B_I/	23320	B	4350	-9999	325295	ILCTLIMIT 345KV_DUNWOD_R71_REACTR	325296	ILCTLIMIT 345KV_DUNWOD_R72_REACTR	325298	ILCTLIMIT 345KV_SPRNBK_5S3_REACTR
Sprain/Dunwd-South_REACTORS_C_I/	23320	B	4350	-9999	325295	ILCTLIMIT 345KV_DUNWOD_R71_REACTR	325297	ILCTLIMIT 345KV_SPRNBK_4S3_REACTR	325298	ILCTLIMIT 345KV_SPRNBK_5S3_REACTR
Sprain/Dunwd-South_REACTORS_D_I/	23320	B	4350	-9999	325296	ILCTLIMIT 345KV_DUNWOD_R72_REACTR	325297	ILCTLIMIT 345KV_SPRNBK_4S3_REACTR	325298	ILCTLIMIT 345KV_SPRNBK_5S3_REACTR
Tot-East_5018_O/S	23314	B	6400	-9999	25019	BRANCHBG-RAMAPO 500_5018	0		0	
Tot-East_5018+Fraser_SVC O/S	23314	B	6300	-9999	25019	BRANCHBG-RAMAPO 500_5018	31328	FRASER 345_FRASER SVC	0	
Tot-East_5018+Leeds_SVC O/S	23314	B	6300	-9999	25019	BRANCHBG-RAMAPO 500_5018	31327	LEEDS 345_LEEDS SVC	0	
Tot-East_ALI	23314	B	6500	-9999	0		0		0	
UPNY-CE 5018_O/S	23315	B	4000	-9999	25019	BRANCHBG-RAMAPO 500_5018	0		0	
UPNY-CE ALI	23315	B	5100	-9999	0		0		0	
UPNY-CE REACTORS A_I/S	23315	B	4850	-9999	325295	ILCTLIMIT 345KV_DUNWOD_R71_REACTR	325296	ILCTLIMIT 345KV_DUNWOD_R72_REACTR	325297	ILCTLIMIT 345KV_SPRNBK_4S3_REACTR
UPNY-CE REACTORS B_I/S	23315	B	4850	-9999	325295	ILCTLIMIT 345KV_DUNWOD_R71_REACTR	325296	ILCTLIMIT 345KV_DUNWOD_R72_REACTR	325298	ILCTLIMIT 345KV_SPRNBK_5S3_REACTR
UPNY-CE REACTORS C_I/S	23315	B	4850	-9999	325295	ILCTLIMIT 345KV_DUNWOD_R71_REACTR	325297	ILCTLIMIT 345KV_SPRNBK_4S3_REACTR	325298	ILCTLIMIT 345KV_SPRNBK_5S3_REACTR
UPNY-CE REACTORS D_I/S	23315	B	4850	-9999	325296	ILCTLIMIT 345KV_DUNWOD_R72_REACTR	325297	ILCTLIMIT 345KV_SPRNBK_4S3_REACTR	325298	ILCTLIMIT 345KV_SPRNBK_5S3_REACTR
UPNY-CE RFK-305_O/S	23315	B	4100	-9999	25108	ROSETON -EFISHKIL 345_305	0		0	
UPNY-CE Y88_O/S	23315	B	4150	-9999	25185	LADENTWN-BUCHAN_S 345_Y88	0		0	
UPNY-CE Y94_O/S	23315	B	4150	-9999	25184	RAMAPO -BUCHAN_N 345_Y94	0		0	
West-Cent ALI	23312	B	2250	-9999	0		0		0	
West-Cent_NR-2_O/S	23312	B	1750	-9999	25084	NIAGARA -ROCHESTR 345_NR2	0		0	
West-Cent_PC-1_O/S	23312	B	1300	-9999	25058	PANNELL -CLAY 345_PC1	0		0	
West-Cent_PC-2_O/S	23312	B	1300	-9999	25050	PANNELL -CLAY 345_PC2	0		0	
West-Cent_RP-1_O/S	23312	B	1900	-9999	25192	ROCHESTR-PANNELL 345_RP1	0		0	
West-Cent_RP-2_O/S	23312	B	1900	-9999	25172	ROCHESTR-PANNELL 345_RP2	0		0	
West-Cent_SR-1_O/S	23312	B	1700	-9999	25073	KINTIGH -ROCHESTR 345_SR-1	0		0	
WESTERN_EXP_ALI	23327	B	8100	-9999	0		0		0	
WESTERN_EXP_PA301_BP76	23327	B	1100	-9999	25024	BECK -PACKARD 230_BP76	25040	BECK -NIAGARA 345_PA301	0	
WESTERN_EXP_PA301_BP76_NR2	23327	B	700	-9999	25024	BECK -PACKARD 230_BP76	25040	BECK -NIAGARA 345_PA301	25084	NIAGARA -ROCHESTR 345_NR2
WESTERN_EXP_PA301_BP76_NS1-38	23327	B	700	-9999	25024	BECK -PACKARD 230_BP76	25040	BECK -NIAGARA 345_PA301	25074	NIAGARA -KINTIGH 345_NS1-38
WESTERN_EXP_PA301_BP76_PC1	23327	B	700	-9999	25024	BECK -PACKARD 230_BP76	25040	BECK -NIAGARA 345_PA301	25058	PANNELL -CLAY 345_PC1
WESTERN_EXP_PA301_BP76_PC2	23327	B	700	-9999	25024	BECK -PACKARD 230_BP76	25040	BECK -NIAGARA 345_PA301	25050	PANNELL -CLAY 345_PC2
WESTERN_EXP_PA301_BP76_RP1	23327	B	700	-9999	25024	BECK -PACKARD 230_BP76	25040	BECK -NIAGARA 345_PA301	25192	ROCHESTR-PANNELL 345_RP1
WESTERN_EXP_PA301_BP76_RP2	23327	B	700	-9999	25024	BECK -PACKARD 230_BP76	25040	BECK -NIAGARA 345_PA301	25172	ROCHESTR-PANNELL 345_RP2
WESTERN_EXP_PA301_BP76_SR1-39	23327	B	700	-9999	25024	BECK -PACKARD 230_BP76	25040	BECK -NIAGARA 345_PA301	25073	KINTIGH -ROCHESTR 345_SR-1
WESTERN_EXP_PA301_PA27_BP76	23327	B	1100	-9999	25024	BECK -PACKARD 230_BP76	25025	BECK -NIAGARA 230_PA27	25040	BECK -NIAGARA 345_PA301
WESTERN_EXP_PA301_PA27_NR2	23327	B	700	-9999	25025	BECK -NIAGARA 230_PA27	25040	BECK -NIAGARA 345_PA301	25084	NIAGARA -ROCHESTR 345_NR2
WESTERN_EXP_PA301_PA27_NS1-38	23327	B	700	-9999	25025	BECK -NIAGARA 230_PA27	25040	BECK -NIAGARA 345_PA301	25074	NIAGARA -KINTIGH 345_NS1-38
WESTERN_EXP_PA301_PA27_PC1	23327	B	700	-9999	25025	BECK -NIAGARA 230_PA27	25040	BECK -NIAGARA 345_PA301	25058	PANNELL -CLAY 345_PC1
WESTERN_EXP_PA301_PA27_PC2	23327	B	700	-9999	25025	BECK -NIAGARA 230_PA27	25040	BECK -NIAGARA 345_PA301	25050	PANNELL -CLAY 345_PC2
WESTERN_EXP_PA301_PA27_RP1	23327	B	700	-9999	25025	BECK -NIAGARA 230_PA27	25040	BECK -NIAGARA 345_PA301	25192	ROCHESTR-PANNELL 345_RP1
WESTERN_EXP_PA301_PA27_RP2	23327	B	700	-9999	25025	BECK -NIAGARA 230_PA27	25040	BECK -NIAGARA 345_PA301	25172	ROCHESTR-PANNELL 345_RP2

Interface Name	PTID	Limit Change Flag	Forward Limit	Reverse Limit	Outage 1 PTID	Outage 1		Outage 2		Outage 3		
						Name	PTID	Name	PTID	Name	PTID	
WESTERN_EXP_PA301_PA27_SR1-39	23327	B	700	-9999	25025	BECK	-NIAGARA_230_PA27	25040	BECK	-NIAGARA_345_PA301	25073	KINTIGH_-ROCHESTR_345_SR-1
WESTERN_EXP_PA301_PA302	23327	B	1100	-9999	25040	BECK	-NIAGARA_345_PA301	25041	BECK	-NIAGARA_345_PA302	0	
WESTERN_EXP_PA301_PA302_BP76	23327	B	700	-9999	25024	BECK	-PACKARD_230_BP76	25040	BECK	-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302
WESTERN_EXP_PA301_PA302_NR2	23327	B	700	-9999	25040	BECK	-NIAGARA_345_PA301	25041	BECK	-NIAGARA_345_PA302	25084	NIAGARA_-ROCHESTR_345_NR2
WESTERN_EXP_PA301_PA302_NS1-38	23327	B	700	-9999	25040	BECK	-NIAGARA_345_PA301	25041	BECK	-NIAGARA_345_PA302	25074	NIAGARA_-KINTIGH_345_NS1-38
WESTERN_EXP_PA301_PA302_PA27	23327	B	700	-9999	25025	BECK	-NIAGARA_230_PA27	25040	BECK	-NIAGARA_345_PA301	25041	BECK_-NIAGARA_345_PA302
WESTERN_EXP_PA301_PA302_PC1	23327	B	700	-9999	25040	BECK	-NIAGARA_345_PA301	25041	BECK	-NIAGARA_345_PA302	25058	PANNELL_-CLAY_345_PC1
WESTERN_EXP_PA301_PA302_PC2	23327	B	700	-9999	25040	BECK	-NIAGARA_345_PA301	25041	BECK	-NIAGARA_345_PA302	25050	PANNELL_-CLAY_345_PC2
WESTERN_EXP_PA301_PA302_RP1	23327	B	700	-9999	25040	BECK	-NIAGARA_345_PA301	25041	BECK	-NIAGARA_345_PA302	25192	ROCHESTR-PANNELL_345_RP1
WESTERN_EXP_PA301_PA302_RP2	23327	B	700	-9999	25040	BECK	-NIAGARA_345_PA301	25041	BECK	-NIAGARA_345_PA302	25172	ROCHESTR-PANNELL_345_RP2
WESTERN_EXP_PA301_PA302_SR1-39	23327	B	700	-9999	25040	BECK	-NIAGARA_345_PA301	25041	BECK	-NIAGARA_345_PA302	25073	KINTIGH_-ROCHESTR_345_SR-1
WESTERN_EXP_PA302_BP76	23327	B	1100	-9999	25024	BECK	-PACKARD_230_BP76	25041	BECK	-NIAGARA_345_PA302	0	
WESTERN_EXP_PA302_BP76_NR2	23327	B	700	-9999	25024	BECK	-PACKARD_230_BP76	25041	BECK	-NIAGARA_345_PA302	25084	NIAGARA_-ROCHESTR_345_NR2
WESTERN_EXP_PA302_BP76_NS1-38	23327	B	700	-9999	25024	BECK	-PACKARD_230_BP76	25041	BECK	-NIAGARA_345_PA302	25074	NIAGARA_-KINTIGH_345_NS1-38
WESTERN_EXP_PA302_BP76_PC1	23327	B	700	-9999	25024	BECK	-PACKARD_230_BP76	25041	BECK	-NIAGARA_345_PA302	25058	PANNELL_-CLAY_345_PC1
WESTERN_EXP_PA302_BP76_PC2	23327	B	700	-9999	25024	BECK	-PACKARD_230_BP76	25041	BECK	-NIAGARA_345_PA302	25050	PANNELL_-CLAY_345_PC2
WESTERN_EXP_PA302_BP76_RP1	23327	B	700	-9999	25024	BECK	-PACKARD_230_BP76	25041	BECK	-NIAGARA_345_PA302	25192	ROCHESTR-PANNELL_345_RP1
WESTERN_EXP_PA302_BP76_RP2	23327	B	700	-9999	25024	BECK	-PACKARD_230_BP76	25041	BECK	-NIAGARA_345_PA302	25172	ROCHESTR-PANNELL_345_RP2
WESTERN_EXP_PA302_BP76_SR1-39	23327	B	700	-9999	25024	BECK	-PACKARD_230_BP76	25041	BECK	-NIAGARA_345_PA302	25073	KINTIGH_-ROCHESTR_345_SR-1
WESTERN_EXP_PA302_PA27_BP76	23327	B	1100	-9999	25024	BECK	-PACKARD_230_BP76	25025	BECK	-NIAGARA_230_PA27	25041	BECK_-NIAGARA_345_PA302
WESTERN_EXP_PA302_PA27_NR2	23327	B	700	-9999	25025	BECK	-NIAGARA_230_PA27	25041	BECK	-NIAGARA_345_PA302	25084	NIAGARA_-ROCHESTR_345_NR2
WESTERN_EXP_PA302_PA27_NS1-38	23327	B	700	-9999	25025	BECK	-NIAGARA_230_PA27	25041	BECK	-NIAGARA_345_PA302	25074	NIAGARA_-KINTIGH_345_NS1-38
WESTERN_EXP_PA302_PA27_PC1	23327	B	700	-9999	25025	BECK	-NIAGARA_230_PA27	25041	BECK	-NIAGARA_345_PA302	25058	PANNELL_-CLAY_345_PC1
WESTERN_EXP_PA302_PA27_PC2	23327	B	700	-9999	25025	BECK	-NIAGARA_230_PA27	25041	BECK	-NIAGARA_345_PA302	25050	PANNELL_-CLAY_345_PC2
WESTERN_EXP_PA302_PA27_RP1	23327	B	700	-9999	25025	BECK	-NIAGARA_230_PA27	25041	BECK	-NIAGARA_345_PA302	25192	ROCHESTR-PANNELL_345_RP1
WESTERN_EXP_PA302_PA27_RP2	23327	B	700	-9999	25025	BECK	-NIAGARA_230_PA27	25041	BECK	-NIAGARA_345_PA302	25172	ROCHESTR-PANNELL_345_RP2
WESTERN_EXP_PA302_PA27_SR1-39	23327	B	700	-9999	25025	BECK	-NIAGARA_230_PA27	25041	BECK	-NIAGARA_345_PA302	25073	KINTIGH_-ROCHESTR_345_SR-1
WESTERN_EXP_PA301	23327	B	4600	-9999	25040	BECK	-NIAGARA_345_PA301	0			0	
WESTERN_EXP_PA302	23327	B	4600	-9999	25041	BECK	-NIAGARA_345_PA302	0			0	
WESTERN_EXP_PA27	23327	B	6350	-9999	25025	BECK	-NIAGARA_230_PA27	0			0	
WESTERN_EXP_BP76	23327	B	6350	-9999	25024	BECK	-PACKARD_230_BP76	0			0	
WESTERN_EXP_NR2	23327	B	7700	-9999	25084	NIAGARA	-ROCHESTR_345_NR2	0			0	
WESTERN_EXP_NS1-38	23327	B	7700	-9999	25074	NIAGARA	-KINTIGH_345_NS1-38	0			0	
WESTERN_EXP_PC1	23327	B	7700	-9999	25058	PANNELL	-CLAY_345_PC1	0			0	
WESTERN_EXP_PC2	23327	B	7700	-9999	25050	PANNELL	-CLAY_345_PC2	0			0	
WESTERN_EXP_RP1	23327	B	7700	-9999	25192	ROCHESTR-PANNELL	_345_RP1	0			0	
WESTERN_EXP_RP2	23327	B	7700	-9999	25172	ROCHESTR-PANNELL	_345_RP2	0			0	
WESTERN_EXP_SR-1	23327	B	7700	-9999	25073	KINTIGH	-ROCHESTR_345_SR-1	0			0	
WESTERN_EXP_NR2	23327	B	7700	-9999	25084	NIAGARA	-ROCHESTR_345_NR2	0			0	

Note: "ALI" Denotes "All Lines In Service"