

Analysis of HQ-NY Transfers above 1200MW

*NYISO Operations Engineering
August 20, 2001*

Operation of MSC-7040 above 1200MW



- **Scheduling limit raised to 1800MW on 6/00**
 - *Allow HQ-US to sell energy through NYCA to external parties*
- **Problems experienced in real-time:**
 - *Voltage problems in central-NY in real-time*
 - *Unable to meet the day-ahead schedules*
- **Limit reduced to 1500MW on 8/13/00**

NYISO Staff Analysis

- Compare results using three cases:
 - *Summer 1999 – July 6, 1999 review*
 - *Summer 2000 operating study case*
 - *Summer 2000 modified*
- Analyses with all cases assumes peak load and constant value of Central East flow

Results of previous analyses...

- Voltage vs. MSC-7040 flow
 - *Edic 345kV pre-contingency voltage below limit (347kV) when transfers increase above 1500MW*
 - *New Scotland voltage below limit (348kV) when transfers increase above 1500MW*



Conclusions...

1. *Quebec delivery above 1200MW at constant Central East the greater voltage impact is at Edic, limiting transfers to 1500MW.*
2. *The reactive load (power factor) is critical to the accurate representation and solution of the transmission system voltages.*
3. *The analysis underscores the importance of accurate generator representations and capabilities.*

Summer 2001 Analysis

- Operating Committee requested detailed analysis of HQ transfers for Summer 2001
- Study based on the Marcy FACTS Phase I (STATCOM) analysis completed 4/2001
- Evaluated sensitivity of the Central East Voltage Collapse transfer limits for higher transfer levels on MSC-7040

Results...

- **Impact on Central East MTLs**
 - *Increasing HQ-MS7040 flow from 1500MW to 1800MW reduces the MTLs approximately 75MW*
 - Impact on internal NYISO transfers would be a reduction of up to 150MW (Total East) based on the MTL reduction
 - *Resulting analysis assumes Central East flow is constant for increasing MS7040 flow*
 - Results are (therefore) optimistic

Recommendations...

- Maintaining or maximizing Central East transfer capability in real-time is best for all market participants
- NYISO continues to allow scheduling up to 1500MW on MS7040 in day-ahead.
- Scheduling above 1500MW in HAM may be possible if adequate reactive and flow margins exist in central NY voltages and Central East transfers