

Rules Assessment

MSWG 6/29/06

Bob Thompson

Proposals for Initial Items

- Initial items for consideration are:
 - 15 minute scheduling qualification restrictions
 - Penalty exemption for generator testing.
- NYISO proposal development sidelined for Min oil burn discussions.
- NYISO Proposals will be ready by next MSWG. MP-sponsored proposals also invited.
- Initial proposal on wind rules will also be discussed.

15 Minute Scheduling

- No units are currently on 15 minute dispatch
- One unit has requested to qualify
- Capacity that is not on 5 minute dispatch **and** is also capable of 15 minute response appears to be very limited.
- All but a few of the remaining units are run-of-river hydro, cogens, gas turbines, fixed diesel, or wind.

15 Minute Scheduling (cont)

- Currently researching units that may be qualified for flexible dispatch but are bidding fixed.

Generator Testing Exemption

- Nearly all (17) of the described (IPPNY Memo) tests have the following characteristics:
 - Fixed operating points for extended time periods
 - Can be scheduled in advance,
- Two tests are currently identified as initiated without notice.
 - One of these two tests will also require response to varying NYISO basepoints.

Next steps

- Complete proposals for the next MSWG
 - Gen test proposal will be limited to schedulable tests.
 - Un-noticed testing will require more time to evaluate.