

NYISO (JWC) suggests that this section be included in Section 4.4 Operating Data Reporting Requirements with a few more edits noted below

4.14 Temporary Interruption in Availability

4.14.1 Interruption at the Election of a Generator

If a Generator ~~elects to~~does not sell or certify it's UCAP~~interrupt operations at a unit~~ on a temporary basis (i.e. elects not to participate in the UCAP Market or is not successful in selling its UCAP at auction or in a bilateral transaction), ~~it must forego bidding the unit into the UCAP market for that period of time and it must notify the NYISO.~~ Such interruption in availability of UCAP shall be taken on a monthly basis and may~~shall~~ be treated for purposes of calculating the EFORD ~~rating~~ for that unit as a maintenance outage with prior notification of the NYISO. ~~provided however, that if~~ If the Generator elects to bid the unit into the NYISO energy markets during such period, all such service hours and forced outage hours shall be included in the computation of the unit's EFORD ~~rating~~, but periods where the unit is not selected may be reported as Reserve Shutdown Hours.

4.14.2 Interruption Resulting from a Transmission Outage

If an outage occurs on the transmission system beyond the generator step-up transformer at a time when a Generator has not placed its unit on a maintenance outage, such interruption in availability shall be treated for purposes of calculating the unit's EFORD rating as a reserve shutdown. ~~If an outage occurs on the transmission system beyond the generator step-up transformer at a time when a Generator is~~~~has already placed its unit~~ on a maintenance outage, such interruption in availability shall be treated for purposes of calculating the unit's EFORD rating as a maintenance outage. In the event that service resumes on the transmission system but the unit categorized as being on a reserve shutdown is not able to perform, the unit shall be charged with a forced outage from the time that the transmission outage ended until the time it resumes operations; provided however, that if the unit had been scheduled to take a maintenance outage during this time period, the unit ~~only~~ shall be charged with a ~~F~~forced ~~O~~utage until the scheduled start date of its maintenance outage at which time it will be charged with a maintenance outage until the end of its scheduled maintenance period~~such time that it resumes operations.~~