



# **AC Transmission Public Policy Transmission Planning Report**

**A Report by the  
New York Independent System Operator**

**DRAFT**  
April 25, 2018

# Table of Contents

<b>EXECUTIVE SUMMARY .....</b>	<b>5</b>
<b>1. THE PUBLIC POLICY TRANSMISSION PLANNING PROCESS .....</b>	<b>6</b>
1.1 Identification of a Public Policy Transmission Need .....	7
1.2 Solicitation for Proposed Solutions.....	7
1.3 Evaluation for Viability and Sufficiency.....	8
1.4 Evaluation for Selection as the More Efficient or Cost Effective Solution.....	8
1.5 Identifying a Cost Allocation Methodology for the Public Policy Transmission Need.....	9
<b>2. AC TRANSMISSION PUBLIC POLICY TRANSMISSION NEED .....</b>	<b>11</b>
2.1 Identification of AC Transmission Public Policy Transmission Need .....	11
2.2 Development of Solutions .....	15
2.3 Viability and Sufficiency Assessment.....	18
2.4 Confirmation of Need for Transmission.....	20
2.5 Local Transmission Plan Updates and PSC-Directed Upgrades.....	20
<b>3. EVALUATION FOR SELECTION OF THE MORE EFFICIENT OR COST EFFECTIVE SOLUTION.....</b>	<b>21</b>
3.1 Overview of Proposed Viable and Sufficient Solutions .....	21
3.1.1 <i>Segment A Projects</i> .....	21
T018: National Grid/Transco - NYES Segment A.....	21
T021: NextEra - Enterprise Line Segment A.....	22
T025: NAT/NYPA - Segment A + 765 kV.....	23
T026: NAT/NYPA - Segment A Base.....	24
T027: NAT/NYPA - Segment A Double-Circuit .....	25
T028: NAT/NYPA - Segment A Enhanced.....	26
T031: ITC - 16NYPP1-1A AC Transmission Segment A .....	27
3.1.2 <i>Segment B Projects</i> .....	28
T019: National Grid/Transco - NYES Segment B .....	28
T022: NextEra - Enterprise Line Segment B.....	29
T023: NextEra - Enterprise Line Segment B-Alt .....	30
T029: NAT/NYPA - Segment B Base.....	31
T030: NAT/NYPA - Segment B Enhanced.....	32
T032: ITC - 16NYPP1-1A AC Transmission Segment B .....	33
3.2 Overview of Evaluation Assumptions .....	33
3.2.1 <i>Transfer Limit Analysis</i> .....	34

3.2.1.1 Baseline Transfer Analysis .....	35
3.2.1.2 Viability and Sufficiency Assessment Transfer Analysis.....	36
3.2.2 Resource Adequacy Analysis .....	36
3.2.3 Production Cost Analysis .....	37
3.2.3.1 Baseline Analysis .....	37
3.2.3.2. Scenario Analysis .....	38
3.3 Evaluation Metrics.....	41
3.3.1 Capital Cost Estimate .....	43
3.3.2 Cost Per MW Ratio .....	46
3.3.3 Expandability.....	49
3.3.3.1 Physical Expandability .....	49
3.3.3.2 Electrical Expandability.....	53
3.3.4 Operability .....	55
3.3.4.1 Substation Configuration Assessment.....	55
3.3.4.2 Dispatch Flexibility.....	58
3.3.4.3 Benefits under Maintenance Conditions .....	58
3.3.5 Performance.....	60
3.3.6 Production Cost.....	62
3.3.7 ICAP Benefits .....	68
3.3.8 Property Rights and Routing .....	68
3.3.9 Potential Construction Delay .....	72
3.3.10 Potential Risks.....	73
3.4 Consequences for Other Regions.....	74
3.5 Impact on Wholesale Electricity Markets .....	74
3.6 Evaluation of Interaction with Local Transmission Owner Plans .....	75
<b>4. CONCLUSIONS AND RECOMMENDATIONS.....</b>	<b>76</b>
4.1 Summary of Project Evaluations .....	76
4.2 Ranking.....	76
4.3 Selection Recommendation .....	76
4.4 Next Steps .....	76
<b>APPENDICES.....</b>	<b>77</b>
Appendix A – Public Policy Transmission Planning Process Glossary .....	77
Appendix B – AC Transmission Public Policy Transmission Planning Need Viability and Sufficiency Assessment.....	77
Appendix C – Phase 2 Selection Assumptions .....	77

Appendix D – SECO Report ..... 77

Appendix E – Market Monitoring Unit Report ..... 77

Appendix F – AC Transmission Project Proposals detailed descriptions ..... 77

DRAFT

## Executive Summary

This draft report presents the preliminary results of the Public Policy Transmission Planning Process administered by the New York Independent System Operator (NYISO) for the AC Transmission Public Policy Transmission Need.

DRAFT

## 1. The Public Policy Transmission Planning Process

The Public Policy Transmission Planning Process (PPTPP) is the newest component of the NYISO's Comprehensive System Planning Process and considers transmission needs driven by Public Policy Requirements in the local and regional transmission planning processes. The Public Policy Transmission Planning Process was developed in consultation with NYISO stakeholders and the New York State Public Service Commission (PSC), and was approved by the Federal Energy Regulatory Commission (FERC) under Order No. 1000.<sup>1</sup> At its core, the Public Policy Transmission Planning Process provides for the NYISO's evaluation and selection of transmission solutions to satisfy a transmission need driven by Public Policy Requirements. The process was developed to encourage both incumbent and non-incumbent transmission developers to propose projects in response to an identified need.

The NYISO is responsible for administering the Public Policy Transmission Planning Process in accordance with Attachment Y to its Open Access Transmission Tariff (OATT). Consistent with its obligations to regulate and oversee the electric industry under New York State law, the PSC has the primary responsibility for the identification of transmission needs driven by Public Policy Requirements.

A Public Policy Transmission Planning Process cycle typically commences every two years following the posting of the draft Reliability Needs Assessment study results, and consists of four core steps—(1) the identification of a Public Policy Transmission Need, (2) developers proposing solutions to satisfy the identified Public Policy Transmission Need, (3) an evaluation of the viability and sufficiency of the proposed Public Policy Transmission Projects and Other Public Policy Projects, and (4) a comparative evaluation of the viable and sufficient projects for the NYISO Board of Directors to select the more efficient or cost effective Public Policy Transmission Project that satisfies the Public Policy Transmission Need, if the PSC confirms that there is a need for transmission. The selected Public Policy Transmission Project is eligible for cost allocation and cost recovery under the NYISO's tariffs.

---

<sup>1</sup> See *New York Indep. Sys. Operator, Inc.*, Order on Compliance Filing, 143 FERC ¶ 61,059 (April 18, 2013); *New York Indep. Sys. Operator, Inc.*, Order on Compliance Filing, 148 FERC ¶ 61,044 (July 17, 2014); *New York Indep. Sys. Operator, Inc.*, Order on Compliance Filing, 151 FERC ¶ 61,040 (April 16, 2015); *New York Indep. Sys. Operator, Inc.*, Order on Compliance Filing, 155 FERC ¶ 61,037 (April 18, 2016); *New York Indep. Sys. Operator, Inc.*, Order on Compliance Filing, 162 FERC ¶ 61,107 (February 15, 2018).

### **1.1 Identification of a Public Policy Transmission Need**

For each cycle of the Public Policy Transmission Planning Process, the NYISO begins the process by inviting stakeholders and interested parties to submit proposed transmission needs driven by Public Policy Requirements. A Public Policy Requirement includes an existing federal, state, or local law or regulation, or a new legal requirement that the PSC establishes after public notice and comment under New York State law.

Following the submission of proposals, the NYISO posts all submittals on its website and provides those submissions, including any proposal from the NYISO, to the PSC. The NYISO separately provides any submission that proposes the identification of transmission needs driven by Public Policy Requirements within the Long Island Transmission District to the Long Island Power Authority (LIPA). The PSC and LIPA, as applicable, consider the proposals in order to identify any Public Policy Transmission Needs, and the PSC determines whether the NYISO should solicit solutions to any of the identified needs.

### **1.2 Solicitation for Proposed Solutions**

After the PSC determines that a Public Policy Transmission Need or a transmission need solely within the Long Island Transmission District driven by a Public Policy Requirement should be evaluated and considered by the NYISO for selection and regional cost allocation, the NYISO solicits proposed solutions that Developers believe will satisfy the identified need. Developers are afforded 60 days to propose their solutions and are required to provide specific Developer qualification and project information as detailed in Attachment Y to the OATT, the Public Policy Transmission Planning Process Manual, and the NYISO's solicitation.

Under the Public Policy Transmission Planning Process, proposed solutions fall into two categories—(i) Public Policy Transmission Projects and (ii) Other Public Policy Projects. A Public Policy Transmission Project is a transmission project or a portfolio of transmission projects proposed by a qualified Developer to satisfy an identified Public Policy Transmission Need and for which the Developer seeks to be selected by the NYISO for purposes of allocating and recovering the project's costs under the NYISO OATT. An Other Public Policy Project is a non-transmission project (*i.e.*, generation or demand-side projects) or a portfolio of transmission and non-transmission projects proposed by a Developer to satisfy an identified Public Policy Transmission Need. The NYISO will determine whether an Other Public Policy Project is viable and sufficient to meet a Public Policy Transmission Need. However, an Other Public Policy Project is not entitled to

cost allocation and recovery under the NYISO OATT.

### **1.3 Evaluation for Viability and Sufficiency**

In the first phase of analyses, the NYISO evaluates each proposed solution to the Public Policy Transmission Need to determine whether it is viable and sufficient. The NYISO assesses all resources types on a comparable basis within the same general timeframe. Under the viability evaluation, the NYISO considers a Developer's qualification and the project information data to determine whether the project is technically practicable, whether there is the ability to obtain the necessary rights-of-way within the required timeframe, and whether the project could be completed within the required timeframe. Under the sufficiency evaluation, the NYISO evaluates the degree to which each proposed solution independently satisfied the Public Policy Transmission Need, including any specific criteria established by the PSC in its order identifying the need. After completing the viability and sufficiency evaluations, the NYISO presents the assessment to stakeholders, interested parties, and the PSC for review and comments.

Following the NYISO's presentation of the Viability and Sufficiency Assessment, the Public Policy Transmission Planning Process requires the PSC to review the assessment and issue an order. If the PSC concludes that there is no longer a transmission need driven by a Public Policy Requirement, the NYISO will not perform an evaluation, or make a selection of, a more efficient or cost-effective transmission solution for that planning cycle. If the PSC modifies the transmission need driven by a Public Policy Requirement, the NYISO will restart its Public Policy Transmission Planning Process as an out-of-cycle process. This out-of-cycle process begins with the NYISO's solicitation of Public Policy Transmission Projects to address the modified Public Policy Transmission Need. The NYISO evaluates the viability and sufficiency of the proposed Public Policy Transmission Projects. The NYISO then proceeds to evaluate the viable and sufficient Public Policy Transmission Projects for purposes of selecting the more efficient or cost-effective transmission solution to the modified Public Policy Transmission Need.

### **1.4 Evaluation for Selection as the More Efficient or Cost Effective Solution**

Once the PSC determines that there remains a transmission need driven by a Public Policy Requirement, the NYISO proceeds with the evaluation of the proposed Public Policy Transmission Projects. The NYISO only considers those Public Policy Transmission Projects that it determined to be viable and sufficient and that have provided the required notifications to proceed with the



evaluation for selection as the more efficient or cost effective solution to the identified need.

The NYISO's selection is based on the totality of its evaluation of the eligible projects using the pre-defined metrics set forth in Attachment Y of the OATT and others set by the PSC and/or in consultation with stakeholders. The NYISO uses the project information provided by the Developer at the start of the process, in addition to any other information available to the NYISO. In performing its evaluation, the NYISO, or an independent consultant, reviews the reasonableness and comprehensiveness of the information submitted by the Developer for each project that is eligible for selection to be measured against the specific evaluation metrics (*see* Section 3.2, below).

In determining which of the eligible proposed regulated Public Policy Transmission Projects is the more efficient or cost effective solution to satisfy the Public Policy Transmission Need, the NYISO considers each project's total performance under all of the selection metrics. The NYISO may develop scenarios that modify certain assumptions to evaluate the proposed Public Policy Transmission Projects under differing system conditions. The NYISO considers and ranks each proposed solution based on its performance under the metrics. Based upon its evaluation of each viable and sufficient Public Policy Transmission Project, the NYISO staff recommends in the draft Public Policy Transmission Planning Report what project is the more efficient or cost effective solution to satisfy the Public Policy Transmission Need, if any. After the draft report is reviewed through the collaborative governance process and by the Market Monitoring Unit, the NYISO Board of Directors may approve the report, including whether to select a Public Policy Transmission Project, or propose modifications.

### **1.5 Identifying a Cost Allocation Methodology for the Public Policy Transmission Need**

Under the Public Policy Transmission Planning Process and consistent with FERC's directives under Order No. 1000, a regulated transmission project that is selected as the more efficient or cost-effective solution to satisfy an identified Public Policy Transmission Need will be eligible to receive cost allocation and recovery under the OATT. The Public Policy Transmission Planning Process contains an approved load ratio share cost allocation methodology, and a multi-step process for identifying any alternative methodology. This process was designed to provide flexibility in prescribing a methodology that would allocate the costs of a selected Public Policy Transmission Project consistent with the Public Policy Requirement driving the identified transmission need and roughly commensurate with the derived benefits. In allocating the costs of the selected Public Policy Transmission Project, the NYISO will use the default methodology under

Attachment Y to the OATT or an alternative methodology proposed in this process and accepted by FERC. The cost allocation methodology eventually accepted by the Commission has no bearing on the NYISO's selection of the more efficient or cost-effective transmission project to meet the Public Policy Transmission Need.

DRAFT

## 2. AC Transmission Public Policy Transmission Need

### 2.1 Identification of AC Transmission Public Policy Transmission Need

The NYISO issued a letter on August 1, 2014, inviting stakeholders and interested parties to submit proposed transmission needs driven by Public Policy Requirements to the NYISO on or before September 30, 2014.<sup>2</sup> On October 3, 2014, the NYISO filed the proposed needs for consideration with the PSC.<sup>3</sup> These proposed needs had two common and recurring themes: (i) increase transfer capability between upstate and downstate, and (ii) mitigate transmission constraints in Western New York to facilitate full output from the Niagara hydroelectric power plant and imports from Ontario. The PSC issued notices soliciting public comments on the proposed needs on November 12, 2014, and numerous parties submitted comments.<sup>4</sup>

Prior to the NYISO's solicitation of proposed transmission needs driven by Public Policy Requirements, the PSC initiated the Alternating Current Transmission Upgrades proceedings to consider whether to address the persistent transmission congestion that exists at the Central East and Upstate New York/Southeast New York (UPNY/SENY) electrical interfaces on the New York State Transmission System.<sup>5</sup> In those proceedings, the PSC sought and received in January 2013 numerous proposed projects to address the PSC's public policy objective with the intent of increasing transfer capability by approximately 1,000 MW based upon the recommendation of the Governor's Energy Highway Task Force. In response to the 2014 State of the State Address encouraging utilities and transmission developer to build solely within existing rights-of-way corridors, the PSC afforded the opportunity for revisions to the proposals, and four entities

---

<sup>2</sup> The NYISO's letter can be obtained at the following link: [http://www.nyiso.com/public/markets/operations/services/planning/planning\\_studies/index.jsp](http://www.nyiso.com/public/markets/operations/services/planning/planning_studies/index.jsp).

<sup>3</sup> The proposed needs and the NYISO's submission of the needs can be obtained at the following link: <http://documents.dps.ny.gov/public/MatterManagement/CaseMaster.aspx?MatterCaseNo=14-E-0454&submit=Search>.

<sup>4</sup> The notices seeking comments were issued under PSC Case Nos. 12-T-0502, *et al.*, and PSC Case No. 14-E-0454, and the comments can be obtained from the Department of Public Service website: <http://www.dps.ny.gov/>.

<sup>5</sup> The UPNY/SENY interface represents a collection of transmission on which power flows from upstate New York to southeast New York, and is comprised of: two 345 kV lines from Utica to south of the Catskills (commonly known as "Marcy South"); three 345 kV lines from Athens to Kingston and Pleasant Valley, in addition to underlying 115 kV lines (commonly known as "Leeds South"); and one 345 kV line from Connecticut to Pleasant Valley (commonly known as "Pleasant Valley-Long Mountain").

proposed 22 revised proposals.

Following the PSC's receipt and review of comments in response to the NYISO's invitation for proposed transmission needs driven by Public Policy Requirements, the PSC continued its efforts in the Alternating Current Transmission Upgrades comparative proceedings and sought to coordinate its comparative evaluation of proposed projects with the NYISO's Public Policy Transmission Planning Process. During the period in which the PSC was considering comments, the PSC requested that the NYISO perform analysis of the 22 proposed projects proposed in the PSC's proceedings. On July 6, 2015, DPS posted the Trial Staff Interim Report with the initial results of the NYISO's evaluation, and the NYISO, on July 20, 2015, presented the initial results at a technical conference hosted by New York State Department of Public Service (DPS) in the Alternating Current Transmission Upgrades proceedings.

Thereafter, due to public information that the CPV Valley Energy Center—a 680 MW generation facility that would interconnect to the New York State Transmission System at Dolson Avenue Substation—received its financing and would commence construction, DPS requested the NYISO to update its analysis to consider the effects of the CPV Valley Energy Center. On September 22, 2015, DPS issued its Trial Staff Final Report, containing the results of the NYISO's analysis, and a companion motion recommending that the Commission find that there is a transmission need driven by Public Policy Requirements to move power from upstate to downstate over the Central East and UPNY/SENY interfaces.

Following presentation of the Trial Staff Final Report at a technical conference in October 2015, the PSC issued an order, on December 17, 2015, identifying numerous public policies<sup>6</sup> that,

---

<sup>6</sup> The PSC identified that, as it relates to the AC Transmission Need, it is the public policy of the state to: reduce transmission congestion so that large amounts of power can be transmitted to regions of New York where it is most needed; to reduce production costs through congestion relief; reduce capacity resource costs; to improve market competition and liquidity; to enhance system reliability, flexibility, and efficiency; to improve preparedness for and mitigation of impacts of generator retirements; enhance resiliency/storm hardening; to avoid refurbishment costs of aging transmission; to take better advantage of existing fuel diversity; to increase diversity in supply, including additional renewable resources; to promote job growth and the development of new efficient generation resources Upstate; to reduce environmental and health impacts through reductions in less efficient electric generation; to reduce costs of meeting renewable resource standards; to increase tax receipts from increased infrastructure investment; to enhance planning and operational flexibility; to obtain synergies with other future transmission projects; and to relieve gas transportation constraints. December 2015 Order at pp 66-67. In addition the Commission found that the 2015 State Energy Plan (containing the New York's Energy Highway Blueprint), Section 6-104(1) of the New York Energy Law that requires the State Energy Planning Board to adopt a State Energy Plan, and Section 6-104(5)(b) of the New York Energy Law constitute Public Policy Requirements. *See id.* at pp 67-68.

taken together, constitute Public Policy Requirements driving transmission needs associated with the Central East and UPNY/SENY interfaces on the New York State Transmission System (collectively, “AC Transmission Need”).<sup>7</sup> The PSC distinguished the transmission need based on each affected system—*i.e.*, Central East (Segment A) and UPNY/SENY (Segment B), and described the transmission needs on the two segments as follows:

#### **SEGMENT A**

##### Edic/Marcy to New Scotland; Princetown to Rotterdam

Construction of a new 345 kV line from Edic or Marcy to New Scotland on existing right-of-way (primarily using Edic to Rotterdam right-of-way west of Princetown); construction of two new 345 kV lines or two new 230 kV lines from Princetown to Rotterdam on existing Edic to Rotterdam right-of-way; decommissioning of two 230 kV lines from Edic to Rotterdam; and related switching or substation work at Edic or Marcy, Princetown, Rotterdam and New Scotland.

#### **SEGMENT B**

##### Knickerbocker to Pleasant Valley

Construction of a new double circuit 345 kV/115 kV line from Knickerbocker to Churchtown on existing Greenbush to Pleasant Valley right-of-way; construction of a new double circuit 345 kV/115 kV line or triple circuit 345 kV/115 kV/115 kV line from Churchtown to Pleasant Valley on existing Greenbush to Pleasant Valley right-of-way; decommissioning of a double-circuit 115 kV line from Knickerbocker to Churchtown; decommissioning of one or two double-circuit 115 kV lines from Knickerbocker to Pleasant Valley; construction of a new tap of the New Scotland-Alps 345 kV line and new Knickerbocker switching station; and related switching or substation work at Greenbush, Knickerbocker, Churchtown and Pleasant Valley substations.

##### Upgrades to the Rock Tavern Substation Terminal Equipment

New line traps, relays, potential transformer upgrades, switch upgrades, system control upgrades and the installation of data acquisition measuring equipment and control wire needed to handle higher line currents that will result as a consequence of the new Edic/Marcy to New Scotland; Princetown to Rotterdam and Knickerbocker to Pleasant Valley lines.


---

<sup>7</sup> See December 2015 Order, at p 68 & Appendix A.

### Shoemaker to Sugarloaf

Construction of a new double circuit 138 kV line from Shoemaker to Sugarloaf on existing Shoemaker to Sugarloaf right-of-way; decommissioning of a double circuit 69 kV line from Shoemaker to Sugarloaf; related switching or substation work at Shoemaker, Hartley, South Goshen, Chester, and Sugarloaf.<sup>8</sup>

**Figure 2-1: AC Transmission Public Policy Transmission Need**



<sup>8</sup> December 2015 Order, at Appendix A. With respect to the upgrades to the Rock Tavern substation terminal equipment and the Shoemaker-Sugarloaf facilities, the PSC stated that “all developers should include the upgrade costs in their bids at the same level, and the upgrade costs should not be used as a distinguishing factor between bids.” *Id.* at p 62.



The PSC referred the AC Transmission Need to the NYISO for solicitation and evaluation of proposed solutions under the NYISO's Public Policy Transmission Planning Process for potential selection in the regional transmission plan for purposes of cost allocation under the OATT. The PSC also prescribed specific evaluation criteria in Appendix B of the December Order, which are set forth in Appendix C of this report, for the NYISO to consider, to the extent feasible, in its evaluation and selection process.

In addition, the PSC identified that the cost allocation methodology for the AC Transmission need would be based on a "beneficiaries pay" approach that would allocate the 75 percent of the project costs to economic beneficiaries of reduced congestion and the remaining 25 percent of the project costs across the state based upon load-ratio share.<sup>9</sup> The PSC noted that this methodology will allocate approximately 90 percent of the transmission project's cost to ratepayers in the downstate region. The PSC requested the NYISO to apply its expertise and design a more granular cost allocation among downstate entities consistent with the prescribed methodology.

## 2.2 Development of Solutions

The NYISO made a presentation at a combined meeting of the Transmission Planning Advisory Subcommittee (TPAS) and Electric System Planning Working Group (ESPWG) on February 5, 2016 to review the PSC's December 2015 Order and the nature of the resulting AC Transmission Need.<sup>10</sup> The NYISO then established sufficiency criteria in accordance with the criteria set by the PSC in its December 2015 Order, and made available baseline models and associated Power flow results to aid interested parties in developing project proposals.<sup>11</sup> The PSC specifically prescribed in its December 2015 Order that, in order for a proposed Public Policy Transmission Project or Other Public Policy Project to be considered sufficient by the NYISO, it must satisfy, at a minimum, the

---

<sup>9</sup> *Id.* at p 69 & Appendix D.

<sup>10</sup> The NYISO presentation is posted on its website under meeting materials at the following link: [http://www.nyiso.com/public/webdocs/markets\\_operations/committees/bic\\_espwg/meeting\\_materials/2016-02-05/03\\_AC%20Transmission\\_PPTN.pdf](http://www.nyiso.com/public/webdocs/markets_operations/committees/bic_espwg/meeting_materials/2016-02-05/03_AC%20Transmission_PPTN.pdf).

<sup>11</sup> The baseline study cases for the AC Transmission Need were the same system representation used by the NYISO to perform the evaluation directed by DPS for the Trial Staff Final Report in the Alternating Current Transmission Upgrades proceedings. The baseline study cases were available to all developers, subject to satisfactorily completing a Critical Energy Infrastructure Information (CEII) request, and the base line results are publicly available on the NYISO website at: [http://www.nyiso.com/public/markets\\_operations/services/planning/planning\\_studies/index.jsp](http://www.nyiso.com/public/markets_operations/services/planning/planning_studies/index.jsp)

following criteria:

- Proposed solutions to Segment A (Central East) must provide at least a 350 MW increase to the Central East interface transfer capability in accordance with Normal Transfer Criteria as defined by the New York State Reliability Council (NYSRC) Reliability Rules.
- Proposed solutions to Segment B (UPNY/SENY) must provide at least a 900 MW increase to the UPNY/SENY interface transfer capability in accordance with Normal Transfer Criteria as defined by the NYSRC Reliability Rules.

Additionally, a sufficient Public Policy Transmission Project must meet the following criteria, as set forth by the December 2015 Order:

- Proposed solutions to Segment A (Central East) must include all project components included in Segment A, as described in the December 2015 Order.
- Proposed solutions to Segment B (UPNY/SENY) must include all project components included in Segment B, as described in the December 2015 Order.
- No acquisition of new permanent transmission rights-of-way, except for *de minimis* acquisitions that cannot be avoided due to unique circumstances; however, the transfer or lease of existing transmission right-of-way property or access rights from a current utility company owner to a Developer shall not be considered such an acquisition.
- No crossing of the Hudson River, either overhead, underwater, in riverbed, or underground, or in any other way by any component of the transmission facility.
- For those Public Policy Transmission Projects that were also evaluated in the Alternating Current Transmission Upgrades proceedings, the December 2015 Order required that the cost estimate must not exceed the level estimated by the Trial Staff for the project, unless the developer can demonstrate that upward estimates are necessary to correct errors or omissions made by Trial Staff for the components that were added or adjusted by Trial Staff.

For each proposed Public Policy Transmission Project, the PSC required the sponsoring developer to submit at least two project cost estimates. The first cost estimate required the



developer to presume that “all prudently incurred costs will be recovered and there will be no sharing of cost overruns.”<sup>12</sup> The second cost estimate was required to reflect an 80/20 incentive regime, where if there are actual cost overruns, “the developer shall bear 20% of the cost over-runs, while ratepayers shall bear 80% of those costs[, but if] actual costs come in below a bid, then the developer should retain 20% of the savings,” provided that the developer would not seek incentives from FERC above the base return-on-equity otherwise approved.<sup>13</sup>

On February 29, 2016, the NYISO issued a solicitation for proposed solutions of all types (transmission, generation, and demand side) to the AC Transmission Need. Following the issuance of the solicitation, the NYISO received numerous questions from interested developers seeking clarification on the process and the AC Transmission Need. The NYISO issued a public Frequently Asked Questions (FAQ) document on March 30, 2016, and updated it on April 13, 2016, summarizing the questions and providing responses.<sup>14</sup>

As a result of the solicitation, the NYISO received a total of 16 proposals consisting of both Public Policy Transmission Projects and an Other Public Policy Project. The list of the proposed projects submitted to the NYISO and considered in the Viability and Sufficiency Assessment are included in Table 2-1, below.

**Table 2-1: Proposed Projects**

Developer	Project Name	Project ID	Category	Type	Location (County/State)
National Grid/Transco	New York Energy Solution Segment A	T018	PPTP	AC	Segment A
National Grid/Transco	New York Energy Solution Segment A	T019	PPTP	AC	Segment B
NextEra Energy Transmission New York	Enterprise Line: Segment A	T021	PPTP	AC	Segment A
NextEra Energy Transmission New York	Enterprise Line: Segment B	T022	PPTP	AC	Segment B
NextEra Energy Transmission New York	Enterprise Line: Segment B-Alt	T023	PPTP	AC	Segment B
North America Transmission / NYPA	Segment A + 765 kV	T025	PPTP	AC	Segment A

<sup>12</sup> See December 2015 Order, at Appendix C.

<sup>13</sup> See *id.*

<sup>14</sup> The AC Transmission Public Policy Transmission Need FAQ document is available at: [http://www.nyiso.com/public/webdocs/markets\\_operations/services/planning/Planning\\_Studies/Public\\_Policy\\_Documents/AC\\_Transmission\\_PPTN/AC-Transmission\\_PPTN\\_FAQ\\_2016-04-13.pdf](http://www.nyiso.com/public/webdocs/markets_operations/services/planning/Planning_Studies/Public_Policy_Documents/AC_Transmission_PPTN/AC-Transmission_PPTN_FAQ_2016-04-13.pdf).

North America Transmission / NYPA	Segment A Base	T026	PPTP	AC	Segment A
North America Transmission / NYPA	Segment A Double Circuit	T027	PPTP	AC	Segment A
North America Transmission / NYPA	Segment A Enhanced	T028	PPTP	AC	Segment A
North America Transmission / NYPA	Segment B Base	T029	PPTP	AC	Segment B
North America Transmission / NYPA	Segment B Enhanced	T030	PPTP	AC	Segment B
ITC New York Development	16NYPP1-1A AC Transmission	T031	PPTP	AC	Segment A
ITC New York Development	16NYPP1-1B AC Transmission	T032	PPTP	AC	Segment B
AvanGrid	Connect New York Recommended	T033	PPTP	HVDC	Segments A and B
AvanGrid	Connect New York Alternative	T034	PPTP	HVDC	Segments A and B
GlidePath	Distributed Generation Portfolio	OPP004	OPPP	Gen	Orange, Ulster, Putnam, Greene, NY
PPTP = Public Policy Transmission Project OPPP = Other Public Policy Project		Gen = Generation AC = Alternating Current Transmission HVDC = High-Voltage Direct Current Transmission			

### 2.3 Viability and Sufficiency Assessment

Through the second and third quarters of 2016, the NYISO assessed the viability and sufficiency of all proposed projects. In conducting its viability and sufficient assessment, the NYISO performed a comparable transfer limit analysis of each project in the same manner as the baseline analysis.<sup>15</sup> Consistent with the PSC’s direction that Segment A proposals depend on a Segment B proposal being in place, the NYISO combined each Segment A proposal with each developer’s Segment B counterpart proposal. If there was at least one combined case that increased the Central East transfer limit by at least 350 MW, the Segment A proposal met the Central East sufficiency criterion.

The NYISO presented a draft AC Transmission Public Policy Transmission Need Viability and Sufficiency Assessment to stakeholders at the joint ESPWG/TPAS on September 26, 2016. After receiving and addressing comments from stakeholders, the NYISO posted on its website the final Viability and Sufficiency Assessment report on October 27, 2016 and filed the same at the PSC in

<sup>15</sup> On July 29, 2016, the NYISO notified stakeholders and interested parties that although it had acted diligently in administering the current process, it would extend the 2014 cycle of the Public Policy Transmission Planning Process beyond two years as permitted by the OATT. See OATT Section 31.4.1.

Case No. 14-E-0454 and the Alternative Current Transmission Upgrades proceedings on October 28, 2016.<sup>16</sup> The assessment is included in this report as Appendix B.<sup>17</sup>

In the AC Transmission Public Policy Transmission Need Viability and Sufficiency Assessment, the NYISO determined the following projects are viable and sufficient to satisfy the AC Transmission Need:

- T018: National Grid / Transco – New York Energy Solution Segment A
- T019: National Grid / Transco – New York Energy Solution Segment B
- T021: NextEra Energy Transmission New York – Enterprise Line: Segment A
- T022: NextEra Energy Transmission New York – Enterprise Line: Segment B
- T023: NextEra Energy Transmission New York – Enterprise Line: Segment B Alt.
- T025: North America Transmission / NYPA – Segment A + 765 kV
- T026: North America Transmission / NYPA – Segment A Base
- T027: North America Transmission / NYPA – Segment A Double Circuit
- T028: North America Transmission / NYPA – Segment A Enhanced
- T029: North America Transmission / NYPA – Segment B Base
- T030: North America Transmission / NYPA – Segment B Enhanced
- T031: ITC New York Development – 16NYPP1-1A AC Transmission
- T032: ITC New York Development – 16NYPP1-1B AC Transmission

Together with the AC Transmission Public Policy Transmission Need Viability and Sufficiency Assessment, the NYISO filed a more granular cost allocation methodology consistent with the prescribed methodology set forth in the December 2015 Order for the PSC’s consideration.

---

<sup>16</sup> The NYISO’s filing can be obtained at the following link: <http://documents.dps.ny.gov/public/MatterManagement/CaseMaster.aspx?MatterCaseNo=12-t-0502&submit=Search+by+Case+Number>.

<sup>17</sup> The NYISO’s “AC Transmission Public Policy Transmission Need Viability and Sufficiency Assessment” can be obtained at the following link: [http://www.nyiso.com/public/markets\\_operations/services/planning/planning\\_studies/index.jsp](http://www.nyiso.com/public/markets_operations/services/planning/planning_studies/index.jsp).

## 2.4 Confirmation of Need for Transmission

On January 24, 2017, following consideration of public comments, the PSC issued an order confirming the AC Transmission Need.<sup>18</sup> The January 2017 Order stated that “[t]he Commission agrees that persistent congestion on the Central East and UPNY/SENY interfaces continues to contribute to higher energy costs for downstate customers and to limit the accessibility of renewable resources located upstate,” and that the Clean Energy Standard (CES) “further heightens the public policy need for transmission constraint relief and cross-state power flows” allowing renewable resources to be delivered to downstate load centers.<sup>19</sup> Based on the “various economic and public policy benefits,” the PSC directed the NYISO to proceed with its evaluation and selection of the proposed transmission solutions deemed viable and sufficient solution that will satisfy the AC Transmission Need.

The January 2017 Order also adopted the NYISO’s analysis of the recommended cost allocation methodology that the PSC identified as a part of the AC Transmission Public Policy Requirement/Public Policy Transmission Need in its December 2015 Order.<sup>20</sup> In response to the PSC’s adoption of the NYISO’s recommended cost allocation methodology, the NYISO filed, and the FERC accepted, the AC Transmission Cost Allocation methodology.<sup>21</sup>

## 2.5 Local Transmission Plan Updates and PSC-Directed Upgrades

The PSC, in its December 2015 Order, ordered Orange and Rockland Utilities, Inc. (O&R) and Central Hudson Gas and Electric Corporation (Central Hudson) respectively to upgrade the Shoemaker to Sugarloaf 138 kV facilities and the terminal upgrades at Rock Tavern 345 kV Substation, as part of Segment B project proposals. In its order confirming the AC Transmission Need, the PSC determined that the costs of the additional Segment B upgrades should not be a

---

<sup>18</sup> PSC Case No. 12-T-0502, *et al.*, *Proceeding on Motion of the Commission to Examine Alternating Current Transmission Upgrades*, Order Addressing Public Policy Transmission Need for AC Transmission Upgrades (January 24, 2017) (“January 2017 Order”).

<sup>19</sup> *Id.* at pp 18-19.

<sup>20</sup> *Id.* at p 21. The Commission also reiterated the appropriateness of certain incentives to ensure accurate cost estimates, and encouraged developers to pursue the cost-containment incentives before the Federal Energy Regulatory Commission (FERC) in their rates. *See id.*

<sup>21</sup> *See New York Indep. Sys. Operator, Inc.*, 161 FERC ¶ 61,160 (November 16, 2017). The AC Transmission Cost Allocation methodology is contained in Section 31.8 of Attachment Y to the OATT.

distinguishing factor among project proposals. Accordingly, the NYISO did not include, for each Segment B project, the cost for the additional upgrades for the purpose of evaluation and selection.

### 3. Evaluation for Selection of the More Efficient or Cost Effective Solution

Upon issuance of the January 2017 Order confirming the need for transmission, the NYISO commenced a detailed evaluation of each viable and sufficient transmission proposal with the assistance of its independent consultant, Substation Engineering Company (SECO). This section of the report details the NYISO's evaluation and the results.

#### 3.1 Overview of Proposed Viable and Sufficient Solutions

The NYISO determined that 13 transmission solutions are viable and sufficient. All proposed projects utilize the existing rights-of-way as required by the PSC order. The locations of the proposed projects are shown in Figure 2-1. A brief description of each of the 13 viable and sufficient projects is provided below, while a detailed description is provided in Appendix G of this study report.

##### 3.1.1 Segment A Projects

###### T018: National Grid/Transco - NYES Segment A

National Grid/Transco's NYES Segment A Proposal includes the following components:


- A new 345 kV line of approximately 87 miles from the existing Edic 345 kV substation to the existing New Scotland 345 kV substation. The New Scotland 345kV Substation will be upgraded and expanded
- Two new 345 kV lines of approximately 5 miles single-circuit looping the existing 345 kV Edic to New Scotland #14 line into and out of a new Rotterdam 345 kV Substation. The

Rotterdam 230 kV substation will be retired

- Two new 345/115 kV autotransformers connecting the existing Rotterdam 115 kV switchyard to the new 345 kV switchyard
- One new 345/230 kV autotransformer connecting the existing 230 kV Rotterdam to Eastover Road #38 line to the new Rotterdam 345 kV switchyard
- One new 135 MVAR capacitor bank connected to the new Rotterdam 345 kV switchyard
- Decommission of the Porter to Rotterdam 230 kV lines #30 and #31

Figure 3-1 shows the one-line diagram of T018 (together with components of T019).

**Figure 3-1: One-Line Diagram of T018+T019**



**T021: NextEra - Enterprise Line Segment A**


NextEra’s Enterprise Segment A Proposal includes the following components:

- A new 345 kV line of approximately 86 miles (83.4 miles 345 kV line and 2.6 miles double circuit 345/115 kV line) from the existing Edic 345 kV substation to the existing New Scotland 345 kV substation
- Rebuild 2.6 miles of existing Rotterdam-New Scotland 115 kV line circuit #13
- A new breaker-and-a-half 345/230 kV Princetown Substation, located near the existing Rotterdam 230 kV substation. The substation will include two 345/230 kV autotransformers
- Two new 345 kV circuits each approximately 4 miles in length to loop the existing Marcy –

New Scotland 345 kV circuit #18 into Princetown 345/230 kV substation

- Two new 1 mile 230 kV lines from Princetown-Rotterdam
- Decommission of the Porter to Rotterdam 230 kV lines #30 and #31

Figure 3-2 shows the one-line diagram of T021 (together with components of T022/T023).



**T025: NAT/NYPA - Segment A + 765 kV**

The NAT/NYPA Segment A +765 kV Proposal consists of the following components:

- A new 345 kV line of approximately 86 miles from the existing Edic 345 kV substation to the existing New Scotland 345 kV substation
- Two new 345 kV lines of approximately 5 miles single-circuit looping the existing 345 kV Edic to New Scotland #14 line into and out of a new Rotterdam 345 kV Substation. The Rotterdam 230 kV substation will be retired
- Two new 345/115 kV lower impedance transformers connecting the existing Rotterdam 115 kV switchyard to the new 345 kV switchyard. One new 345/230 kV transformer connecting the existing 230 kV Rotterdam to Eastover Road #38 line to the new Rotterdam 345 kV switchyard
- A new Princetown 345kV switchyard by tapping the newly proposed Edic-New Scotland




lines and Rotterdam-New Scotland transmission lines

- Convert the Marcy – New Scotland and New Scotland – Knickerbocker 345 kV transmission lines to 765 kV operation as Marcy – Knickerbocker 765 kV (with no connection at New Scotland)
- Switching station or substation work at Knickerbocker with two new 2000 MVA 765/345 kV transformers at Knickerbocker
- Terminal upgrades at Edic and Marcy 345 kV substations
- Decommission of the Porter to Rotterdam 230 kV lines #30 and #31

Figure 3-3 shows the one-line diagram of T025 (together with components of T029/T030).

**Figure 3-3: One-Line Diagram of T025+T029/T030**



T026: NAT/NYPA - Segment A Base

NAT/NYPA Segment A Base Proposal consists of the following components:

- A new 345 kV line of approximately 86 miles from the existing Edic 345 kV substation to the existing New Scotland 345 kV substation
- Two new 345 kV lines of approximately 5 miles single-circuit looping the existing 345 kV Edic to New Scotland #14 line into and out of a new Rotterdam 345 kV Substation. The




Rotterdam 230 kV substation will be retired

- Two new 345/115 kV transformers connecting the existing Rotterdam 115 kV switchyard to the new 345 kV switchyard. One new 345/230 kV transformer connecting the existing 230 kV Rotterdam to Eastover Road #38 line to the new Rotterdam 345 kV switchyard
- Terminal upgrades at Edic and Marcy 345kV substations
- Decommission of the Porter to Rotterdam 230 kV lines #30 and #31

Figure 3-4 shows the one line diagram of T026 (together with components of T029/T030).

**Figure 3-4: One-Line Diagram of T026+T029/T030**



T027: NAT/NYPA - Segment A Double-Circuit


NAT/NYPA Segment A Double Circuit Proposal consists of the following components:

- A new 345 kV double circuit line of approximately 86 miles from the existing Edic 345 kV substation to the existing New Scotland 345 kV substation
- Two new 345 kV lines of approximately 5 miles single-circuit looping the existing 345 kV Edic to New Scotland #14 line into and out of a new Rotterdam 345 kV Substation. The Rotterdam 230 kV substation will be retired
- Two new 345/115 kV lower impedance transformers connecting the existing Rotterdam 115 kV switchyard to the new 345 kV switchyard. One new 345/230 kV transformer connecting the existing 230 kV Rotterdam to Eastover Road #38 line to the new Rotterdam 345 kV switchyard

- Rebuild approximately 6 miles of the Rotterdam to New Scotland 345 kV transmission line to accommodate the new double-circuit line beginning from Princetown junction
- Remove the Rotterdam to New Scotland 115 kV transmission line
- A new Princetown 345 kV switchyard by tapping the newly proposed Edic-New Scotland lines and Rotterdam-New Scotland transmission lines
- Terminal upgrades at Edic and Marcy 345 kV substations
- Decommission of the Porter to Rotterdam 230 kV lines #30 and #31

Figure 3-5 shows the one-line diagram for T027 (together with components of T029/T030).

**Figure 3-5: One-Line Diagram of T027+T029/T030**



**T028: NAT/NYPA - Segment A Enhanced**


The NAT/NYPA - Segment A Enhanced Proposal consists of the following components:

- A new 345 kV line of approximately 86 miles from the existing Edic 345 kV substation to the existing New Scotland 345 kV substation
- Two new 345 kV lines of approximately 5 miles single-circuit looping the existing 345 kV Edic to New Scotland #14 line into and out of a new Rotterdam 345 kV Substation. The Rotterdam 230 kV substation will be retired

- Two new 345/115 kV lower impedance transformers connecting the existing Rotterdam 115 kV switchyard to the new 345 kV switchyard. One new 345/230 kV transformer connecting the existing 230 kV Rotterdam to Eastover Road #38 line to the new Rotterdam 345 kV switchyard
- A new Princetown 345 kV switchyard by tapping the newly proposed Edic-New Scotland lines and Rotterdam-New Scotland transmission lines
- Terminal upgrades at Edic and Marcy 345 kV substations
- Decommission of the Porter to Rotterdam 230 kV lines #30 and #31

Figure 3-6 shows the one-line diagram of T028 (together with components of T029/T030).

**Figure 3-6: One-Line Diagram of T028+T029/T030**



**T031: ITC - 16NYPP1-1A AC Transmission Segment A**


The ITC Segment A Proposal consists of the following components:

- A new Princetown 345 kV switching station tapping the existing Marcy to New Scotland 345 kV #18 line and Edic to New Scotland 345 kV #14 line
- A new Edic – Princetown – New Scotland 345 kV line, rebuilding line #14 between Princetown and New Scotland and sharing the common tower structures with the new line
- A new Rotterdam 345 kV substation with two new 345/230 kV transformers

- Two new Princetown to Rotterdam 345 kV lines of approximately 5.2 miles single circuit
- Decommission of the Porter to Rotterdam 230 kV lines #30 and #31

Figure 3-7 shows the one-line diagram of T031 (together with components of T032).

**Figure 3-7: One-Line Diagram of T031+T032**



### 3.1.2 Segment B Projects

All Segment B projects include the common upgrades required by the PSC in its December 2015 Order, which ordered Orange and Rockland Utilities, Inc. (O&R) and Central Hudson Gas and Electric Corporation (Central Hudson) respectively to upgrade the Shoemaker to Sugarloaf 138 kV facilities and the terminal upgrades at Rock Tavern 345 kV Substation, as part of Segment B projects.

#### T019: National Grid/Transco - NYES Segment B


National Grid/Transco-NYES Segment B proposal consists of the following components:

- A new double-circuit 345/115 kV line from a new Knickerbocker 345 kV Switching Station to the existing Pleasant Valley Substation, including a rebuild of the Churchtown 115 kV Switching Station and an upgrade of the existing Pleasant Valley 345/115 kV Substation, and 50% series compensation on Knickerbocker to Pleasant Valley 345 kV line
- Two new 135 MVAR 345 kV capacitor banks connected to the Pleasant Valley 345 kV Substation

- Terminal upgrades to the existing Roseton 345 kV Substation and Transition Station to upgrade the thermal ratings on the 345 kV Roseton to East Fishkill #305 line
- Terminal upgrades to the existing New Scotland 345 kV Substation to upgrade the thermal ratings on the 345 kV New Scotland to Knickerbocker #2A line
- Retirement of aging infrastructure including multiple existing 115 kV lines between Greenbush 115 kV Substation and Pleasant Valley 115 kV Substation

Figure 3-8 shows the one-line diagram of T019 (together with components of T018).

**Figure 3-8: One-Line Diagram of T018+T019**



**T022: NextEra - Enterprise Line Segment B**


NextEra Enterprise Line Segment B proposal consists of the following components:

- Multiple retirements and reconfigurations on 115 kV lines between Greenbush – Pleasant Valley
- New Knickerbocker 345 kV Switchyard, approximately 13 miles southeast of New Scotland along the New Scotland - Alps 345 kV line
- Loop New Scotland - Alps 345 kV line circuit #2 into Knickerbocker Switchyard
- New North Churchtown 115 kV Switchyard, just north of NYSEG’s existing Churchtown 115 kV switchyard
- A new 345 kV line from a new Knickerbocker 345 kV switching station to the existing Pleasant Valley 345 kV substation (double-circuit 345/115 kV line between

Knickerbocker and Churchtown, and single-circuit 345 kV line between Churchtown and Pleasant Valley)

Figure 3-9 shows the one-line diagram of T022 (together with components of T021).

**Figure 3-9: One-Line Diagram of T022**




**T023: NextEra - Enterprise Line Segment B-Alt**

NextEra Enterprise Line Segment B-Alt proposal consists of the following components:

- Multiple retirements and reconfigurations on 115 kV lines between Greenbush – Pleasant Valley
- New Knickerbocker 345 kV Switchyard, approximately 13 miles southeast of New Scotland along the New Scotland - Alps 345 kV line
- Loop New Scotland - Alps 345 kV line circuit #2 into Knickerbocker Switchyard
- New North Churchtown 115 kV Switchyard, just north of NYSEG’s existing Churchtown 115 kV switchyard
- A new double-circuit 345/115 kV line from a new Knickerbocker 345 kV switching station to the existing Pleasant Valley 345 kV substation

Figure 3-10 shows the one-line diagram of T023 (together with components of T021).

**Figure 3-10: One-Line Diagram of T023**




**T029: NAT/NYPA - Segment B Base**

NAT/NYPA Segment B Base Proposal consists of the following components:

- Multiple retirements and reconfigurations on 115 kV lines between Greenbush – Pleasant Valley
- A new 345 kV Knickerbocker switchyard along the New Scotland - Alps 345 kV line
- Loop the existing 345 kV New Scotland to Alps transmission line into Knickerbocker Switchyard
- A new double-circuit 345/115 kV line from a new Knickerbocker 345 kV switching station to Pleasant Valley 345 kV substation (double-bundled 345 kV line)
- A new Churchtown 115 kV substation
- Shoemaker – Shoemaker Tap – Middletown 345/138 kV transformer and 138 kV facilities upgrades

Figure 3-11 shows the one-line diagram of T029 (together with components of T027).

**Figure 3-11: One-Line Diagram of T027+T029/T030**




**T030: NAT/NYPA - Segment B Enhanced**

NAT/NYPA Segment B Enhanced Proposal consists of the components included with the Segment B Base Proposal with use of a triple bundle (instead of double bundle) conductor for the Knickerbocker – Pleasant Valley 345 kV transmission line.

Figure 3-12 shows the one-line diagram of T030 (together with components of T027).

**Figure 3-12: One-Line Diagram of T027+T029/T030**






**T032: ITC - 16NYPP1-1A AC Transmission Segment B**

ITC Segment B Proposal consists of the following components:

- Multiple retirements and reconfigurations on 115 kV lines between Greenbush and Pleasant Valley
- A new Knickerbocker 345/115 kV substation by tapping the existing 345 kV New Scotland to Alps circuit and Greenbush to Pleasant Valley 115 kV line respectively
- A new 345/115 kV double-circuit line from the Knickerbocker station to Churchtown station on existing Greenbush to Pleasant Valley right-of-way
- A new 345/115/115 kV triple-circuit line from Churchtown to Pleasant Valley on existing Greenbush to Pleasant Valley right-of-way

Figure 3-13 shows the one-line diagram of T032 (together with components of T031).

**Figure 3-13: One-Line Diagram of T031+T032**



**3.2 Overview of Evaluation Assumptions**

The process for the evaluation of solutions is described in the NYISO Public Policy Transmission Planning Process Manual, and evaluates the metrics set forth in the NYISO’s tariff and, to the extent feasible, the criteria prescribed by the PSC. Notably, the NYISO’s evaluation of Public Policy Transmission Projects differs from its evaluation of projects in its other planning processes because it can give varying levels of considerations to the baseline and the chosen scenarios based upon the nature of the proposed Public Policy Transmission Projects. In other words, certain

projects may perform differently under normal operating conditions (*i.e.*, the baseline) and other potential operating conditions. Based upon the particulars of the Public Policy Transmission Need, the more efficient or cost-effective solution may be chosen based upon a scenario or a combination of scenarios and the baseline cases.

Three major types of analysis were conducted in evaluating quantitative metrics: transfer limit analysis, resource adequacy analysis, and production cost simulation. The study method, assumptions, and the metrics evaluated by the study method are described in the following sections. The results of these analyses are described in Section 3.3.

### **3.2.1 Transfer Limit Analysis**

Transfer limit analysis evaluates the amount of power that can be transferred across an interface while observing applicable reliability criteria. The results of transfer limit analysis were used in the evaluation of metrics such as cost per MW, operability, and expandability. Based on the criteria set forth by the NYPSC Order, the NYISO determined that a power flow model is necessary to evaluate the transfer limits of the Central East and UPNY/SENY interfaces.

The Central East interface represents transmission lines from Utica to Albany and a line from northern New York to Vermont. Central East is typically a voltage-constrained interface; therefore, the NYISO performed a voltage transfer analysis using the PowerGEM TARA software and in accordance with the NYISO Guideline for Voltage Analysis and Determination of Voltage-Based Transfer Limits. To determine the voltage transfer limits, the NYISO created a set of power flow cases with increasing transfer levels by increasing generation upstream of the interface and decreasing generation downstream of the interface. As the transfer level across the interface was increased, the voltage-constrained transfer limit was determined to be the lower of: (1) the pre-contingency power flow at which the pre/post-contingency voltage falls below the voltage limit criteria, or (2) 95% of the pre-contingency power flow at the voltage collapse point, also known as the “tip of the nose” of the post-contingency power-voltage (PV) curve.

The UPNY-SENY interface represents a collection of transmission lines on which power flows from Upstate New York to Southeast New York. UPNY/SENY is historically limited by the thermal capability of the individual transmission lines; therefore, the NYISO performed the thermal transfer analysis for the interface in accordance with the Normal Transfer Criteria as defined by the New York State Reliability Council (NYSRC) Reliability Rules. The NYISO used the PowerGEM TARA program to perform the thermal transfer analysis. To determine the thermal transfer limits, the

NYISO raised the power flow across the interface by uniformly increasing upstream generation and uniformly decreasing downstream generation. The long-term emergency (LTE) ratings of the BPTF were monitored while simulating design contingency events. During transfer analysis, the NYISO also monitored all 100 kV and above facilities that are not BPTF. Whenever the post contingency power flow on the non-BPTF exceeded short-term emergency (STE) ratings, the NYISO evaluated whether the loss of the non-BPTF would cause other facilities to be overloaded. If the affected facility's loss caused other non-BPTF to exceed their STE ratings or BPTF to exceed their LTE ratings (consistent with the NYSRC Reliability Rules and Exceptions), the NYISO determined a transfer limit that would allow the system to operate without the loss of multiple transmission facilities.

#### 3.2.1.1 Baseline Transfer Analysis

For purposes of evaluating the proposed solutions, the NYISO performed a baseline transfer analysis starting with the power flow cases that were used in the 2016 Reliability Planning Process<sup>22</sup> (2016 RPP) base case system representation of 2026 summer peak load to determine the performance of the AC Transmission Public Policy Transmission Projects. These 2016 RPP power flow base cases were then updated with the latest information from the 2017 Load and Capacity Data Report. Some of these includes generation additions such as Ginna, FitzPatrick, Cayuga, CPV Valley Energy Center, Cricket Valley Energy Center, Bayonne Energy Center II, and Bethlehem Energy Center Up-rate. Other updates include retirement of the Indian Point Energy Center Units No. 2 & 3 and inclusion of Empire State Line which the NYISO selected to satisfy Western New York Public Policy Transmission need in the system topology. Generic upgrades were also added in the transfer analysis scenario for the underlying Chester - Shoemaker area as directed by the NYPSC. The transfer analysis scenario considered two Roseton dispatches, one with Roseton dispatched at 100% of its capacity and another with Roseton dispatched at 85% of its capacity. The 2016 RPP base case modeled the Marcy South Series Compensation as in-service. The Hudson Transmission Project (HTP) was scheduled at 0 MW based on its cancellation of Firm Transmission Withdrawal Rights in PJM. Operational Base Flow (OBF) was not scheduled on the ABCJK PARs based on the

---

<sup>22</sup> The 2016 Reliability Needs Assessment is posted at: [http://www.nyiso.com/public/webdocs/markets\\_operations/services/planning/Planning\\_Studies/Reliability\\_Planning\\_Studies/Reliability\\_Assessment\\_Documents/2016\\_RNA\\_Final\\_Oct18\\_2016.pdf](http://www.nyiso.com/public/webdocs/markets_operations/services/planning/Planning_Studies/Reliability_Planning_Studies/Reliability_Assessment_Documents/2016_RNA_Final_Oct18_2016.pdf).

expected expiration of the NYISO-PJM Joint Operating Agreement.

### 3.2.1.2 Viability and Sufficiency Assessment Transfer Analysis

This report also included the transfer analysis performed during the Viability and Sufficiency Assessment in 2016. This transfer analysis was based on the power flow cases from the NYISO 2014 Reliability Planning Process base case system representation of the 2019 summer peak load, modified to include the CPV Valley Energy Center generation plant and associated System Deliverability Upgrades. Appendix B describes the detailed assumptions used in the Viability and Sufficiency Assessment.

### 3.2.2 Resource Adequacy Analysis

Resource adequacy is the ability of the electric systems to supply the aggregate electricity demand and energy requirements of the customers at all times, taking into account scheduled and unscheduled outages of system elements. The New York Control Area (NYCA) is planned to meet a Loss of Load Expectation (LOLE) that, at any given point in time, is less than or equal to an involuntary load disconnection that is not more frequent than once in every 10 years, or 0.1 events per year. The purpose of resource adequacy analysis for the AC Transmission Need was not intended to identify any reliability needs, but to 1) make sure the MAPS database has enough resources in the comparative evaluation, and 2) set up the MARS database for the ICAP benefit analysis.

The NYISO performed a baseline resource adequacy evaluation of the NYCA for the AC Transmission Need. The 2016 RPP base cases were used as a starting point and the NYCA load forecast was extended up to year 2046 to cover the study period. The generation and transmission assumptions are the same as those NYISO used in the baseline transfer analysis. Consistent with the MARS topology proposed for the 2018 RNA,<sup>23</sup> the pre-project UPNY-ConEd transfer limit was increased to 6,250 MW, and the pre-project UPNY-SENY topology was updated with dynamic limits. For comparative evaluation purpose, MARS topology was also developed for AC Transmission projects based on transfer analysis.

LOLE analysis was also performed for a scenario modeling the Clean Energy Standard (CES) and retirement of aging generation. The assumptions used for this scenario are described in

---

<sup>23</sup> See 2018 RNA Preliminary Topology Presentation, [http://www.nyiso.com/public/webdocs/markets/operations/committees/bic\\_espwg/meeting\\_materials/2018-03-13/2018RNA\\_PreliminaryTopology.pdf](http://www.nyiso.com/public/webdocs/markets/operations/committees/bic_espwg/meeting_materials/2018-03-13/2018RNA_PreliminaryTopology.pdf)

Section 3.2.3.2.3, and the MARS topology is the same as the NYISO used in the baseline resource adequacy analysis.

If any potential NYCA LOLE violations were identified in the analysis, compensatory MW were added to NYCA zones to resolve the LOLE violations. The compensatory MW amounts and locations were determined based on a review of binding interfaces and zonal LOLE levels in an iterative process to address the LOLE violations. Table 3-1 below shows the cumulative compensatory MW that needs to be added to satisfy the LOLE criterion of 0.1 events per year.

**Table 3-1: Cumulative Compensatory MW in 2042**

	Project	Zone C	Zone H	Zone J	Zone K	Total
Baseline	Pre-Project	-	500	550	350	1400
	Combinations involving T018, T025, or T027	250	250	450	350	1300
	Other Combinations	250	250	500	350	1350
CES+Retirement	Pre-Project	-	-	1450	550	2000
	Combinations involving T018, T025, or T027	-	-	1150	550	1700
	Other Combinations	-	-	1250	550	1800

### 3.2.3 Production Cost Analysis

Production cost analysis evaluated the proposed Public Policy Transmission Projects and their impact on NYISO wholesale electricity markets. The results of production cost analysis were used in the evaluation of metrics such as production cost savings, production cost saving/project cost ratio, system CO<sub>2</sub> emission reduction, LBMP, load payment, and performance.

#### 3.2.3.1 Baseline Analysis

The AC Transmission Need production cost analysis baseline case was derived from the draft 2017 CARIS Phase 1 database.<sup>24</sup> Updates were made to the system while extensions were made for increasing the range of the study period (2017 – 2046). At the November 17, 2017 ESPWG/TPAS meeting, the NYISO presented the starting database, updates, and extensions for the baseline

<sup>24</sup> 2017 CARIS Phase 1 assumptions and results are posted at: [http://www.nyiso.com/public/webdocs/markets\\_operations/committees/bic/meeting\\_materials/2018-03-15/2017\\_Report\\_CARIS2017\\_final\\_draft\\_031518\\_BIC.pdf](http://www.nyiso.com/public/webdocs/markets_operations/committees/bic/meeting_materials/2018-03-15/2017_Report_CARIS2017_final_draft_031518_BIC.pdf).

production cost analysis.<sup>25</sup> The generation and transmission assumptions are the same as used in the power flow baseline.

Due to the longer study period of the AC Transmission baseline case, the load, fuel, and emissions forecasts were extended. While the fuel and emissions forecasts would affect the four-pool system in the Northeast (IESO, ISO-NE, NYISO, and PJM), the NYISO was able to model load forecast extensions only for the NYISO. Load forecasts for the external control areas only range from 2017 to 2026 consistent with the CARIS methodology. Therefore, after 2026, the NYISO held external control area loads fixed to the 2026 schedule for 2027 through 2046. The baseline also modeled a national CO<sub>2</sub> program starting in 2027.

### 3.2.3.2. Scenario Analysis

At the November 17, 2017 ESPWG meeting, the NYISO solicited from stakeholders the potential scenarios for evaluating the AC Transmission Public Policy Transmission Projects. Based on stakeholder feedback, the NYISO developed scenarios by modifying the baseline assumptions to evaluate the robustness of the proposed Public Policy Transmission Projects according to the selection metrics and the impact on NYISO wholesale electricity markets. The following sections describe the scenarios that assist in understanding the overall performance of the projects under various conditions.

#### 3.2.3.2.1. Scenario #1: National CO<sub>2</sub> removed

The baseline modeled a national CO<sub>2</sub> program starting from 2027. The NYISO developed Scenario #1 assuming the national CO<sub>2</sub> program is not in place.

#### 3.2.3.2.2. Scenarios #2 and #3: High fuel and low fuel

The NYISO also developed high and low fuel costs for the baseline consistent with the fuel forecast methodology used in the CARIS process. Energy Information Administration's Annual Energy Outlook forecasts of the annual national delivered price were used to generate Low and High natural gas price forecasts for each region. Figure 3-14 and Figure 3-15 show the high and low natural gas forecast used in these scenarios.

---

<sup>25</sup> The meeting materials are posted at: [http://www.nyiso.com/public/webdocs/markets\\_operations/committees/bic\\_espwg/meeting\\_materials/2017-11-17/AC\\_Transmission\\_Ph2\\_Assumptions.pdf](http://www.nyiso.com/public/webdocs/markets_operations/committees/bic_espwg/meeting_materials/2017-11-17/AC_Transmission_Ph2_Assumptions.pdf).

Figure 3-14: High Natural Gas Forecast





Figure 3-15: Low Natural Gas Forecast



3.2.3.2.3. Scenario #4: Clean Energy Standard (CES) with Aging Generation Retirements and National CO<sub>2</sub> removed

Scenario #4 assumes the integration of sufficient renewable generation and energy efficiency to meet the objectives of the Clean Energy Standard<sup>26</sup> along with the retirement of all New York

<sup>26</sup> New York State Department of Public Service, Staff White Paper on Clean Energy Standard, Case No. 15-E-0302 (January 25, 2016).



coal units and approximately 3,500 MW of old GTs in NYC and Long Island. The NYISO also developed Scenario #4 assuming the national CO<sub>2</sub> program is not in place. The resource changes are captured in Table 3-2. In addition, approximately 17 TWh of energy efficiency was modeled. With these assumptions, approximately 50% of New York’s energy requirements were projected to be served by renewable resources.

**Table 3-2: Capacity of Zonal Renewable Generation added in Scenario #4 (MW)**

Zone	Capacity (MW)	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	Total
Total	Land-Based Wind	-	-	73	473	317	522	346	293	285	615	657	91	780	106	4,558
	Utility-Scale Solar	-	-	-	-	462	570	-	-	1,821	1,227	338	2,930	1,241	2,893	11,482
	Offshore Wind	-	-	-	-	-	-	-	-	-	-	-	-	-	226	226
	Imports	-	-	-	-	-	258	258	-	-	-	-	-	-	-	516
Zone A	Land-Based Wind			73	367	109	47	252	86		190	79		30		1,233
	Utility-Scale Solar										108	153	732	871		1,864
	Offshore Wind															-
Zone B	Land-Based Wind															-
	Utility-Scale Solar														344	344
	Offshore Wind															-
Zone C	Land-Based Wind										59			210		269
	Utility-Scale Solar											185	1,219		2,429	3,833
	Offshore Wind															-
Zone D	Land-Based Wind															-
	Utility-Scale Solar													152		152
	Offshore Wind															-
Zone E	Land-Based Wind						162		112	245	284	553	91	429	106	1,982
	Utility-Scale Solar															-
	Offshore Wind															-
Zone F	Land-Based Wind				56	71	221	94	95	40	42	25		54		698
	Utility-Scale Solar					462	345			1,821	58		895			3,581
	Offshore Wind															-
Zone G	Land-Based Wind				50	40	92				40			57		279
	Utility-Scale Solar						143				565			218	120	1,046
	Offshore Wind															-
Zone H	Land-Based Wind															-



Zone	Capacity (MW)	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	Total
	Utility-Scale Solar						12									12
	Offshore Wind															-
Zone I	Land-Based Wind															-
	Utility-Scale Solar															-
	Offshore Wind															-
Zone J	Land-Based Wind															-
	Utility-Scale Solar															-
	Offshore Wind															-
Zone K	Land-Based Wind					97										97
	Utility-Scale Solar						70				496		84			650
	Offshore Wind														226	226
Imports	LBW Quebec															
	Ontario Utility Scale Solar															
	LBW Ontario						258	258								516
	LBW PJM															-
	PJM Utility Scale Solar															
<b>Total</b>		<b>0</b>	<b>0</b>	<b>73</b>	<b>473</b>	<b>779</b>	<b>1,350</b>	<b>604</b>	<b>293</b>	<b>2,106</b>	<b>1,842</b>	<b>995</b>	<b>3,021</b>	<b>2,021</b>	<b>3,225</b>	<b>16,782</b>

### 3.3 Evaluation Metrics

Consistent with the PSC’s direction that no Public Policy Transmission Project shall be selected for Segment A unless a Public Policy Transmission Project is selected for Segment B, the NYISO combined each Segment A proposal with each developer’s Segment B counterpart proposal. In order to evaluate a feasible number of possible combinations between Segment A and Segment B proposals, the NYISO developed representative combinations as follows:

- Combining all Segment A and Segment B projects from the same developers, and
- Combining Segment A and Segment B projects from different developers based on combinations with similar electrical characteristics.
  - Similar Segment A projects: T018, T021, T026, T028, T031
  - Segment A: T025
  - Segment A: T027

- Similar Segment B projects: T022, T023, T029, T030, T032
- Segment B: T019

Table 3-3 shows the complete list of the representative combinations that were studied by NYISO and Table 3-4 shows how the combinations results represents other project combinations that were not studied.

**Table 3-3: Representative Combinations**

Combination ID	Representative Combination
1	T018+T019
2	T021+T022
3	T021+T023
4	T025+T019
5	T025+T029
6	T025+T030
7	T026+T029
8	T026+T030
9	T027+T019
10	T027+T029
11	T027+T030
12	T028+T029
13	T028+T030
14	T031+T032

**Table 3-4: Project combinations Representative results**

Representative Results for Central East Voltage Transfer and Production Cost Analysis

	T018	T021	T025	T026	T027	T028	T031
T019	1	3	4	7	9	12	14
T022	1	2	5	7	10	12	14
T023	1	3	5	7	10	12	14
T029	1	3	5	7	10	12	14
T030	1	3	6	8	11	13	14
T032	1	3	5	7	10	12	14

Representative Results for UPNY-SENY Thermal Transfer

	T018	T021	T025	T026	T027	T028	T031
T019	1	1	4	1	9	1	1
T022	2	2	5	2	10	2	2
T023	3	3	5	3	10	3	3
T029	7	7	5	7	10	12	12
T030	8	8	6	8	11	13	13
T032	14	14	5	14	10	14	14

### 3.3.1 Capital Cost Estimate

The NYISO and its independent consultant, SECO, evaluated each Developer’s capital cost estimates for their proposed Public Policy Transmission Project for accuracy and reasonableness, and on a comparative basis with other proposed Public Policy Transmission Projects. Each Developer was required to submit detailed and credible estimates for the capital costs associated with the engineering, procurement, permitting, and construction of a proposed transmission solution. SECO reviewed all the information submitted by the Developers and developed independent cost estimates for each project based on material and labor cost by equipment, engineering and design work, permitting, site acquisition, procurement and construction work, and commissioning needed for the proposed Public Policy Transmission Projects. Appendix D details the analysis performed by SECO. Consistent with the PSC’s direction that the costs should be evaluated using raw construction costs on a comparable basis, the NYISO applied the same contingency rate to the independent consultant’s capital cost estimates for all projects. Also, per the PSC’s criterion that the selection process for transmission solutions for Segment B not use the costs of upgrades to the Rock Tavern Substation and upgrades to the Shoemaker to Sugarloaf

transmission lines as a distinguishing factor between Public Policy Transmission Projects, the NYISO and its independent consultant SECO excluded these costs from the cost estimates. Table 3-5 summarizes SECO’s overnight capital cost estimates for Segment A and Segment B projects in 2018 dollars:

**Table 3-5: Independent Cost Estimate<sup>27</sup>**

Segment	Project ID	Independent Cost Estimate: 2018 \$M (w/ 30% contingency rate)	Independent Cost Estimate: 2018 \$M (w/o 30% contingency rate)
A	T018	520	400
	T021	498	383
	T025	861	662
	T026	489	376
	T027	741	570
	T028	512	394
	T031	570	438
B	T019	445	342
	T022	357	274
	T023	390	300
	T029	387	298
	T030	406	313
	T032	502	386

**Table 3-6** summarizes the cost estimates for all the Segment A and Segment B project combinations. NYISO considered a 5% synergy in cost estimates if the same developer were to develop both Segment A and Segment B projects. PSC’s criteria allows for consideration of cost

<sup>27</sup> At the time that this draft report was released, the System Impact Studies for all of the projects were still in progress. Hence, the NYISO provided two sets of cost estimates—one cost estimate with the cost of Network Upgrade Facilities (NUF), equaling 30%, applied to all projects to account for any system upgrades that may be identified through the NYISO’s Transmission Interconnection Procedures, and the other cost estimate without including any costs for NUF.

synergies if same developer were to develop both Segment A and Segment B

**Table 3-6: Independent Cost Estimate – Project Combinations**

Developers	Project ID	Independent Cost Estimate: 2018 \$M (w/ 30% contingency rate) (w/o synergies)	Independent Cost Estimate: 2018 \$M (w/ 30% contingency rate) (w/ 5% synergies if same developers)
Same Developers	T018+T019		917
	T021+T022		812
	T021+T023		843
	T025+T029		1159
	T025+T030		1177
	T026+T029		832
	T026+T030		850
	T027+T029		1072
	T027+T030		1090
	T028+T029		854
	T028+T030		873
	T031+T032		1018
Different Developers	T021+T019	943	
	T025+T019	1273	
	T026+T019	934	
	T027+T019	1186	
	T028+T019	957	
	T031+T019	1015	
	T018+T022	877	
	T025+T022	1189	
	T026+T022	846	
	T027+T022	1098	
	T028+T022	869	
	T031+T022	927	
	T018+T023	910	
	T025+T023	1222	
	T026+T023	878	
	T027+T023	1131	
	T028+T023	902	
	T031+T023	960	
	T018+T029	907	
	T021+T029	885	
T031+T029	957		
T018+T030	926		

T021+T030	904	
T031+T030	976	
T018+T032	1022	
T021+T032	1000	
T025+T032	1323	
T026+T032	991	
T027+T032	1243	
T028+T032	1014	

### 3.3.2 Cost Per MW Ratio

The cost per MW ratio metric was calculated by dividing SECO’s independent cost estimates by the MW value of transfer capability. For the purpose of calculating cost per MW based on transfer limits, the NYISO calculated the Central East voltage transfer limits and UPNY-SENY thermal transfer limits.

Table 3-7 and Table 3-8 summarize the baseline transfer results.

**Table 3-7: Voltage Transfer across Central East**

Project ID	Transfer Limit	Incremental
Pre-Project	2,575	-
T018+T019	3,000	425
T021+T022	2,925	350
T021+T023	2,925	350
T025+T019	3,875	1,300
T025+T029	3,700	1,125
T025+T030	3,775	1,200
T026+T029	2,850	275
T026+T030	2,850	275
T027+T019	3,450	875
T027+T029	3,400	825
T027+T030	3,400	825

T028+T029	2,975	400
T028+T030	2,900	325
T031+T032	2,975	400

**Table 3-8: Thermal Transfer across UPNY-SENY**

Project ID	Roseton at 100%			Roseton at 85%			Optimal Transfer Limit		
	Limit	Constraint	Delta	Limit	Constraint	Delta	Limit	Constraint	Delta
Pre-Project	4775	(1)	-	4825	(1)	-	5025	(1)	-
T018+T019	6375	(2)(A)	1600	6500	(2)(A)	1675	7000	(2)	1975
T021+T022	5975	(3)	1200	6350	(1)	1525	6525	(1)	1500
T021+T023	5975	(3)	1200	6300	(1)	1475	6475	(1)	1450
T025+T019	5825	(4)	1050	5825	(4)	1000	6175	(4)	1150
T025+T029	6600	(3)	1825	6950	(1)	2125	7250	(1)	2225
T025+T030	6700	(3)	1925	7100	(1)	2275	7350	(1)	2325
T026+T029	5925	(3)	1150	6225	(1)	1400	6425	(1)	1400
T026+T030	6000	(3)	1225	6375	(1)	1550	6550	(1)	1525
T027+T019	6525	(2)(A)	1750	6700	(2)(A)	1875	7125	(2)	2100
T027+T029	6125	(3)	1350	6150	(1)	1325	6350	(1)	1325
T027+T030	6175	(3)	1400	6300	(1)	1475	6475	(1)	1450
T028+T029	5950	(3)	1175	6250	(1)	1425	6450	(1)	1425
T028+T030	6025	(3)	1250	6400	(1)	1575	6575	(1)	1550
T031+T032	6000	(3)	1225	6325	(1)	1500	6500	(1)	1475

(1) Leeds - Pleasant Valley at 1538 MW LTE rating for TE44:L/O ATHENS-PV 345 91

(2) Middletown Transformer at 707 MW STE rating for T:77&76

(3) Roseton - East Fishkill at 2676 MW LTE rating for T:77&76

(4) Knickerbocker Series Comp at 2308 MW LTE rating for T:34&44

(A) Limited by cascading test

Table 3-9 displays the cost per MW (\$M/MW) ratio based on transfer limits. The table displays the proportional UPNY-SENY transfer limit with Roseton dispatched at 100% and 85% as well as the optimal UPNY-SENY transfer limit.



DRAFT

**Table 3-9: Cost Per MW Ratio**

Project ID	Segment A Independent Cost Estimate: 2018 \$M	Segment B Independent Cost Estimate: 2018 \$M	Cost/MW: incremental Central East Voltage Limit (N-1)		Cost/MW: incremental UPNY-SENY thermal Limit (N-1 NTC)					
					Roseton at 100%		Roseton at 85%		Optimized Transfer	
			Inc. MW	\$M/MW	Inc. MW	\$M/MW	Inc. MW	\$M/MW	Inc. MW	\$M/MW
T018+T019	494	423	425	1.16	1,600	0.26	1,675	0.25	1,998	0.21
T021+T022	473	339	350	1.35	1,200	0.28	1,525	0.22	1,519	0.22
T021+T023	473	370	350	1.35	1,200	0.31	1,475	0.25	1,466	0.25
T025+T019	861	445	1,300	0.66	1,050	0.42	1,000	0.45	1,163	0.38
T025+T029	818	368	1,125	0.73	1,825	0.20	2,125	0.17	2,226	0.17
T025+T030	818	386	1,200	0.68	1,925	0.20	2,275	0.17	2,342	0.16
T026+T029	464	368	275	1.69	1,150	0.32	1,400	0.26	1,401	0.26
T026+T030	464	386	275	1.69	1,200	0.32	1,525	0.25	1,535	0.25
T027+T019	741	445	875	0.85	1,750	0.25	1,875	0.24	2,103	0.21
T027+T029	704	368	825	0.85	1,350	0.27	1,325	0.28	1,326	0.28
T027+T030	704	386	825	0.85	1,400	0.28	1,475	0.26	1,470	0.26
T028+T029	487	368	400	1.22	1,175	0.31	1,425	0.26	1,427	0.26
T028+T030	487	386	325	1.50	1,250	0.31	1,575	0.25	1,569	0.25
T031+T032	542	477	400	1.35	1,225	0.39	1,500	0.32	1,476	0.32

**3.3.3 Expandability**

In assessing the expandability of the proposed projects, the NYISO considers the feasibility and ease of physically expanding a facility, which can include consideration of future opportunities to economically expand a facility and the likelihood of future transmission siting. Such consideration may include future modifications to increase equipment ratings of the proposed facilities, staging or phasing of future transmission development, or otherwise benefiting from the proposed facilities for future reliability or congestion relief purposes. The details are summarized in the following sections.

**3.3.3.1 Physical Expandability**

The NYISO contracted the independent consultant, SECO, to perform the project expandability

assessment to account for any possibilities of facilitating future transmission or substation expansion or generation interconnection as the result of the project proposals. SECO conducted evaluation of the expansion capability of the Developers' proposals by using the projects' information submitted by the Developers during the Viability and Sufficiency Assessment and additional information, specifically on expandability, provided by Developers in response to a request for additional information by the NYISO.

Applicable design approaches to enhance future expandability are limited in the AC Public Policy Transmission Projects since only the existing rights-of-way (ROW) can be utilized. Much of the existing transmission ROW will be fully utilized in construction of this project but there remains is some opportunity for expansion.

Potential transmission expansion includes the following:

- All proposals for Segment A involve replacement of the existing Porter-Rotterdam 230 kV circuits #30 and #31 with a single Edic to New Scotland 345 kV line. This will provide space for future use of the existing ROW and may allow for the addition of another circuit from Edic/Porter to Princetown Junction within the existing ROW, based on current electrical clearance requirements. Any proposal to construct an additional circuit is subject to the applicable permitting and regulatory requirements, such as public acceptance of visual impact, EMF compliance, compatibility with existing gas facilities and regulatory approvals.
  - For the base proposals, NextEra affords the most efficient use of the existing ROW by utilizing 100 ft. single-pole delta structures. National Grid/Transco, NAT/NYPA and ITC propose using 65-85 ft. H-pole structures, which requires the use of more space within the ROW. In all base proposals, there may be adequate space in the existing ROW remaining for an additional 345 kV line. However, a compact transmission line configuration may be required to fit a future 345 kV line in the remaining ROW.
  - All alternative proposals may also provide adequate space within the existing ROW for a future line with the exception of NAT/NYPA T027. The NAT/NYPA T027 double circuit line proposal utilizes all 4 existing circuit positions for the first 12 miles out of Edic.
  - During detailed engineering the placement of structures should be optimized to maximize the remaining ROW.

- Refer to the table below for summary of the ROW requirements for each Developer’s projects in the Edic to Princetown Junction corridor.

**Table 3-10: ROW requirements in the Edic to Princetown Junction corridor**

Segment-A							
Sector	Corridor Width (ft.)	Developer	Proposal	Proposed Structure Configuration	ROW Req. (ft.)	ROW Corridor Remaining (ft.)	Remarks
Edic to Princetown Jct	200	NGRID/Transco	T018	1 Ckt – 345kV H-pole Horizontal	120	80	Sufficient reserved ROW for expansion utilizing Compact Vertical Configuration
		NextEra	T021	1 Ckt – 345kV Single Pole Delta	80	120	Sufficient reserved ROW for expansion utilizing H-pole Horizontal Configuration
		NYPA/NAT	T026 & T028	1 Ckt – 345kV H-pole Horizontal	140 (a)	60 (a)	Sufficient reserved ROW for expansion utilizing Compact Vertical Configuration
		NYPA/NAT	T027	2 Ckt – 345kV Single Pole Vertical	105	95	Sufficient reserved ROW for expansion utilizing Single Pole Delta Configuration with exception of the first 12.6 miles out of Edic
		ITC	T031	1 Ckt – 345kV H-pole Horizontal	100 (b)	100 (b)	Sufficient reserved ROW for expansion utilizing Single Pole Delta Configuration

- (a) For NYPA/NAT proposals T026 & T028, 24 spans are limiting the remaining corridor to 60 ft. If, in the final design, the ROW requirement can be kept to within 60 ft. of either side of centerline (through increased tension, shorter span lengths or special design), the ROW required would be 120 ft., leaving 80 ft. for future expansion.
- (b) The ITC proposal T031 is able to have less of an ROW requirement due to using more structures and shorter span lengths.

- The new Edic to New Scotland line for Segment A could be designed for double circuit capability similar to the NAT/NYPA T027 double circuit line proposal.
- Transmission lines could be constructed with higher ampacity conductor or re-conducted in the future.
- Most proposals provide for future expansion of substations or could be modified to provide for additional line terminals and transformers in the new substations.

Potential substation expansion for each Developer’s specific proposal is discussed in the Table 3-11.

**Table 3-11: AC Transmission Projects Substation Expandability Analysis**

Segment	Project ID	Substation Expandability
A	T018	At Rotterdam Substation, the 345 kV gas-insulated substation design provides one open 345kV bay position and room for additional 345 kV bays. Design also provides ability to connect one additional 345 kV/115 kV transformer to support the local transmission system. Lastly, the design allows for the rebuilding of the 115 kV straight bus configuration into a breaker-and-a-half configuration.
	T021	NextEra is proposing a “Princetown” substation approximately 2 miles west of Rotterdam Substation on a new greenfield site. The design provides two open 345 kV bay positions and room on the property for adding bays. It maintains the existing and aging Rotterdam 230 kV yard intact.
	T025, T027, T028	At Rotterdam, rebuilding and relocating the 345 kV substation allows for the rebuilding of the 115 kV straight bus configuration into a breaker-and-a-half configuration. A new Princetown Substation is proposed at the junction of the 345 kV Edic-New Scotland line and the 230 kV Porter to Rotterdam lines. Due to the proximity to the neighboring properties, constructing or expanding the substation will be difficult. T025 also creates an open line terminal position at New Scotland substation.
	T026	At Rotterdam, rebuilding and relocating the 345 kV substation allows for the rebuilding of the 115 kV straight bus configuration into a breaker-and-a-half configuration. The proposed design for New Scotland provides the possibility of reconfiguring the substation as a breaker-and-a-half.
	T031	ITC’s proposal does not provide any additional bays at Princetown or Rotterdam Substations. ITC’s proposal maintains the existing and aging Rotterdam 230 kV yard intact. Additionally, physical limitations at these properties may preclude future expansions without purchasing additional property.
B	T019	At Knickerbocker Substation, design provides one open 345 kV bay position. The Knickerbocker design also allows the 345 kV ring bus configuration to be converted to a breaker-and-a-half configuration with room on the property for adding bays. At Churchtown Substation, design provides one open 115 kV bay position. Additional breaker-and-a-half bays can be added in the future.
	T022, T023	At Knickerbocker Substation, the proposed design provides one open 345 kV bay position. The Knickerbocker design also allows the 345 kV ring bus configuration to be converted to a breaker-and-a-half configuration with room on the property for adding bays. At North Churchtown Substation, design provides one open 115 kV bay position and with room on the property for adding bays. The southern-most bay could also be built out to a breaker-and-a-half configuration.
	T029, T030	The Developer proposes a new 115 kV breaker-and-a-half substation and eliminates the existing NYSEG Churchtown substation. The three-bay substation is proposed for south of the existing substation and north of Orchard Road. This location will permit future expansion of the proposed substation to the north. At Knickerbocker, the Developer’s design allows the 345 kV ring bus configuration to be converted to a breaker-and-a-half configuration with room on the property for adding bays.
	T032	At Knickerbocker Substation, design provides one open 345 kV bay position and one open 115 kV bay position. Additionally, during detailed design, the ability to connect up to two 345 kV – 115 kV transformers to support the local transmission system could be provided.

### 3.3.3.2 Electrical Expandability

This analysis focused on the potential incremental transfer limits of each proposed project if the limiting element or path is resolved by future additional transmission expansion.

The optimal N-1 UPNY-SENY transfer limits and the constraints summarized in Section 3.3.2.1 were analyzed to determine the most limiting element. To find the next most limiting element, the optimal N-1 transfer was calculated again while excluding the most limiting monitored element. To find the next most limiting path, this process was repeated until a new limiting pathway was found. The incremental transfer capability between the transfer limits constrained by the most limiting element and the second most limiting element captures the electrical benefits of future modifications to increase equipment ratings of the most limiting facilities. Furthermore, if expansion can be made to the entire constraint path, the electrical benefits could be approximated by the incremental transfer capability. Based on the results of the transfer limit analysis, the NYISO determined the two transfer paths are: (i) the Marcy South path (MS) and (ii) the Leeds-Pleasant Valley corridor (LPV).

Figure 3-16 summarizes the potential benefits using Optimal N-1 Transfers. The blue portion of the bars represents the transfer limits based on the project proposal, the red portion represents the transfer limits should the most limiting constraint being resolved, and the green portion represents the transfer limits should the most limiting transfer path be resolved.

Figure 3-16: Electrical Expandability Analysis




Table 3-12: Electrical Expandability Limiting Path

Project	T018+T019	T021+T022	T021+T023	T025+T019	T025+T029	T025+T030	T026+T029	T026+T030	T027+T019	T027+T029	T027+T030	T028+T029	T028+T030	T031+T032
Optimal Transfers	MS	LPV	LPV	LPV	LPV	LPV	LPV	LPV	MS	LPV	LPV	LPV	LPV	LPV



### **3.3.4 Operability**

The NYISO considered how the proposed Public Policy Transmission Projects affect flexibility in operating the system, such as dispatch of generation, access to operating reserves, access to ancillary services, or the ability to remove transmission for maintenance. The NYISO also considered how the proposed projects may affect the cost of operating the system, such as how they may affect the need for operating generation out of merit for reliability needs, reduce the need to cycle generation, or provide more balance in the system to respond to system conditions that are more severe than design conditions.

#### **3.3.4.1 Substation Configuration Assessment**

The operability of the proposals was evaluated by the NYISO and also by the independent consultant, SECO. The following factors were considered in evaluating each of the proposals:

1. **Level of Integration:** Operational preference is for a project that would integrate with the existing New York State Transmission System to the maximum extent possible. For example, a project using an existing right-of-way (ROW) should not bypass existing substations on the ROW except for reasons such as short circuit limitations, space limitations, and design perspective where a new substation is desirable.
2. **Substation Design Configuration:** Operational preference is for substation designs in the following order: double-breaker-double-bus, a breaker-and-a-half, ring bus, main and transfer bus, sectionalized bus, and straight (single) bus.
3. **Transfer Capability Impact with Project Component Out of Service:** From an operations perspective, it is desirable for a project not to lose its improvement to transfer capability as a result of the loss of any of the project's component.

In this assessment, the proposed projects have the greatest impact on the following three substations: Princetown 345 kV, Rotterdam 345 kV, and Knickerbocker 345 kV Substations. Based on the substation configuration, the findings and comparisons are summarized in Table 3-13 for Princetown 345 kV Substation, and Table 3-14 for Rotterdam 345 kV Substation, and Table 3-15 for Knickerbocker 345 kV Substation.

**Table 3-13: Princetown 345 kV Substation Arrangement Comparison**

Developer	# of new Lines	# of new Transformers	Total new elements	Proposed Breaker Arrangement	# of Breakers
T018 NGRID/Transco	No Princetown Substation proposed.				
T021 NextEra	2 – 345kV	2	6	Breaker & Half	7 – 345kV
	2 – 230kV				6 – 230kV
T026 NYPA/NAT	No Princetown Substation proposed.				
T025 NYPA/NAT	4	0	4	Ring Bus	4
T027 NYPA/NAT	6	0	6	Breaker & Half	9
T028 NYPA/NAT	4	0	4	Ring Bus	4
T031 ITC	8	0	8	Breaker & Half	12

Proposals T021 and T031, proposes a breaker-and-a-half configuration for Princetown Substation. Proposal T021 has three bays, and proposal T031 has four bays. Potential issues with siting the Princetown substation were discussed in the Risk Analysis section above. Proposals T025 and T028, proposes a four-breaker ring-bus configuration for Princetown Substation. For proposal T027, NYPA/NAT proposes a gas-insulated three-bay breaker-and-a-half configuration.

**Table 3-14: Rotterdam 345 kV Substation Arrangement Comparison**

Developer	# of new Lines	# of new Transformers	Total new elements	Proposed Breaker Arrangement	# of Breakers
T018 NGRID/Transco	2 – 345kV 1 – 230kV 2 – 115kV*	1 – 345kV-230kV 2 – 345kV-115kV	8	Breaker & Half (Gas-Insulated)	9 – 345kV 1 – 230kV
T021 NextEra	No changes to Rotterdam proposed.				
T026 NYPA/NAT	2 – 345kV 1 – 230kV 2 – 115kV*	1 – 345kV-230kV 2 – 345kV-115kV	8	Breaker & Half	8 – 345kV 1 – 230kV
T025 NYPA/NAT	Same as T026				
T027 NYPA/NAT	Same as T026				
T028 NYPA/NAT	Same as T026				
T031 ITC	2 – 345kV	2 – 345kV-230kV	4	Sectionalized Bus	3 – 345kV 1 – 230kV
*These are tie lines to the existing 115 kV yard at Rotterdam.					

Proposals T018, T025, T026, T027 and T028 propose new 345 kV breaker-and-a-half substations at Rotterdam. These proposals also add two 345 kV-115 kV transformers and one 345 kV-230 kV transformer. Proposal T031 adds a 345 kV sectionalized bus yard to the north side of the existing Rotterdam 230 kV yard. Proposal T021 makes no changes to the existing Rotterdam bus arrangement.

**Table 3-15: Knickerbocker 345 kV Substation Arrangement Comparison**

Developer	# of new Lines	# of new Transformers	Total new elements	Proposed Breaker Arrangement	# of Breakers
T019 NGRID/Transco	3	0	3 (also includes Series Compensation)	Ring Bus (built for future Breaker & Half)	3
T022 NextEra	3	0	3	Ring Bus (built for future Breaker & Half)	3
T023 NextEra	Same as T022.				
T025 NYPA/NAT	1 – 765kV 2 – 345kV	2	5	765kV – Ring Bus 345kV – Ring Bus	3 – 765kV 4 – 345kV
T029 NYPA/NAT	3	0	3	Ring Bus (built for future Breaker & Half)	3
T030 NYPA/NAT	Same as T029.				
T032 ITC	3 – 345kV 3 – 115kV	0	6	345kV - Ring Bus 115kV – Ring Bus	3 – 345kV 3 – 115kV

Except for combinations that include proposal T025, all Developers propose a new Knickerbocker Substation with similar 345 kV ring bus arrangements. Proposal T019 includes Series Compensation on the line terminal to Pleasant Valley. Proposal T032 adds an independent 115 kV ring bus yard. Proposal T025 proposes a 765 kV ring bus yard and a 345 kV ring bus yard with two 765 kV – 345 kV transformers. Proposal T025 will also require the installation of a new 765 kV breaker and associated equipment at the Marcy Substation.

### 3.3.4.2 Dispatch Flexibility

The network configuration, load levels, and generation available for dispatch vary from day to day and sometimes from second to second. While the transfer limit analysis was conducted for the peak load condition assuming all generation shifted was sunk entirely in the New York Control Area, the analysis in this section identified another set of transfer limits that shows the effect of sinking to different areas including New England. The transfer limit analysis was performed using several sinks as sensitivities, and the resulting transfer limits are summarized in the table below.

**Table 3-16: Impact to Grid Operations**

Project ID	Sink	Monitored Element			Limit	Delta
Pre-Project	50% F / 50% G	MARCY	Base Case	Voltage Violation	2,575	
T025+T029	50% F / 50% G	EDIC	Base Case	Voltage Violation	3,700	1,125
T027+T029	50% F / 50% G	EDIC	Base Case	Voltage Violation	3,400	825
Pre-Project	35% F / 65% NE	T:34&44_CE18/UC30		Collapse	2,850	
T025+T029	35% F / 65% NE	KB765	T:34&44_CE18/UC30	Voltage Violation	3,875	1,025
T027+T029	35% F / 65% NE	ROTTERDAM	T:34&44_CE18/UC30	Voltage Violation	3,750	900

### 3.3.4.3 Benefits under Maintenance Conditions

These Central East voltage transfer limits were found after an N-1 outage of a major transmission line that would affect the Central East interface. These results are based on the 2016 RPP case with updates detailed in Section 3.2.1 and use the same methodology as the N-1 Central East Voltage Transfers results in Table 3-7.

**Table 3-17: Central East N-1-1 Voltage Transfer Capability**

Project ID	Maintenance Outage	Transfer Limit	Delta
Pre-Project	Marcy-New Scotland 345 kV Line	1,861	-
T021+T022	Marcy-Princetown 345 kV Line	2,250	389
T025+T019	Marcy-Knickerbocker 765 kV Line	2,165	304
T025+T029	Marcy-Knickerbocker 765 kV Line	2,243	382
T027+T019	Marcy-New Scotland 345 kV Line	2,976	1,115
T027+T029	Marcy-New Scotland 345 kV Line	2,883	1,022
T031+T032	Marcy-Princetown 345 kV Line	2,400	539
T018+T019	Marcy-New Scotland 345 kV Line	2,285	424

The following thermal transfer analysis calculates the N-1 transfer capability under different system maintenance conditions by using optimal N-1-1 transfer limits. The N-1-1 transfer analysis optimally shifts generation from Ontario and Upstate New York and sinks it to the Lower Hudson Valley while securing New York elements to both their pre- and post-contingency ratings. When an overload cannot be mitigated, the optimal transfer limit is determined. Internal NYC PARs were optimized to mitigate local overloads.

Based on the 2016 RPP case with the updates detailed in Section 3.2.1, the table below shows the N-1-1 transfer limits.

**Table 3-18: UPNY-SENY N-1-1 Thermal Transfer Capability**

Maintenance Outage	No Outage		CPV - Rock Tavern 345 kV Line		Marcy - Coopers Corners 345 kV Line		Roseton - East Fishkill 345 kV Line		Athens-Pleasant Valley 345 kV Line	
Pre-Project	5025	(1)	4369	(1)	4505	(1)	3763	(1)	3339	(2)
T018+T019	7023	(3)	6443	(4)	6361	(4)	4423	(3)	5234	(5)
T021+T022	6543	(1)	5827	(1)	5971	(1)	4212	(3)	4587	(2)
T021+T023	6490	(1)	5777	(1)	5923	(1)	4202	(3)	4542	(2)
T025+T019	6187	(6)	6080	(7)	5962	(8)	4867	(3)	5373	(9)
T025+T029	7251	(1)	6519	(1)	6674	(10)	5880	(1)	5108	(5)
T025+T030	7367	(1)	6639	(1)	6683	(10)	6020	(1)	5220	(5)
T026+T029	6426	(1)	5709	(1)	5849	(1)	5123	(1)	4481	(2)
T026+T030	6560	(1)	5835	(1)	5976	(1)	5250	(1)	4599	(2)
T027+T019	7128	(3)	6396	(11)	6500	(11)	4545	(3)	4758	(9)
T027+T029	6351	(1)	5668	(1)	5825	(1)	5094	(1)	4467	(12)
T027+T030	6495	(1)	5793	(1)	5960	(1)	5223	(1)	4572	(5)
T028+T029	6452	(1)	5737	(1)	5877	(1)	5146	(1)	4510	(2)
T028+T030	6594	(1)	5863	(1)	6006	(1)	5274	(1)	4629	(2)
T031+T032	6501	(1)	5788	(1)	5918	(1)	4219	(3)	4556	(2)

**Notes:**

- (1) 126294 PLTVLLEY 345 137451 LEEDS 3 345 2 | TE44:L/O ATHENS-PV 345 91 secured to 1538 MWs
- (2) 126294 PLTVLLEY 345 137451 LEEDS 3 345 2 | T:34&44\_CE18/UC30 secured to 1538 MWs
- (3) 146754 MDTN TAP 345 146772 SHOEMTAP 138 1 | T:77&76 secured to 707 MWs
- (4) 137451 LEEDS 3 345 137453 N.SCOT99 345 2 | B:N.S.\_77\_TE32 secured to 1538 MWs
- (5) 126294 PLTVLLEY 345 137451 LEEDS 3 345 2 | LEEDS - HURLEY 345 301 secured to 1538 MWs
- (6) 138019 KNICKERBOCKR 345 146143 KNICK\_SCAP 345 SC | T:34&44\_CE18/UC30 secured to 2308 MWs

- (7) 138019 KNICKERBOCKR 345 146143 KNICK\_SCAP 345 SC | OE:COOPC\_34 secured to 2308 MWs
- (8) 138019 KNICKERBOCKR 345 146143 KNICK\_SCAP 345 SC | T:#40&EDIC-PTN secured to 2308 MWs
- (9) 126294 PLTVLLEY 345 137451 LEEDS 3 345 2 | T:96&10 secured to 1538 MWs
- (10) 130650 FRACCSC 345 130750 COOPC345 345 1 | SB:KNICKERBOCKER345 secured to 1721 MWs
- (11) 126294 PLTVLLEY 345 137451 LEEDS 3 345 2 | T:96&4 secured to 1538 MWs
- (12) 126294 PLTVLLEY 345 137451 LEEDS 3 345 2 | SB:LEEDS345\_R301 secured to 1538 MWs

### Incremental UPNY-SENY N-1-1 Thermal Transfer Capability

Maintenance Outage	No Outage	CPV - Rock Tavern 345 kV Line	Marcy - Coopers Corners 345 kV Line	Roseton - East Fishkill 345 kV Line	Athens-Pleasant Valley 345 kV Line
T018+T019	1998	2073	1856	660	1895
T021+T022	1519	1457	1466	449	1248
T021+T023	1466	1408	1418	439	1203
T025+T019	1163	1711	1456	1104	2034
T025+T029	2226	2149	2169	2117	1769
T025+T030	2342	2269	2178	2257	1881
T026+T029	1401	1340	1344	1360	1142
T026+T030	1535	1465	1470	1487	1260
T027+T019	2103	2027	1995	782	1419
T027+T029	1326	1299	1320	1331	1128
T027+T030	1470	1423	1455	1459	1233
T028+T029	1427	1367	1371	1383	1171
T028+T030	1569	1493	1501	1511	1290
T031+T032	1476	1418	1413	455	1217

#### 3.3.5 Performance

For the AC Transmission Need, the performance metric is primarily concerned with maximizing energy transfer from upstate to downstate over Central East and UPNY-SENY interfaces. Table 3-19 and Table 3-20 list the 20-year incremental energy flows across Central East and UPNY-SENY interfaces for each of the projects compared to the pre-project case. The flows are from the MAPS Baseline and CES + Retirement without National CO<sub>2</sub> cases.

**Table 3-19: Baseline 20-year Incremental Energy (GWh)**

Project ID	CENTRAL EAST	UPNY-SENY
T018+T019	28,721	27,500
T021+T022	26,420	24,699
T021+T023	26,050	24,058
T025+T019	89,669	40,642
T025+T029	72,646	27,889
T025+T030	76,301	29,734
T026+T029	23,081	15,115
T026+T030	23,806	15,905
T027+T019	61,551	40,089
T027+T029	55,818	27,524
T027+T030	56,664	28,546
T028+T029	26,361	18,984
T028+T030	26,114	19,485
T031+T032	25,775	31,841

**Table 3-20: CES + Retirement without National CO<sub>2</sub> 20-year Incremental Energy (GWh)**

Project ID	CENTRAL EAST	UPNY-SENY
T018+T019	52,543	34,444
T021+T022	46,260	32,657
T021+T023	45,841	32,024
T025+T019	149,696	57,394
T025+T029	128,379	46,939
T025+T030	134,174	49,003
T026+T029	38,377	22,467
T026+T030	38,812	23,187
T027+T019	104,019	47,535
T027+T029	96,623	36,942
T027+T030	96,878	38,166
T028+T029	49,548	25,394
T028+T030	44,079	24,472
T031+T032	46,711	26,718



### 3.3.6 Production Cost

The NYISO calculated the production costs for the AC Transmission Public Policy Transmission Projects. Each entry in the following tables represents the differences between the pre-project and post-project over the duration of a project’s study period. The study period begins with the in-service date proposed by the Developers and goes out 20 years. Entries with a dollar value are listed in 2018 millions of dollars. The discount rate used to calculate present value is 6.988% consistent with the 2017 CARIS Phase 1 database. The NYISO used scenarios to distinguish projects and to measure the robustness of project performance. Blank entries mean that a certain scenario was not a distinguishing factor for that particular project. In general, a negative value (listed in red) is a more positive outcome for the various metrics (*i.e.*, the system benefits from the reduction in production cost, lower LBMPs, and reduced emissions).

**Error! Reference source not found.** through Table 3-27 shows the various results associated with the production cost analysis for each proposal:

**Table 3-21: NYCA Production Cost Saving in 2018 M\$**

Project ID	Baseline	National CO2 Removed	High Natural Gas	Low Natural Gas	CES + Retirement w/o National CO2
		Based off Baseline			
T018+T019	(236)	(268)	(391)	(182)	(830)
T021+T022	(199)	(223)	(329)	(159)	(714)
T021+T023	(196)				(707)
T025+T019	(513)	(555)			(1,492)
T025+T029	(437)	(517)	(815)	(343)	(1,417)
T025+T030	(457)				(1,461)
T026+T029	(190)				(626)
T026+T030	(195)				(615)
T027+T019	(368)				(1,179)
T027+T029	(331)	(373)	(603)	(255)	(1,129)
T027+T030	(337)				(1,108)
T028+T029	(221)				(840)
T028+T030	(205)				(704)
T031+T032	(206)	(242)	(336)	(168)	(570)

**Table 3-22: Baseline 20-Year Average LBMP Change in 2018 \$M**

Project	West	Genesee	Central	North	Mohawk Valley	Capital	Hudson Valley	Millwood	Dunwoodie	NY City	Long Island
T018+T019	0.43	0.41	0.43	0.44	0.47	(0.02)	(0.07)	(0.15)	(0.19)	(0.16)	(0.12)
T021+T022	0.38	0.38	0.40	0.45	0.45	0.01	(0.08)	(0.17)	(0.20)	(0.16)	(0.13)
T021+T023	0.37	0.38	0.40	0.45	0.45	(0.00)	(0.08)	(0.17)	(0.20)	(0.16)	(0.13)
T025+T019	0.97	0.90	0.84	1.29	1.04	(0.31)	(0.13)	(0.24)	(0.26)	(0.22)	(0.16)
T025+T029	0.95	0.90	0.90	1.30	1.05	(0.28)	(0.12)	(0.24)	(0.26)	(0.21)	(0.17)
T025+T030	0.97	0.92	0.91	1.31	1.06	(0.30)	(0.14)	(0.25)	(0.28)	(0.23)	(0.18)
T026+T029	0.39	0.38	0.40	0.48	0.45	0.01	(0.02)	(0.10)	(0.14)	(0.10)	(0.08)
T026+T030	0.41	0.39	0.40	0.48	0.45	0.02	(0.02)	(0.10)	(0.14)	(0.10)	(0.09)
T027+T019	0.75	0.71	0.70	0.84	0.79	(0.26)	(0.19)	(0.29)	(0.32)	(0.27)	(0.20)
T027+T029	0.67	0.66	0.67	0.83	0.78	(0.28)	(0.16)	(0.26)	(0.29)	(0.24)	(0.18)
T027+T030	0.69	0.67	0.68	0.83	0.78	(0.27)	(0.16)	(0.26)	(0.29)	(0.24)	(0.18)
T028+T029	0.43	0.44	0.46	0.58	0.55	(0.13)	(0.08)	(0.17)	(0.20)	(0.16)	(0.12)
T028+T030	0.43	0.41	0.42	0.52	0.49	(0.09)	(0.08)	(0.17)	(0.20)	(0.16)	(0.12)
T031+T032	0.37	0.37	0.38	0.44	0.46	0.06	(0.16)	(0.27)	(0.30)	(0.25)	(0.19)

**Table 3-23: CES + Retirement Without National CO<sub>2</sub> 20-Year Average LBMP Change in 2018 \$M**

Project	West	Genesee	Central	North	Mohawk Valley	Capital	Hudson Valley	Millwood	Dunwoodie	NY City	Long Island
T018+T019	1.65	1.89	1.96	2.43	2.24	(1.18)	(0.15)	(0.63)	(0.84)	(0.55)	(0.49)
T021+T022	1.41	1.60	1.66	2.04	1.92	(0.66)	(0.10)	(0.57)	(0.79)	(0.49)	(0.46)
T021+T023	1.39	1.60	1.65	2.06	1.92	(0.71)	(0.11)	(0.57)	(0.79)	(0.49)	(0.46)
T025+T019	3.09	3.58	3.58	4.80	4.06	(2.31)	(0.62)	(1.19)	(1.37)	(0.92)	(0.83)
T025+T029	2.94	3.42	3.47	4.64	3.92	(2.21)	(0.65)	(1.22)	(1.40)	(0.93)	(0.85)
T025+T030	3.05	3.55	3.60	4.82	4.06	(2.34)	(0.70)	(1.27)	(1.45)	(0.97)	(0.88)
T026+T029	1.26	1.41	1.47	1.74	1.70	(0.31)	0.02	(0.46)	(0.69)	(0.41)	(0.37)
T026+T030	1.25	1.38	1.44	1.69	1.66	(0.32)	0.02	(0.45)	(0.68)	(0.41)	(0.37)
T027+T019	2.40	2.78	2.83	3.63	3.21	(1.91)	(0.46)	(0.97)	(1.17)	(0.80)	(0.72)
T027+T029	2.27	2.67	2.74	3.56	3.15	(1.82)	(0.43)	(0.96)	(1.15)	(0.77)	(0.71)
T027+T030	2.25	2.63	2.69	3.50	3.09	(1.91)	(0.45)	(0.96)	(1.15)	(0.77)	(0.72)
T028+T029	1.58	1.85	1.94	2.44	2.26	(0.76)	(0.10)	(0.59)	(0.80)	(0.50)	(0.46)
T028+T030	1.38	1.55	1.61	1.95	1.87	(0.42)	(0.02)	(0.50)	(0.73)	(0.44)	(0.40)
T031+T032	1.38	1.59	1.68	2.08	2.02	(1.62)	(0.14)	(0.62)	(0.83)	(0.62)	(0.55)

**Table 3-24: Baseline 20-Year Total Load Payment Change in 2018 \$M**

Project	West	Genesee	Central	North	Mohawk Valley	Capital	Hudson Valley	Millwood	Dunwoodie	NY City	Long Island
T018+T019	143	92	156	40	131	(16)	(42)	(11)	(32)	(238)	(77)
T021+T022	127	85	147	41	106	45	(7)	(12)	(33)	(234)	(78)
T021+T023	124	84	147	41	106	43	(7)	(11)	(32)	(232)	(78)
T025+T019	320	189	301	119	344	(128)	(110)	(16)	(42)	(305)	(93)
T025+T029	303	186	312	120	325	(111)	(24)	(15)	(40)	(282)	(93)
T025+T030	310	190	318	121	331	(117)	(45)	(16)	(42)	(301)	(97)
T026+T029	128	84	145	44	135	6	5	(7)	(23)	(163)	(55)
T026+T030	134	86	147	44	135	10	(2)	(7)	(23)	(165)	(56)
T027+T019	241	149	246	78	255	(125)	(74)	(19)	(49)	(358)	(108)
T027+T029	216	139	235	77	251	(131)	(28)	(17)	(43)	(319)	(100)
T027+T030	222	140	237	77	251	(130)	(37)	(17)	(45)	(323)	(98)
T028+T029	139	94	163	54	173	(57)	(8)	(11)	(31)	(227)	(71)
T028+T030	139	89	152	48	165	(47)	(16)	(11)	(31)	(231)	(74)
T031+T032	122	81	140	39	123	26	(24)	(18)	(44)	(326)	(103)

**Table 3-25: CES + Retirement without National CO2 20-Year Total Load Payment Change in 2018 \$M**

Project	West	Genesee	Central	North	Mohawk Valley	Capital	Hudson Valley	Millwood	Dunwoodie	NY City	Long Island
T018+T019	496	359	609	215	339	(243)	(36)	(36)	(116)	(627)	(204)
T021+T022	429	310	522	181	286	(80)	(2)	(32)	(110)	(564)	(194)
T021+T023	424	309	521	182	287	(95)	(3)	(33)	(109)	(569)	(195)
T025+T019	903	649	1,083	425	652	(512)	(150)	(66)	(174)	(934)	(307)
T025+T029	856	620	1,048	411	623	(486)	(100)	(66)	(177)	(934)	(314)
T025+T030	885	642	1,085	428	643	(518)	(121)	(69)	(182)	(967)	(323)
T026+T029	387	277	469	154	273	(26)	19	(26)	(97)	(493)	(160)
T026+T030	385	272	460	150	268	(27)	13	(26)	(97)	(491)	(161)
T027+T019	705	509	861	322	509	(441)	(92)	(54)	(152)	(833)	(275)
T027+T029	665	489	832	316	500	(424)	(59)	(53)	(149)	(805)	(275)
T027+T030	660	481	815	310	490	(448)	(68)	(53)	(150)	(807)	(277)
T028+T029	473	351	603	217	361	(147)	1	(33)	(109)	(562)	(188)
T028+T030	419	301	510	173	309	(67)	8	(29)	(101)	(514)	(169)
T031+T032	413	299	520	184	303	(349)	1	(34)	(109)	(653)	(217)

**Table 3-26: NYCA 20-Year Total Demand Congestion Change in 2018 M\$**

Project ID	Baseline	National CO2 Removed	High Natural Gas	Low Natural Gas	CES + Retirement w/o National CO2
		Based off Baseline			
T018+T019	(1,556)	(1,991)	(2,578)	(1,405)	(6,863)
T021+T022	(1,253)	(1,597)	(2,126)	(1,089)	(5,629)
T021+T023	(1,233)				(5,661)
T025+T019	(2,959)	(3,820)			(11,851)
T025+T029	(2,675)	(3,598)	(4,707)	(2,364)	(11,363)
T025+T030	(2,801)				(11,837)
T026+T029	(1,355)				(4,831)
T026+T030	(1,385)				(4,749)
T027+T019	(2,576)				(9,633)
T027+T029	(2,333)	(3,003)	(3,958)	(2,088)	(9,292)
T027+T030	(2,369)				(9,194)
T028+T029	(1,683)				(6,499)
T028+T030	(1,575)				(5,336)
T031+T032	(1,369)	(1,935)	(2,636)	(1,184)	(5,733)

**Table 3-27: System 20-Year Total CO<sub>2</sub> Emission Change (1000 tons)**

Project ID	Baseline	National CO2 Removed	High Natural Gas	Low Natural Gas	CES + Retirement w/o National CO2
		Based off Baseline			
T018+T019	1,150	(2,476)	441	678	(4,686)
T021+T022	1,111	(1,285)	(240)	628	(7,298)
T021+T023	1,306				(8,235)
T025+T019	3,239	5,215			(15,416)
T025+T029	7,570	7,499	20,356	4,160	(11,656)
T025+T030	8,424				(11,524)
T026+T029	2,211				(6,231)
T026+T030	1,943				(6,908)
T027+T019	2,474				(10,661)
T027+T029	2,616	1,163	8,629	863	(9,429)
T027+T030	2,128				(10,184)
T028+T029	3,758				(4,056)
T028+T030	2,074				(5,901)
T031+T032	(1,724)	(6,475)	(4,868)	(2,621)	(8,814)

### 3.3.7 ICAP Benefits

*[To be filled later]*

### 3.3.8 Property Rights and Routing

For each project, the NYISO reviewed whether the Developer already possesses the right of way (ROW) necessary to implement the project or has specified a plan or approach for determining routing and acquiring property rights. In assessing the availability of real property rights for each proposed project, the NYISO relied on its independent consultant, SECO, along with the knowledge of the New York State Department of Public Service (DPS) and information provided by the Transmission Owner(s) in the applicable Transmission District(s). The NYISO and SECO also reviewed, in consultation with the DPS, transmission routing studies provided by Developers that identified potential routing alternatives and land-use or environmentally sensitive areas, such as wetlands, agriculture, and residential areas.

SECO reviewed the Developers' property rights acquisition plans associated with the proposals using the Developers' projects information submitted in the Viability and Sufficiency Assessment process and responses provided by Developers to requests for additional information relating to property rights and transmission siting. Additionally, the NYISO and SECO consulted with a third-party consultant to understand the viability of Developer's property rights acquisition plans, and determined that there are no legal obstacles to incumbent and non-incumbent Developer obtaining the right to use existing ROWs and easements owned by incumbent utilities at commercially reasonable rates.

SECO found that the following items were common among all proposals in their property rights:

- All Developers propose to use existing ROW for their transmission facilities.
- Some additional real estate is required for new substation construction at Princetown Junction:
  - NextEra's project (T021) proposes a new Greenfield site located between Princetown Junction and Rotterdam, and has an option to purchase the real estate for the substation.
  - ITC's project (T031) proposes a larger substation at Princetown Junction compared to the substations proposed by other projects, and will require additional property acquisition.



- All Developers have completed preliminary routing of their proposed lines.
- All Developers have documented plans to obtain site control.

All of the non-incumbent Developers claim the following two common rights to assist in obtaining property:

- Developers cite the December 2015 Order to obtain access to the incumbent utility ROW. In that order, the PSC stated its expectation that incumbent transmission owners will act in a reasonable manner to negotiate access to and usage of their ROWs for the selected transmission project.
- If negotiations with the incumbent transmission owners or the private land owners are unsuccessful, Developers have asserted that they believe that under New York State Law they would have or obtain eminent domain authority after certification of a route by the PSC.

SECO also reviewed Developers' proposals for routing their transmission lines and substations to identify where new property rights would need to be acquired. SECO derived estimates for property from recent comparable sales and tax assessments in the town and county where the property would be located.

All Developers propose to utilize existing incumbent transmission owner-owned property and ROW with the following exceptions:

- All proposals for Segment A with the exception of NAT/NYPA Double Circuit Alternative T027 proposal will likely require the acquisition of easements to meet EMF guidelines in the Princetown Junction to New Scotland corridor. NYPA/NAT's T025 765 kV line conversion also requires additional easements to meet EMF guidelines.
- *De minimis* property rights may be required for construction laydown area and access, tree trimming or danger tree clearing.
- Development of a new substation at the Princetown Junction may require additional property or easements:
  - Proposals T018 and T026 do not include a substation at Princetown Junction.
  - NextEra proposal T021 proposes to build the substation at Princetown Junction on a new Greenfield site for which they have obtained an option to acquire.

- Proposal T031 proposes to tie all seven lines into a substation at Princetown Junction, which will require additional property.
- Proposals T025, T027, and T028 propose smaller substations at Princetown Junction with four breaker ring bus arrangements or GIS equipment that may fit in the existing property. Although it appears that placing these stations on the site is possible, the review team has identified this as a potential risk that will need to be carefully considered and potentially mitigated during detailed engineering and licensing development.

Table 3-28 and

Table 3-29 show a summary of SECO’s review on property rights acquisitions and the property requirements to mitigate EMF for all the Segment A and Segment B proposals. A detailed analysis on property right analysis and routing can be found in Appendix D of this study report.

**Table 3-28: Summary of Property Rights Acquisitions & Requirements – Segment A**

Project ID	Summary of Property Rights Acquisition	Substation Property Requirements				
		Substation	County	Owner		EMF Mitigation (Width in Feet)
				Incumbent Utility (Acres)	Non-Utility (Acres)	
T018	<ul style="list-style-type: none"> <li>• NGrid completed routing study</li> <li>• Project ROW is fee-owned by, or under the control (via easement or permit) of, NGrid.</li> <li>• NGrid will transfer ownership of all assets to Transco.</li> </ul>	Rotterdam Substation (Extension)	Schenectady	2.6	0	10
T021	<ul style="list-style-type: none"> <li>• NextEra has an option to purchase property for the proposed Princetown Substation.</li> <li>• Would use existing ROW, owned by the incumbent utility.</li> <li>• Has a well-documented plan to obtain property and site control</li> </ul>	Princetown Substation (New)	Schenectady	0	24.0	10
T025	<ul style="list-style-type: none"> <li>• NAT/NYPA would use existing ROW, owned by the incumbent utility.</li> <li>• Does not yet possess the required ROWs.</li> <li>• Has a well-documented plan to obtain property and site control</li> <li>• NYPA to lead negotiations with the NYTO’s in negotiating and obtaining easements.</li> </ul>	Knickerbocker Substation (New)	Rensselaer	30.0	0	8 - 25
		Princetown Substation (New)	Schenectady	3.0	0	
		Rotterdam Substation (New)	Schenectady	7.5	0	
T026	Same as T025	Rotterdam Substation (New)	Schenectady	7.5	0	10
T027	Same as T025	Edic Substation (Extension)	Oneida	1.3	0	0
		Princetown Substation (New)	Schenectady	3.0	0	
		Rotterdam Substation (New)	Schenectady	7.5	0	

T028	Same as T025	Princeton Substation (New)	Schenectady	3.0	0	10
		Rotterdam Substation (New)	Schenectady	7.5	0	
T031	<ul style="list-style-type: none"> <li>ITC would use existing ROW, owned by the incumbent utility.</li> <li>Would likely require additional property to construct the proposed Princetown Substation.</li> <li>Has a well-documented plan to obtain property and site control.</li> </ul>	Princeton Substation (New)	Schenectady	5.5	2.6	10
		Rotterdam Substation (Extension)	Schenectady	2.5	0	

**Table 3-29: Summary of Property Rights Acquisitions & Requirements – Segment B**

Project ID	Summary of Property Rights Acquisition	Substation Property Requirements				
		Substation	County	Owner		EMF Mitigation (Width in Feet)
				Incumbent Utility (Acres)	Non-Utility (Acres)	
T019	<ul style="list-style-type: none"> <li>NGrid completed routing study</li> <li>Project ROW is fee-owned by, or under the control (via easement or permit) of, NGrid.</li> <li>NGrid will transfer ownership of all assets to Transco.</li> </ul>	Knickerbocker Substation (New)	Rensselaer	14	0	0
		Churchtown Substation (Extension)	Columbia	11.4	0	
		Pleasant Valley Substation (Extension)	Dutches	1.4	0	
T022	<ul style="list-style-type: none"> <li>NextEra have an option to purchase property for the proposed Princetown Substation.</li> <li>Would use existing ROW, owned by the incumbent utility.</li> <li>Has a well-documented plan to obtain property and site control</li> </ul>	Knickerbocker Substation (New)	Rensselaer	14	0	0
		Churchtown Substation (Extension)	Columbia	5.5	0	
T023	Same as T022	Knickerbocker Substation (New)	Rensselaer	14	0	0
		Churchtown Substation (Extension)	Columbia	5.5	0	
T029	<ul style="list-style-type: none"> <li>NAT/NYPA would use existing ROW, owned by the incumbent utility.</li> <li>Does not yet possess the required ROWs.</li> <li>Has a well-documented plan to obtain property and site control</li> <li>NYPA to lead negotiations with the NYTO's in negotiating and obtaining easements.</li> </ul>	Knickerbocker Substation (New)	Rensselaer	14	0	0
		Churchtown Substation (Extension)	Columbia	11.4	0	
T030	Same as T029	Knickerbocker Substation (New)	Rensselaer	14	0	0
		Churchtown Substation (Extension)	Columbia	11.4	0	
T032	<ul style="list-style-type: none"> <li>ITC would use existing ROW, owned by the incumbent utility.</li> <li>Would likely require additional property to construct the proposed Princetown Substation.</li> <li>Has a well-documented plan to obtain property and site control.</li> </ul>	Knickerbocker Substation (New)	Rensselaer	20	0	0
		Churchtown Substation (Extension)	Columbia	0.3	0	

### 3.3.9 Potential Construction Delay

The NYISO evaluated Developers' schedules for project completion first as part of the Viability and Sufficiency Assessment to determine whether projects were feasible. During the evaluation stage, the NYISO conducted a more in-depth analysis of the project schedules of the viable and sufficient transmission projects to determine the accuracy of schedules provided to the NYISO and the likelihood of project delay. For this purpose, the NYISO used the more detailed engineering and design information as required in Section 31.4.8.1.7 of the OATT.

The NYISO contracted SECO to evaluate the schedules for each proposed Public Policy Transmission Project for potential construction delay. SECO focused on the proposed durations of the tasks in each Developer's project schedule. Based on this evaluation, SECO independently determined its own time estimates for each project schedule and compared it to the Developer's proposed project duration. SECO conducted this evaluation based on its expertise and experience with transmission lines and substation projects in New York State and using comparisons to actual projects that completed the Article VII process. Appendix D provides greater details on the evaluation of the project schedules.

Summary results of the evaluation of the project schedules are presented in Table 3-30. The independent minimum duration was calculated using what SECO determined to be the minimum duration for Article VII application preparation, the anticipated time for the Article VII approval process, ROW procurement where significant, and the anticipated time for construction of the project. The independent minimum duration is the best case and is shown for comparative purposes. The independent duration includes some float to the schedule to establish a reasonable schedule recognizing the potential for minor delays for the purpose of determining the in-service date once a project is selected. SECO recommended adding four (4) months to each minimum schedule to account for the following float:

- Two months to the construction schedule for each proposal to account for typical slippage of construction activities (*i.e.*, potential weather events, delays if construction crews are needed to respond and provide storm support, unanticipated material and equipment issues, and inability to obtain outages on a timely basis); and
- Two months to the schedule for licensing and permitting activities between the PSC issuing the Article VII Certificate and the submittal of the Environmental Management & Construction Plan to account for possible delays in submitting the EMCP should the PSC require changes to the plan submitted in the application.

**Table 3-30: Results of Evaluation of the Projects Schedules**

Segment	Project ID	Independent Minimum Duration Estimate: Months	Independent Duration Estimate: Months
A	T018	48	52
	T021	48	52
	T025	50	54
	T026	48	52
	T027	51	55
	T028	48	52
	T031	48	52
B	T019	45	49
	T022	43	47
	T023	45	49
	T029	45	49
	T030	45	49
	T032	47	51

**3.3.10 Potential Risks**

The NYISO contracted SECO to evaluate any potential risks associated with the individual proposals that might affect the project completion as per schedule in addition to those identified by the developers in their proposals. The significant drivers to the project risks considered were:

- Article VII review approval process and potential environmental issues
- Procurement of major equipment
- Real Estate acquisition
- Construction

Section 4.3 of the SECO’s report attached as Appendix C to this report provides a detailed risk analysis performed by SECO. It also shows all of the risks in common for all the projects and also project specific risks that may distinguish each project from the other projects.

In addition, the Public Policy Transmission Planning Process considers the status and results of the interconnection studies in evaluating and selecting the more efficient or cost effective project. All of the AC Transmission projects are currently being evaluated in the interconnection process. Violations could be identified such as transfer limit degradation between NYISO and ISO-NE. The potential Network Upgrade Facilities to address the violations and associated cost will be

considered in the evaluation and selection of the AC Transmission projects.

### **3.4 Consequences for Other Regions**

In addition to its evaluation to identify the more efficient or cost-effective solution to the identified Public Policy Transmission Need, the NYISO also coordinates with neighboring regions to identify the consequences, if any, of the proposed transmission solutions on the neighboring regions using the respective planning criteria of such regions.

Through the NYISO's Transmission Interconnection Procedures under Attachment P to the OATT and the associated System Impact Studies currently in progress, the NYISO is consulting with the ISO-NE concerning any potential impacts due to the proposed AC Transmission Need Projects. Preliminary results from the System Impact Studies identified the potential for impacts on the neighboring system from each of the proposed Segment B projects. Each of the proposed Segment B projects potentially causes a negative impact on the export capability between the NYISO and its neighboring system. The proposed interconnection of the Q#444 Cricket Valley Energy Center II in conjunction with each of the proposed Segment B projects worsened the potential export capability degradation between the NYISO and its neighboring system. These impacts are considered material. Therefore in accordance with the Transmission Expansion and Interconnection Procedures, the necessary Network Upgrade Facilities will be identified in the System Impact Study to mitigate these potential issues. Current estimates include the cost of mitigating potential violations identified, such as the transfer limit degradation from NYISO to ISO-NE for all Segment B projects

### **3.5 Impact on Wholesale Electricity Markets**

The NYISO evaluates the impact of proposed viable and sufficient Public Policy Transmission Projects on its wholesale electricity markets, using economic metrics including change in production cost, congestion, and load payments.<sup>28</sup> Based on the transfer and production cost analysis results described in Sections 3.3.2 and 3.3.6, the proposed transmission projects all tend to increase the Central East and UPNY-SENY transfer capability and reduce congestion. Therefore, the NYISO staff has determined that the viable and sufficient Public Policy Transmission Projects proposed to address the AC Transmission Need will have no adverse impact on the competitiveness of the New York wholesale electricity markets. Rather, the transmission projects all tend to improve the competitiveness of the NYISO's markets by increasing system transfer capability, allowing more resources and suppliers to compete to serve loads. The review from the NYISO's

---

<sup>28</sup> See OATT Sections 31.4.10 and 31.4.8.1.9.

Market Monitoring Unit is included in Appendix E.<sup>29</sup>

### **3.6 Evaluation of Interaction with Local Transmission Owner Plans**

In its Public Policy Transmission Planning Process, the NYISO is required to review the Local Transmission Owner Plans (LTPs)<sup>30</sup> as they relate to the BPTF to determine whether any proposed regional Public Policy Transmission Project on the BTPF can (i) more efficiently or cost-effectively satisfy any local needs driven by a Public Policy Requirement identified in the LTPs, or (ii) might more efficiently or cost-effectively satisfy the identified regional Public Policy Transmission Need than any local transmission solutions driven by Public Policy Requirements identified in the LTPs.

The Transmission Owners' current LTPs have not identified any needs driven by a Public Policy Requirement in New York State. Accordingly, the NYISO determined that there are no proposed regional Public Policy Transmission Projects that could more efficiently or cost-effectively satisfy a need driven by a Public Policy Requirement identified in an LTP. In the absence of any public policy needs in the LTPs, it is also not necessary for the NYISO to determine whether a regional transmission project would more efficiently or cost effectively satisfy such a transmission need on the BPTF than a local transmission solution.

---

<sup>29</sup> See OATT Section 31.4.11.1 (“[T]he draft report will be provided to the Market Monitoring Unit for its review and consideration”).

<sup>30</sup> See Section 31.2.1.1.2.1 of the OATT.

## **4. Conclusions and Recommendations**

### **4.1 Summary of Project Evaluations**

### **4.2 Ranking**

### **4.3 Selection Recommendation**

### **4.4 Next Steps**



## Appendices

**Appendix A – Public Policy Transmission Planning Process Glossary**

**Appendix B – AC Transmission Public Policy Transmission Planning Need Viability and Sufficiency Assessment**

**Appendix C – Phase 2 Selection Assumptions**

**Appendix D – SECO Report**

**Appendix E – Market Monitoring Unit Report**

**Appendix F – AC Transmission Project Proposals detailed descriptions**