Operations Performance Metrics Monthly Report









August 2012 Report

Operations & Reliability Department New York Independent System Operator



Table of Contents

- Highlights
 - Operations Performance

• Reliability Performance Metrics

- Alert State Declarations
- Major Emergency State Declarations
- IROL Exceedance Times
- Balancing Area Control Performance
- Reserve Activations
- Disturbance Recovery Times
- Load Forecasting Performance
- Wind Forecasting Performance
- Lake Erie Circulation and ISO Schedules

Market Performance Metrics

- RTM Congestion Residuals Monthly Trend
- RTM Congestion Residuals Daily Costs
- RTM Congestion Residuals Event Summary
- RTM Congestion Residuals Cost Categories
- DAM Congestion Residuals Monthly Trend
- DAM Congestion Residuals Daily Costs
- DAM Congestion Residuals Cost Categories
- NYCA Unit Uplift Components Monthly Trend
- NYCA Unit Uplift Components Daily Costs
- Local Reliability Costs Monthly Trend & Commitment Hours
- TCC Monthly Clearing Price with DAM Congestion
- ICAP Spot Market Clearing Price
- UCAP Awards





August 2012 Operations Performance Highlights

- Peak load of 30,989 MW occurred on 8/3/2012 HB 15
- All-time summer capability period peak load of 33,939 MW occurred on 8/2/2006 HB13
- 35 hours of Thunder Storm Alerts were declared
- No hours of NERC TLR level 3 curtailments




Reliability Performance Metrics












For IROL exceedances leading to Major Emergency State declarations, the maximum IROL exceedence time is identified. IROL exceedances of less than thirty minutes are considered NERC compliant.








NYISO Reserve Activations are indicators of the need to respond to unexpected operational conditions within the NYISO Area or to assist a neighboring Area (Shared Activation of Reserves) by activating an immediate resource and demand balancing operation.









<u>Hourly Error MW</u> - Absolute value of the difference between the hourly average actual load demand and the average hour ahead forecast load demand.


<u>Average Hourly Error %</u> - Average value of the ratio of hourly average error magnitude to hourly average actual load demand.

<u>Day-Ahead Average Hourly Error %</u> - Average across all hours of the month of the absolute value of the difference between actual load demand and the Day-Ahead forecast load demand, divided by the actual load demand.

























Market Performance Metrics





Day's investigated in August: 3,5,6,9,11,17,27

		August: 3,5,6,9,11,17,27			
Event	Date (yyyymm		Description		
	8/3/2012		Derate FreshKills-Willow Brook 345kV (#29212)		
	8/3/2012	, ,	Uprate Gowanus-GoethalsS 345kV (#26)		
	8/3/2012		Uprate Gowanus-Greenwood 138kV (#42232)		
	8/3/2012		DerateGowanus-Greenwood 138kV (#42232)		
			Derate Niagara-Packard 230kV (#62) for Vo TWR:Niagara 61&64		
	8/3/2012 14,15		Derate Leeds-Pleasant Valley 345kV (#92) for Vo Athens-Pleansant Valley 345kV (#91)		
	8/3/2012		Derate Scriba-Volney 345kV (#20) for I/o Scriba-Volney 345kV (#21)		
	8/3/2012		Lake Erie Clockwise Circulation, DAM-RTM exceeds 125MW; Leeds-Pleasant Valley (#92)		
	8/5/2012		Thuderstorm Alert		
	8/5/2012	14-21	Derate FreshKills-Willow Brook 345kV (#29212)		
	8/5/2012		Uprate Gowanus-GoethalsS 345kV (#26)		
	8/5/2012	14-19,21	Derate Scriba-Volney 345kV (#20) for I/o Scriba-Volney 345kV (#21)		
	8/5/2012	14-17,19-21	Derate Sprainbrook-EastGarden City 345kV (#Y49)		
8/5/2012			Derate Gowanus-Greenwood 138kV (#42232)		
	8/6/2012		Forced outage East Garden City 345/138kV (#BK1)		
	8/6/2012		Uprate Central East		
	8/6/2012	13,14	Uprate Farragut-Hudson Avenue 138kV (#32077)		
	8/6/2012	9,11,12,16,21	Derate FreshKills-Willow Brook 345kV (#29212)		
	8/6/2012		Uprate Gowanus-GoethalsS 345kV (#26)		
	8/6/2012		Derate Gowanus-Greenwood 138kV (#42232)		
	8/6/2012		Derate Greenwood-Kent Avenue 138kV (#31232) for l/o Vernon-Greenwood 138kV (#31231)		
	8/6/2012	16	Derate Leeds-Pleasant Valley 345kV (#92) for Vo Athens-Pleansant Valley 345kV (#91)		
	8/6/2012	9,11,12	Derate Scriba-Volney 345kV (#20) for I/o Scriba-Volney 345kV (#21)		
	8/6/2012		IESO_AC - NY Scheduling Limit		
	8/6/2012	16	Lake Erie Clockwise Circulation, DAM-RTM exceeds 125MW; Leeds-Pleasant Valley (#92)		
	8/9/2012		Thuderstorm Alert		
	8/9/2012		Derate FreshKills-Willow Brook 345kV (#29212)		
	8/9/2012		Uprate Gowanus-GoethalsS 345kV (#26)		
	8/9/2012 15,21,22 Derate Gowanus-Greenwood 138kV (#42232)				
	8/9/2012		Uprate Scriba-Volney 345kV (#20) for I/o Scriba-Volney 345kV (#21)		
	8/9/2012		IESO_AC - NY Scheduling Limit		
	8/11/2012	17,19,20	Early Return to Service Dunwoodie-Shore Road 345kV (#Y50)		
	8/11/2012	4,13-17	Early Return to Service Greenwood-Kent Ave. 138kV (#31232)		
	8/11/2012	2,3,9,10,12,14	Uprate Gowanus-GoethalsS 345kV (#26)		
	8/11/2012	12	IESO_AC DNI Ramp Limit		
	8/17/2012 17-23 Thuderstorm Alert				
	8/17/2012	17-23	23 Derate FreshKills-Willow Brook 345kV (#29212)		
	8/17/2012	8/17/2012 17,19,20-23 Derate Gowanus-Greenwood 138kV (#42232)			
	8/17/2012	16	NYCA DNI Ramp Limit		
	8/27/2012		Uprate Gowanus-GoethalsS 345kV (#26)		
	8/27/2012	8,9,20	Uprate Scriba-Volney 345kV (#20) for I/o Scriba-Volney 345kV (#21)		
	8/27/2012	21	IESO_AC DNI Ramp Limit		




Real-Time Balancing Market Congestion Residual (Uplift Cost) Categories


Cost Assignment Events Types Event Examples <u>Category</u> Storm Watch Thunderstorm Alert (TSA) TSA Activations Zone J **Unscheduled Transmission Outage** Market-wide Reduction in DAM to RTM transfers Forced Line Outage, related to unscheduled transmission **Unit AVR Outages** Interface Derate - NYISO Security Interface Derates due to Market-wide Reduction in DAM to RTM transfers not related to transmission outage **RTM** voltages Interface Derate - External Security Market-wide Reduction in DAM to RTM transfers TLR Events, related to External Control Area **External Transaction** Security Events Curtailments DAM to RTM Clockwise Unscheduled Loop Flows Market-wide Changes in DAM to RTM Lake Erie Loop Flows unscheduled loop flows impacting **NYISO Interface transmission** greater than 125 MW constraints

Monthly Balancing Market Congestion Report Assumptions/Notes

- 1) Storm Watch Costs are identified as daily total uplift costs
- 2) At a minimum those days with \$100 K/HR, shortfall of \$200 K/Day or more, or surplus of \$100 K/Day or more are investigated
- 3) Uplift costs associated with multiple event types are apportioned equally by hour
- 4) Investigations began with Dec 2008. Prior months are reported as Not Investigated.









Day-Ahead Market Congestion Residual Categories						
<u>Category</u> NYTO Outage Allocation	<u>Cost Assignment</u> Responsible TO	<u>Events Types</u> Direct allocation to NYTO's responsible for transmission equipment status change.	Event Examples DAM scheduled outage for equipment modeled inservice for the TCC Auction.			
Unscheduled Loop Flows	All TO by Monthly Allocation Factor	Residual impact of Lake Erie circulation, MW difference between the DAM and TCC Auction.	Lake Erie Loop Flow Assumptions			
External Outage Allocation	All TO by Monthly Allocation Factor	Direct allocation to transmission equipment status change caused by change in status of external equipment.	Tie line required out-of- service by TO of neighboring control area.			
Central East Commitment Derate	All TO by Monthly Allocation Factor	Reductions in the DAM Central East_VC limit as compared to the TCC Auction limit, which are not associated with transmission line outages.				



