



# **Generator Deactivation Assessment Monroe Livingston LFGE**

**A Report by the  
New York Independent System Operator**

**August 1, 2019**

## Purpose

On May 10, 2019 the New York Independent System Operator, Inc. (“NYISO”) determined that WM Renewable Energy, LLC (“WM Renewable Energy”) had submitted a complete Generator Deactivation Notice for the proposed retirement of the Monroe Livingston LFGE (“Monroe Livingston”) generator. WM Renewable Energy reported that it intends to deactivate the 2.4 MW (nameplate) generator on or about June 30, 2019.

Pursuant to Section 38.3.5 of the NYISO Open Access Transmission Tariff (“OATT”), the NYISO performed resource adequacy and, in coordination with National Grid, LLC (“National Grid”), transmission security analyses of the New York Control Area (“NYCA”) system to determine whether a Generator Deactivation Reliability Need (a “Need”) would result from the deactivation of Monroe Livingston. The NYISO and National Grid timely completed this analysis within the 90-day period starting from May 10, 2019, which is the Generator Deactivation Assessment Start Date (by August 8, 2019). The Generator Deactivation Process ends if the assessment does not identify a Need or if the Need can be timely addressed during the next Reliability Needs Assessment in the NYISO’s biennial reliability planning process. If the NYISO finds a Need, then the NYISO follows the process for soliciting and selecting a solution stated in Sections 38.3.6 – 38.10.5 of the OATT.

## Assumptions

The NYISO evaluated the period five years from the conclusion of the 365-day notice period (May 10, 2020 – May 10, 2025) (the “Study Period”) using the most recent reliability planning process base case. In accordance with the Reliability Planning Process base case inclusion rules<sup>1</sup>, generation and transmission projects are added to the base case if they have met significant milestones such that there is a reasonable expectation of completion of the project. Significant changes to the proposed assessment assumptions, as compared to the those used for the 2019-2028 Comprehensive Reliability Plan (CRP) include: (i) the AC Transmission Segment A

---

<sup>1</sup> NYISO Reliability Planning Process Manual, July 5, 2018

Double Circuits, AC Transmission New York Energy Solution Segment B, which are expected to enter into service in December 2023, and (ii) all other New York Transmission Owner firm Local Transmission Plans listed in the 2019 Load and Capacity Data Report (“Gold Book”) with the exception of the NYSEG Coopers Corners transformers. The NYISO used the load forecast consistent with the 2019 Load and Capacity Data Report (“Gold Book”)<sup>2</sup>.

The NYISO provided stakeholders with its shared governance process information on the modeling assumptions employed in conducting this assessment. Details of the study assumptions were originally reviewed with stakeholders at the June 10, 2019 joint Electric System Planning Working Group (ESPWG)/Transmission Planning Advisory Subcommittee (TPAS)/Interconnection Project Facilities Study Working Group (IPFSWG) meeting. The meeting materials are posted on the NYISO’s public website<sup>3</sup>.

## Findings

This assessment finds that reliability criteria would be met without Monroe Livingston throughout the Study Period under the assumed and forecasted base case system conditions. The NYISO assessed the resource adequacy of the overall NYCA system, per the one-day-in-ten-years (0.1 per year) Loss of Load Expectation (“LOLE”) criterion, which measures the probability of disconnecting firm load due to a resource deficiency. This assessment finds that without Monroe Livingston the resource adequacy criterion is met throughout the Study Period.

Additionally, the NYISO performed a transmission security assessment for the Bulk Power Transmission Facilities (“BPTF”) and National Grid performed a transmission security assessment of its non-BPTFs. The NYISO reviewed and verified the analysis performed by National Grid. Without Monroe Livingston, no transmission security-related Need was identified in the Study Period.

---

<sup>2</sup> This Monroe Livingston Generator Deactivation Assessment utilizes the 2019 Gold Book baseline summer peak load forecast.

<sup>3</sup>

[https://www.nyiso.com/documents/20142/6987817/03\\_2019GDA\\_Steuben\\_MonroeLvgnstn\\_AuburnSS\\_Hudson4\\_KeyAssumptions\\_vFinal.pdf/1835c328-dcd1-aa68-e8b5-c6c37dabaa1e](https://www.nyiso.com/documents/20142/6987817/03_2019GDA_Steuben_MonroeLvgnstn_AuburnSS_Hudson4_KeyAssumptions_vFinal.pdf/1835c328-dcd1-aa68-e8b5-c6c37dabaa1e)

## Conclusions

This assessment does not identify a Generator Deactivation Reliability Need following the deactivation of Monroe Livingston for the Study Period.

WM Renewable Energy, LLC has satisfied the applicable requirements under the NYISO's Generator Deactivation Process to retire the Generators on or after August 9, 2019.<sup>4</sup> This concludes the Generator Deactivation Process.

---

<sup>4</sup> WM Renewable Energy, LLC must complete all required NYISO administrative processes and procedures prior to deactivation. The NYISO's determination in this Generator Deactivation Process does not relieve WM Renewable Energy, LLC of any obligations it has with respect to its participation in the NYISO's markets. If WM Renewable Energy, LLC rescinds its Generator Deactivation Notice or does not deactivate Monroe Livingston by May 9, 2021, then it will be required to submit a new Generator Deactivation Notice in order to deactivate the Generators, and will also be required to repay study costs in accordance with Section 38.14 of the OATT.