

March 24, 2021

Re: Notice of Expedited Deliverability Study 2021-01 Completion

This is to inform you that all Expedited Deliverability Study (EDS) 2021-01 Developers with Deliverable MW (see Attachment A), have accepted their respective Deliverable MW. Therefore, the decision process for EDS 2021-01 has been completed.

If you have any questions, please call me at (518) 356-6025, or send me an e-mail at InterconnectionSupport@nyiso.com.

cc: Iram Iqbal, PSEG-LIPA
Kevin Reardon, NGrid
Class Year 2021 Members

Attachment A

EDS 2021-01 Projects with Deliverable MW¹

PROJECT	Point of Interconnection	Zone	Requested Summer CRIS (MW)	Summer Awarded CRIS (MW)	Winter Awarded CRIS (MW)
Q545 Sky High Solar	Tilden - Tully Center 115 kV	C	20	20	20
Q666 Martin Rd Solar	Arcade - Five Mile 115 kV	A	20	20	20
Q667 Bakerstand Solar	Machias - Maplehurst 34.5 kV	A	20	20	20
Q832 CS Hawthorn Solar	North Troy - Hoosick 115 kV	F	20	20	20
Q833 Dolan Solar	Battenkill - Mohican 115 kV	F	20	20	20
Q865 Flat Hill Solar	Inghams – Valley 46 kV	E	20	20	20
Q885 Grassy Knoll Solar	Watkins Rd - Inghams 115 kV	E	20	20	20

¹ Additional EDS 2021-01 projects were evaluated in the study but the study concluded they had zero Deliverable MW:

PROJECT	Point of Interconnection	Zone	Requested Summer CRIS MW
Q843 NY37 Solar	Coffeen St - West Adams 115 kV	E	20
C.H.I (Dexter) Hydro	Dexter 23 kV	E	5.3
Copenhagen Assoc.	Copenhagen – Carthage 23 kV	E	4.2
West Babylon (PAM-2019-77593)	West Babylon 69 kV	K	9.9