

Ancillary Services Manual Revisions

Brad Garrison

Engineer, Auxiliary Market Operations

New York Independent System Operator

MIWG October 25, 2012 SOAS November 7, 2012



Proposed Changes

- Reactive Power Capability Testing or Demonstration
 - Section 3.6.2
- Regulation Service Qualification and Performance Criteria
 - Section 4.11
 - Section 4.11.2



VSS Testing

- Section 3.6.2
 - TB-155 requires a VSS Supplier to notify the NYISO and TO at least 3 business days prior to performing a VSS test
 - The Manual currently requires VSS Suppliers to notify the NYISO and TO 5 business days prior to at VSS test
 - The Manual also states the NYISO will notify a VSS Supplier of the status of the request three business days prior to the planned test
 - The NYISO proposes to conform the notification requirements in the Manual to those found in TB-155



Regulation Service

- Section 4.11
 - Correcting references to Section 4.13
- Section 4.11.2
 - The NYISO proposes to incorporate language from TB-221 into the Ancillary Services Manual
 - The NYISO may not require a retest of Regulation Service providers that do not meet the scheduling criteria defined in the qualification test, through reasons beyond their control, if sufficient information on the performance of their unit is available from the test results actually achieved




Schedule

- Review changes at October 25th MIWG
- Review changes at November 7th SOAS
- Review changes at November 14th BIC for discussion and vote
- Review changes at November 15th OC for discussion and vote



The New York Independent System Operator (NYISO) is a not-for-profit corporation responsible for operating the state's bulk electricity grid, administering New York's competitive wholesale electricity markets, conducting comprehensive long-term planning for the state's electric power system, and advancing the technological infrastructure of the electric system serving the Empire State.



www.nyiso.com