



Eastern Interconnection Planning Collaborative

EIPC Gas-Electric System Interface Study: Results



Electric-Gas Coordination Working Group

May 19, 2015

LEVITAN & ASSOCIATES, INC.
MARKET DESIGN, ECONOMICS AND POWER SYSTEMS

Acknowledgement and Disclaimer

The EIPC appreciates and acknowledges the support of DOE for the Eastern Interconnection Studies Project

Acknowledgement:

- ◆ This material is based upon work supported by the Department of Energy, National Energy Technology Laboratory, under Award Number DE-OE0000343.

Disclaimers:

- ◆ This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Overview

- ◆ Study Highlights
- ◆ Target 1: Existing Gas Infrastructure Baseline Assessment
- ◆ Target 2: Infrastructure Adequacy Analysis
- ◆ Target 3: Contingency Analysis
- ◆ Target 4: Fuel Assurance Analysis


Study Highlights

- ◆ Character of service: Most generators do not hold firm transportation entitlements, except in TVA and Ontario
- ◆ Gas infrastructure adequacy analysis: Constraints affect generation in ISO-NE, NYISO, EMAAC and SWMAAC
- ◆ Contingency analysis: Most gas contingencies allow time for PPAs to schedule alternative resources
- ◆ Fuel assurance: Dual-fuel capability less expensive than incremental FT in almost all cases

Study Overview – Four Targets

- ◆ Target 1: Develop baseline assessment of natural gas-electric system interfaces, interaction effects, and the current level of coordination between the electric and gas systems
- ◆ Target 2: Evaluate gas infrastructure capability to supply the electric power sector in 2018 and 2023 (Winter and Summer) while serving higher priority RCI loads
- ◆ Target 3: Identify impact of postulated gas and electric contingencies on sustainability of gas-fired generation
- ◆ Target 4: Review operational / planning / economic issues related to fuel assurance through dual-fuel capability and incremental FT


Model Framework



Target 1

Existing Natural Gas-Electric System Interfaces

PPAs and Study Region Pipelines




Study Region Gas Infrastructure

- ◆ 61 interstate pipelines + 1 interprovincial pipeline
- ◆ 10 intrastate pipelines and 75 LDCs serve generators >15 MW
- ◆ 321 conventional underground storage facilities
- ◆ 10 LNG import terminals
- ◆ 78 LNG storage/peak shaving facilities


NYISO Gas Infrastructure

- ◆ 11 interstate pipelines
- ◆ 2 intrastate pipelines and 7 LDCs serve generators >15 MW
- ◆ 26 conventional underground storage facilities in upstate New York
- ◆ 3 LNG storage facilities supporting the New York Facilities System
- ◆ 2 non-FERC jurisdictional production/gathering systems

Pipelines Directly Serving NYISO Generation





LDCs Serving NYISO Generation




North Country	Fillmore Gas	Orange & Rockland
Emkey	NFG Distribution	PSE&G
Central Hudson G&E	NGrid-Long Island	St. Lawrence Gas
Con Edison	NGrid-NYC	Intrastate-Served Generator
Elizabethtown Gas	NGrid-Niagara Mohawk	LDC-Served Generator

Underground Storage Facilities in NYISO




LNG Facilities in NYISO



NYISO Generator Contracting Practices

- ◆ Large majority of NY generators do not have FT
- ◆ NY LDCs offer IT service under negotiated rate schedules
- ◆ NY LDCs require dual fuel capability for generators taking non-firm service
- ◆ A few generators have FT rights for a portion of their fuel requirements
- ◆ Con Edison and NGrid are active assignors in the capacity release market, primarily on Transco and Texas Eastern
- ◆ Capacity releases are short-term and are subject to recall
- ◆ Use of Asset Management Agreements is common


NYISO Generator Contracting Practices



- Algonquin
- CNYOG
- Columbia
- Dominion
- Empire
- Iroquois
- Millennium
- NFG
- Tennessee
- Texas Eastern
- Transco
- Bluestone Gathering
- Laser Gathering
- Emkey
- North Country
- Interstate-Served Generator
- Intrastate-Served Generator
- △ LDC-Served Generator

	Mainline Contract	Dual-Fuel Capable
●	Yes	Yes
●	Yes	No
●	No	Yes
●	No	No


Current NAESB Nomination Cycles



FERC Order No. 809

- ◆ Gas Day start time not changed
- ◆ Timely Cycle nomination deadline pushed back
- ◆ Third Intraday Cycle added
- ◆ Pipelines required to make multi-party FT contracts available if requested by a shipper
- ◆ April 1, 2016 deadline to comply with revised NAESB standards

Revised NAESB Nomination Cycles



Gas-Electric Interface Attributes

	Criterion	NYISO	IESO	ISO-NE	MISO	PJM	TVA
Natural Gas Supply	Gas Supply Portfolio Diversity	Green	Green	Red	Green	Green	Yellow
	Pipeline Connectivity	Green	Yellow	Red	Green	Green	Yellow
	Conventional Storage Deliverability	Yellow	Green	Red	Green	Green	Yellow
	LNG Storage Capability	Yellow	Yellow	Green	Yellow	Yellow	Yellow
Electric-Gas Interface	Firm Transportation Entitlements	Yellow	Green	Red	Yellow	Yellow	Green
	Direct Pipeline Connectivity	Yellow	Green	Green	Green	Green	Green
Electric-Gas Tariff	Pipeline or LDC Penalties	Red	Green	Red	Red	Red	Red
	LDC Provision of Flexible Service	Green	Green	Yellow	Yellow	Green	Yellow
	Active Secondary Market	Green	Red	Green	Green	Green	Yellow

Legend	Favorable Relative to Other PPAs	Neutral	Unfavorable Relative to Other PPAs
---------------	----------------------------------	---------	------------------------------------

Qualitative Assessment – Electric-Gas Tariff

Criterion	NYISO	IESO	ISO-NE	MISO	PJM	TVA
Pipeline or LDC Penalties	Red	Green	Red	Red	Red	Red

- ◆ Pipeline and LDC penalty provisions safeguard against scheduling conduct that harms system integrity or degrades service to firm customers
- ◆ Tariffs require uniform hourly flows and adherence to scheduled quantities
 - Flexibility during normal operating conditions
 - Significant penalties during critical notices incl. OFOs


Target 2

Natural Gas Infrastructure Adequacy
to Serve Electric System Demand


Constraint Identification Approach

- ◆ Develop electric system dispatch model for 2018 and 2023 (Winter & Summer) to estimate hourly gas demands for each generator
- ◆ Combine forecasts of RCI and generator gas demand to represent seasonal coincident peak days
- ◆ Quantify unserved gas demand using optimization modeling of the gas infrastructure network for seasonal peak hours, and allocate the unserved demand to affected generators
- ◆ Quantify frequency and duration (F-D) of pipeline constraints during seasonal daily peak hours
- ◆ Identify gas transportation constraints causing unserved peak hour demand
- ◆ Identify potential mitigation measures to reduce or eliminate transportation constraints affecting generation


Modeling Systems Overview – Electric-Side




Modeling System Overview – Gas-Side




Scenarios and Sensitivities



Transmission Topology



RGDS S0 Resource Mix



HGDS and LGDS Resource Mix Definition


◆ High Gas Demand Scenario

- Increased attrition of selected coal, oil and nuclear units, replaced by new gas-fired units
- “At-risk” units identified by PPAs or selected based on published reports on potential coal retirements


◆ Low Gas Demand Scenario

- Increased penetration of renewables and EE/DR
- Primarily onshore wind added to meet RPS targets and 50% of non-binding renewable targets
- Solar PV added where required by RPS targets
- Lower electric load forecast reflects additional EE/DR


NYISO Resources by Scenario and Year



Gas Price Forecast at Representative Points



Gas Price Forecast (Henry Hub)







Sources: EIA Annual Energy Outlook 2013, Reference Case, High Oil and Gas Resource Case, and Low Oil and Gas Resource Case

Environmental Assumptions

- ◆ Assume that retirement of coal- and oil-fired units in US reflects economic decisions driven by environmental requirements, including MATS, Clean Water Act 316(b), NAAQS, Coal Combustion Residual Rule, Regional Haze, Clean Air Act 111(d), etc.
 - No financial analysis of specific plants was conducted
- ◆ SO₂, NO_x emission allowance prices remain at current CAIR levels; assume no significant change under CSAPR
- ◆ CO₂ emission allowance prices remain consistent with current RGGI program; no change or expansion of footprint


Electric Sector Peak Hour Gas Demand







RCI Demand Forecast Development

- ◆ Based on historical data and published LDC forecasts
 - NYISO: 2013-14 Winter Supply Review (NYPSC Case No. 13-G-0206)
- ◆ Adjustment to coincident peak day values
 - Scaled by ratio of demand on Study Region coincident peak day to non-coincident peak demand
- ◆ Peak hour construct used to test infrastructure against maximum coincident requirements
 - Peak hour generation demand extracted from Aurora
 - Seasonal intraday peak hour percentage of daily demand applied to RCI forecasts


RCI Demand Forecast – Hourly Profile







Total Peak Hour Gas Demand



GPCM Locations in NYISO




NYISO Peak Hour Demand by Location



Infrastructure Expansions Relevant to NYISO

- ◆ Included in RGDS (agreements known by April 2014)
 - Algonquin: AIM, Atlantic Bridge
 - Constitution
 - Empire/NFG: Tuscarora Lateral, Northern Access 2015
 - Tennessee: Connecticut Expansion, Niagara Expansion
 - Texas Eastern: TEAM 2014
 - Transco: Northeast Connector, Rockaway Lateral
- ◆ Included in Sensitivity 13 (announced by April 2014)
 - CNYOG/Stagecoach: Northern Expansion
 - Dominion: New Market
 - Empire/NFG: Central Tioga County, Clermont to Transco, Northern Access 2016
 - Iroquois: South to North
 - Tennessee: Northeast Energy Direct


Constraints: Reference Demand Scenario Winter 2018



“Affected Generation” does not imply a risk to electric reliability


Peak Hour Unserved Generation Gas Demand: 165 MDth (27.6%)

Peak Hour Affected Generation: 21,707 MWh (26.8%)



Legend:
Affected Generation (Orange)
No Affected Generation (Green)


Constraints: High Demand Scenario Winter 2018




“Affected Generation” does not imply a risk to electric reliability

Peak Hour Unserved Generation Gas Demand: 351 MDth (29.4%)

Peak Hour Affected Generation: 45,269 MWh (29.3%)




Constraints: Low Demand Scenario Winter 2018



“Affected Generation” does not imply a risk to electric reliability

Peak Hour Unserved Generation Gas Demand: 64 MDth (17.6%)

Peak Hour Affected Generation: 8,350 MWh (16.6%)




Legend:
Affected Generation (Orange)
No Affected Generation (Green)


Highlights of NYISO Peak Hour Analysis Results

- ◆ Gas infrastructure is constrained in winter 2018 and 2023 under nearly all market conditions and resource mixes
- ◆ Despite large P/L buildout into downstate NY, nearly all pipelines have upstream segments that are fully utilized at the winter peak hour
- ◆ Constrained Transco segments in PJM also affect downstream generators located on Zones J and K
- ◆ Significant dual-fuel capacity mitigates constraints under high daily gas prices (Polar Vortex pricing)
- ◆ Expanded pipeline capacity to accommodate Marcellus materially decreases affected generation


Affected Generation in Winter 2018 Peak Hour



Affected Generation in Winter 2023 Peak Hour



Gas Price Sensitivities - Winter 2018




- Lower gas prices (R3) and higher demand (H0) increase affected generation
- Higher gas prices (L3) and lower demand (L0) decrease affected generation
- Dual fuel capacity in SE New York mitigates impact of gas constraints

Sensitivities Tested

Sensitivity	Description
S1 (R/H/L)	Apply market gas prices for peak winter day
S2 (H/L)	Apply RGDS gas prices to HGDS or LGDS
S3 (R)	Significantly lower delivered gas prices
S5a (R)	Deactivation of add'l coal and nuclear, replaced by wind and solar
S5b (R)	Deactivation of additional coal and nuclear, replaced by imports of Quebec hydropower
S5c (R)	Deactivation of additional coal and nuclear, replaced by EE/DR
S9 (H)	Ontario nuclear units scheduled to be refurbished instead reach the end of life after 2018 and before 2023; Indian Point 2 & 3 retire by end of 2015
S13 (R)	Increased infrastructure to enable additional Marcellus/Utica flows to neighboring PPAs
S14 (R)	Increased gas storage availability and deliverability
S16 (R)	Increased sendout from Canaport and Dstrigas LNG terminals
S18 (R)	High electric load growth
S19 (R)	High industrial gas demand
S23 (R)	Increased LNG exports from U.S. terminals
S30 (R/H)	Bar gas use in dual fuel resources
S31 (R)	Very cold snap with 90/10 electric and RCI gas demands
S33 (R)	S31 + high forced outage rate for coal and oil units
S34 (R)	Maximum gas demand on electric sector
S36 (R)	S33 + Selected nuclear units unavailable
S37 (R)	S13 + Canaport converted to LNG export facility

All NYISO Sensitivities – Winter 2018



Frequency / Duration Analysis


- ◆ F-D of seasonal constraints based on expected demand duration curves
 - Demand duration curves based on peak hour electric model results and historical RCI demand data
 - Duration curves for all demand provided through a constrained segment were combined to determine total daily peak hour demand
 - Daily peak hour conditions were analyzed for three winter and three summer months
 - Interconnection flows accounted for
- ◆ Forecast of RCI and electric gas demand is compared to the maximum flow capability of the segment to determine number and pattern of high congestion days
- ◆ Unserved demand allocated to genco loads

RGDS S0 Winter 2018: Frequency & Duration

Constraint	# of Events	Min. Duration (Days)	Max. Duration (Days)	Total # of Days
Columbia Gas VA/MD	12	1	5	23
Columbia Gas W PA/NY	11	1	5	21
Constitution	5	1	12	25
Dominion Eastern NY	6	1	6	15
Dominion Western NY	1	4	4	4
Dominion Southeast	7	1	12	22
East Tennessee Mainline	7	1	2	9
Eastern Shore	11	1	10	51
Empire Mainline	5	1	12	21
Millennium	4	1	59	83
NB/NS Supply	13	1	20	58
Tennessee Z4 PA	10	1	7	30
Tennessee Z5 NY	2	31	59	90
Texas Eastern M2 PA South	10	1	15	50
Texas Eastern M3 North	10	2	7	39
TransCanada Ontario West	5	1	5	12
TransCanada Quebec	9	1	14	30
Transco Leidy Atlantic	8	2	23	59
Transco Z5	3	1	7	9
Transco Z6 Leidy to 210	5	1	3	8
Union Gas Dawn	2	1	3	4


Frequency-Duration Results Format

Chronological Demand




Note: Charts are examples, not for a specific segment

Descending Demand





Winter 2018: Constitution



# of Events	Min. Duration (Days)	Max. Duration (Days)	Total # of Days
5	1	12	25


- Constitution
- Downstream Pipeline-Served Generator
- Downstream Pipeline → LDC-Served Generator

Winter 2018: Dominion Eastern NY




# of Events	Min. Duration (Days)	Max. Duration (Days)	Total # of Days
6	1	6	15

Winter 2018: Dominion Western NY




# of Events	Min. Duration (Days)	Max. Duration (Days)	Total # of Days
1	4	4	4

Winter 2018: Empire Mainline



# of Events	Min. Duration (Days)	Max. Duration (Days)	Total # of Days
5	1	12	21


Winter 2018: Millennium



- Millennium
- Direct-Connect Generator
- LDC-Served Generator
- Downstream Pipeline-Served Generator
- Downstream Pipeline → LDC-Served Generator


# of Events	Min. Duration (Days)	Max. Duration (Days)	Total # of Days
4	1	59	83

Winter 2018: Tennessee Z4



# of Events	Min. Duration (Days)	Max. Duration (Days)	Total # of Days
10	1	7	30


Winter 2018: Tennessee Z5 NY



# of Events	Min. Duration (Days)	Max. Duration (Days)	Total # of Days
2	31	59	90

- Tennessee Z5 New York
- Direct-Connect Generator
- LDC-Served Generator


Winter 2018: Texas Eastern M2 PA



- Texas Eastern M2 PA South
- Direct-Connect Generator
- LDC-Served Generator
- Downstream Pipeline-Served Generator
- Downstream Pipeline → LDC-Served Generator

# of Events	Min. Duration (Days)	Max. Duration (Days)	Total # of Days
10	1	15	50


Winter 2018: Texas Eastern M3 North



- Texas Eastern M3 North
- Direct-Connect Generator
- LDC-Served Generator
- Downstream Pipeline-Served Generator
- Downstream Pipeline → LDC-Served Generator

# of Events	Min. Duration (Days)	Max. Duration (Days)	Total # of Days
10	2	7	39



Winter 2018: TransCanada Ontario West



- TransCanada Ontario West
- Direct-Connect Generator
- LDC-Served Generator
- Downstream Pipeline-Served Generator
- Downstream Pipeline → LDC-Served Generator

# of Events	Min. Duration (Days)	Max. Duration (Days)	Total # of Days
5	1	5	12

Winter 2018: Transco Leidy Line to Station 210



# of Events	Min. Duration (Days)	Max. Duration (Days)	Total # of Days
5	1	3	8

Risk Factors and Market Dynamics

Market Dynamic and/or Risk Factor	NYISO	IESO	ISO-NE	MISO North/Central	MISO South	PJM	TVA
Transport Deficits	High	Low	High	Low	Low	High	Low
New Pipeline Additions	Low	Low	High	Low	Low	Low	Low
Proximity to Shale Gas	Low	Low	High	Low	Low	Low	Low
Reversal-of-Flow	Low	Low	High	Low	Low	Low	Low
Available Coal Output	Low	Low	Low	High	Low	High	Low
Nuclear Retirements/Delays	Low	High	Low	Low	Low	Low	Low
LNG Import Constraints	Low	Low	High	Low	Low	Low	Low
LNG Export Constraints	Low	Low	Low	Low	Low	Low	Low
Transmission Transfer Limits (Electric)	Low	Low	Low	Low	Low	Low	Low
Generator FT Entitlements	Low	Low	Low	Low	Low	Low	Low
Generator Reliance on Non-Firm Arrangements	High	Low	High	Low	Low	High	Low
Dual Fuel Capability	Low	Low	Low	Low	Low	Low	Low
Renewables Penetration	Low	Low	Low	Low	Low	Low	Low

Legend	Negligible or no impact on affected generation	Low to moderate impact on affected generation	High impact on affected generation
---------------	--	---	------------------------------------

Risk Factors and Market Dynamics

Market Dynamic and/or Risk Factor	NYISO	IESO	ISO-NE	MISO North/Central	MISO South	PJM	TVA
Transport Deficits							

- ◆ Deficits in Capital District, LHV, downstate NY recur throughout peak heating season in response to RCI demand

Market Dynamic and/or Risk Factor	NYISO	IESO	ISO-NE	MISO North/Central	MISO South	PJM	TVA
Generator Reliance on Non-Firm Arrangements							

- ◆ NYISO generators largely rely on non-firm transportation arrangements, particularly on the NYFS

Target 3


Natural Gas and Electric System Contingency Analysis

Contingency Analysis Approach


- ◆ Emphasis is placed on the physical capability of the consolidated network of pipeline and storage infrastructure to maintain service to RCI and generation customers post-contingency
 - Pipeline contractual obligations are not modeled, *i.e.*, on par post-event
 - Generator and RCI demands not differentiated, revealing the outer bound re the post-contingency sustainability of service
- ◆ Identify plants that trip off line due to delivery pressures below 485 psig, and the time interval between the contingency event and the pressure trigger
- ◆ Affected generation following a contingency is **NOT** tantamount to unserved electric energy (mitigation measures are available)
- ◆ MISO South not hydraulically modeled due to its robust available capacity
- ◆ LDC assessments either included in hydraulic models or evaluated by LDC separately

Hydraulic Model Study Region Footprint



Gas-Electric System Interface Study





NYISO Hydraulic Model



NYISO Hydraulic Model – Niagara Area




NYISO Hydraulic Model – Wright Area



Target 3 Gas Demand Profile Inputs


- ◆ Pre- and post-contingency hourly gas use profiles derived from AURORA_{xmp} chronological production cost model based on reference and high gas demand scenarios
- ◆ Sub-hourly ramping profiles developed for each gas-fired technology type
- ◆ Intraday RCI demand profile developed in Target 2 applied to all RCI loads across the Study Region

Sub-Hourly Ramping Profiles by Technology Type




Internal Combustion

— Simplified Model Profile




Small SCGT

— Example Technical Profile
— Simplified Model Profile




Large SCGT

— Example Technical Profile
— Simplified Model Profile



CCGT

— Example Technical Profile
— Simplified Model Profile



Steam Generator

— Example Technical Profile
— Simplified Model Profile


NYISO Generation Gas Demand by Pipeline

Pipeline	RGDS W18 (MDth)	RGDS S18 (MDth)	HGDS W18 (MDth)	HGDS S18 (MDth)	RGDS W23 (MDth)	RGDS S23 (MDth)
Algonquin	0	0	0	2	0	2
Dominion	72	229	208	396	445	396
Empire	138	140	151	142	132	138
Iroquois	56	300	56	401	95	389
Millennium	205	206	222	218	326	300
NFG	11	18	11	23	12	22
Tennessee	156	240	173	269	143	223
Total	637	1,133	820	1,450	1,153	1,469

Note: Does not include NYFS demands


Baseline Hydraulic Results: RGDS 2018

- ◆ Prior to any contingency, baseline pressure and flow evaluated within each PPA-specific consolidated model to determine whether full gas volumes are deliverable



Note: Does not include NYFS

Baseline Hydraulic Results - NYISO



Note: Does not include NYFS

Contingency Selection

- ◆ Postulated contingencies reflect low probability, high impact events
- ◆ Selected pipeline segments exhibited congestion effects based on Target 2 results
- ◆ Identify 2-5 gas-side contingencies and 3-8 electric-side contingencies in each of six PPAs
 - Gas-side contingencies include compressor outages, pipeline ruptures, and loss of major storage deliverability
 - Electric-side contingencies include loss of transmission and major generator(s)
- ◆ Use WinTran over the 24 post-contingency hours to quantify affected generation and time-to-trip intervals

Results of Gas-Side Contingencies – Winter 2018

- ◆ Severity of the contingency event impacts characterized by short time-to-trip intervals and large quantity of affected generation
- ◆ ISO-NE exhibited most severe impacts
 - Most affected generation not dual fuel capable
- ◆ PJM (MAAC area) and NYISO (LHV / downstate) exhibited isolated pockets of affected generation
 - Substantial portion of affected generation is dual fuel capable
- ◆ MISO (North/Central), PJM (rest of RTO), TVA, IESO have less affected generation
 - Consolidated pipeline network and storage facilities provides resiliency


Results of Gas-Side Contingencies – Summer 2018

- ◆ Outside of ISO-NE and the EMAAC and SWMAAC parts PJM, network of pipeline and storage infrastructure results in negligible affected generation
- ◆ In ISO-NE, pipeline pressure limitations potentially constrain availability of gas-fired units
 - Redispatch of other units and other electric system operator actions can mitigate impacts


Contingency Results Summary by Type

Reference Scenario, Winter 2018

Gas-Side Contingencies




Electric-Side Contingencies





Individual Gas-Side Contingency Results

Reference Scenario, Winter 2018



* Scheduled energy with undeliverable gas

Example Contingency Result Outputs




Plant	Time to Trip Following Contingency (h:m:s)	Scheduled Energy (MWh)	Undeliverable Energy (MWh)	Undeliverable Energy (%)
Plant 1	N/A	5,000	0	0
Plant 2*	3:30:00	2,500	2,200	88%
Plant 3	N/A	10,000	0	0
Plant 4*	N/A	15,000	0	0
Plant 5*	N/A	315	0	0
Plant 6	N/A	600	0	0
Plant 7	N/A	750	0	0
Plant 8	4:48:41	5,000	4,000	80%
Total			4,000 (gas only) 2,200 (dual fuel)	

Results of Electric-Side Contingencies

- ◆ Electric contingencies are largely less impactful than gas contingencies
- ◆ For RGDS W2018, results show
 - Affected generation in ISO-NE, NYISO and PJM happens many hours after the event
 - Dual-fuel capable units in MAAC portion of PJM and NYISO lessen impacts
 - Negligible affected generation in MISO, none in TVA
- ◆ For RGDS S2018, results show
 - Delivery pressures do not drop below thresholds
 - Incremental affected generation is limited to plants that are undeliverable in the baseline

Individual Electric-Side Contingency Results

Reference Scenario, Winter 2018



* Scheduled energy with undeliverable gas

LDC Contingency Analysis Approach

- ◆ Evaluation at specific temperatures rather than peak day
 - On a peak day, interruptible service typically not available to generators
- ◆ Evaluation by LAI (Central Hudson Gas & Electric, New Jersey Natural Gas, Public Service Electric & Gas, Washington Gas Light)
 - LDCs provided hydraulic details of segments that serve generation
 - Segments added to regional hydraulic models
 - Results and assessment reviewed with LDCs
- ◆ Evaluation by LDC (Con Edison, National Grid, Baltimore Gas & Electric, Nicor Gas, Peoples Gas, Enbridge Gas, Union Gas)
 - LAI provided generator gas demands to LDCs
 - LDCs provided results to LAI
 - Assessment reviewed with LDCs

Contingency Mitigation

- ◆ Intrinsic – Gas operator actions included as part of the model solutions
 - Use of line-pack
 - Increased interconnect flows from neighboring pipelines
 - Increased utilization of spare horsepower from downstream compression stations
 - Reversal-of-flow across key pipeline segments
- ◆ Extrinsic – Considered in the analysis but not included in the model solutions
 - Electric redispatch and switching to dual fuel
 - Communication initiatives among the PPAs, pipelines and/or LDCs
 - Select pipeline tariff innovations
 - Continued efforts to promote harmonization of gas day and electric day scheduling procedures

Target 4

Fuel Assurance: Dual Fuel Capability
and Firm Transportation Alternatives

Primary Findings

- ◆ *New gas-fired plants are expected to use ULSD as the primary back-up fuel*
- ◆ Anticipated heavy reliance on ULSD represents a major change in the distillate oil market – ULSD supply chain is robust
- ◆ Air permits typically cap oil use to 720 hours, but some permits have established lower annual hourly limits
- ◆ At most locations, the cost of dual-fuel capability is much less expensive than the incremental cost of FT to satisfy the fuel assurance objective

Fuel Assurance Analysis Approach

- ◆ Identify constrained locations across the Study Region from Target 2 F-D results
 - NYISO locations: NYC, Long Island, LHV, Capital District
- ◆ Define gas turbine technology types in SC and CC mode
- ◆ Design cost model to account for regional differences in dual-fuel capability and incremental FT
 - Account for non-firm transportation costs
 - Account for local facility improvements where applicable

Incremental FT Cost Inputs

- ◆ Identification of a pipeline path from a production basin to plant location
- ◆ FT reservation rates for incremental capacity
- ◆ Avoided cost of non-firm transportation
- ◆ Lateral as proxy for LDC transportation costs (where applicable)
- ◆ # of days with interrupted non-firm service (Target 2)

Incremental FT Paths for NYISO Locations


Location	Pipeline	Expansion Project	FERC Docket	Total Rate (\$/Dth-mo.)	Supply Basin
New York City	Constitution Iroquois	New pipeline	CP13-499	30.72*	Marcellus/Utica
Long Island	Constitution Iroquois	New pipeline	CP13-499	30.72*	Marcellus/Utica
Lower Hudson Valley	Millennium	Hancock Compressor	CP13-14	19.77**	Marcellus/Utica
Capital District	Tennessee	Northeast Supply Diversification	CP11-30	6.52	Marcellus/Utica

* For both Long Island and New York City, the total rate is the sum of the Constitution rate filed in CP13-499 plus the current effective tariff rate on Iroquois.

** The most recent project on Millennium, the Hancock Compressor Station Project, did not lead to an increase in rates. Therefore the FT-1 rate was utilized.

Location	Pipeline Connection	LDC Connection Proxy Project	Length (miles)	Estimated Cost (2018\$ MM)
New York City	Iroquois	Eastchester Extension	0.8 (onshore) / 1.7 (marine)	\$69.2
Long Island	Iroquois	Eastern Long Island Expansion	12 (onshore) / 17 (marine)	\$259.0

Net Cost of FT – NYISO Locations



Dual-Fuel Capability Permitting

- ◆ Limitations on back-up fuel use
 - Air permit conditions limit annual hours on oil – most common limit is 720 but some recent permits are less
 - Local zoning conditions govern construction of on-site oil storage tanks, tanker truck delivery routes
- ◆ Converting gas-only to dual-fuel requires permit modifications
 - May require existing pollution controls to be upgraded
 - Cost to retrofit typically higher than to incorporate dual-fuel capability at initial construction
- ◆ Air permits comply with state/federal NSR/PSD rules
 - Attainment v. non-attainment locations for pollutants
 - Best Achievable Control Technology / Lowest Achievable Emission Rate standards


Dual-Fuel Capability Cost Inputs

- ◆ ULSD logistics by location
 - Depot identification
 - Transport mode (truck or barge)
 - New price based on rack price, shipping, demurrage
 - Labor cost factor and tax rates
 - Permit restrictions
- ◆ Target inventory and fuel storage tank volume
 - Expressed in days of full load burn
 - Location-specific variables
 - Severity of natural gas delivery constraint
 - Delivery lag (order to receipt) and potential weather delays
 - Expected capacity factor when operating on ULSD
 - Tank volume allowance for “lumpy” barge delivery size


ULSD Logistics by NYISO Location

Location	Depot Location	Rack Price (\$/gal)	Delivery Mode	Delivery Cost (\$/gal)
New York City	NY Harbor	\$2.74	Barge	\$0.00
Long Island	Inwood, NY	\$2.78	Truck	\$0.05
Lower Hudson Valley	NY Harbor	\$2.74	Barge	\$0.05
Capital District	Albany, NY	\$2.80	Truck	\$0.04

Fuel Tank Size Calculations – NYISO Locations




Dual Fuel Cost Details for NYISO Locations




Fuel Assurance Analysis Results

- ◆ Cost of dual-fuel capability generally similar across locations
 - Variations between barge- and truck-supplied locations
- ◆ Cost of incremental FT varies across Study Region
 - Expensive in New England due to existing bottlenecks
 - Expensive at the local level (NYFS, in particular)
- ◆ Dual-fuel capability typically much lower cost for a new combined-cycle (CC) plant than FT; far more pronounced for simple cycle (SC) plants
 - LDC-served generators additionally incur local facility improvement costs
 - Restrictive environmental permit requirements limit liquid fuel usage
 - Structural changes continue to improve ULSD replenishment logistics

Fuel Assurance Analysis: Combined Cycle



Fuel Assurance Analysis: Simple Cycle



Study Limitations

- ◆ Fuel assurance from PPAs' perspective
- ◆ No quantification of wholesale energy price effects with incremental FT v. dual-fuel capability
- ◆ Other factors affecting generators' willingness to invest in incremental FT
 - Different performance on gas v. ULSD
 - Profit margin, incl. potential hits to EBITDA
 - Margin recoupment from FT capacity release
 - Increased permitting difficulty to store and burn ULSD
 - Penalty avoidance as a capacity resource