

### 2016 RNA: Preliminary Results

Laura Popa
Manager, Reliability Planning
Bill Lamanna
Lead Engineer, Reliability Planning
Kevin DePugh
Manager, Transmission Planning
ESPWG/TPAS

June 22, 2016 KCC

## Background and Process

- This presentation summarizes the 2016 RNA preliminary ("1st pass") Base Case results.
  - Note: No scenarios results complete at this time.
- The objective of providing the stakeholders the preliminary ("1st pass") Reliability Needs (RN) is to identify potential needs early and to encourage stakeholder feedback regarding firm changes prior to the final ("2nd pass") assessment.

### Background and Process, cont.

- In finalizing the RN, system changes that have occurred since the May 1, 2016 initial lock-down date will be considered, such as:
  - Updated LTPs that may impact the RN, changes in BPTFs, and changes in resources (unit status, load forecast, and demand response).
- Notes on the "2<sup>nd</sup> pass" updates process:
  - The new lock-down date is Tuesday, July 5, 2016.
  - The NYISO will apply the inclusion rules on the updates in order to develop a final Base Case
- In parallel, the scenarios will be finalized based on the original Base Cases.

# 2016 RNA Assumptions: GB2016 Baseline Load Forecast

#### Forecast of Coincident Summer Peak Demand by Zone – MW

(Reflects Impacts of Energy Saving Programs & Behind -the -Meter Generation)

| Year | A     | В     | C     | D   | E     | F     | G     | Н   | Ι     | J      | K     | NYCA   |
|------|-------|-------|-------|-----|-------|-------|-------|-----|-------|--------|-------|--------|
| 2016 | 2,680 | 1,992 | 2,810 | 535 | 1,352 | 2,376 | 2,290 | 656 | 1,536 | 11,695 | 5,438 | 33,360 |
| 2017 | 2,684 | 1,997 | 2,828 | 543 | 1,358 | 2,391 | 2,293 | 656 | 1,536 | 11,696 | 5,381 | 33,363 |
| 2018 | 2,688 | 2,003 | 2,841 | 551 | 1,363 | 2,398 | 2,293 | 658 | 1,538 | 11,717 | 5,354 | 33,404 |
| 2019 | 2,692 | 2,006 | 2,855 | 554 | 1,367 | 2,404 | 2,291 | 660 | 1,544 | 11,756 | 5,348 | 33,477 |
| 2020 | 2,695 | 2,009 | 2,867 | 555 | 1,371 | 2,409 | 2,290 | 660 | 1,545 | 11,760 | 5,340 | 33,501 |
| 2021 | 2,697 | 2,011 | 2,874 | 555 | 1,374 | 2,414 | 2,294 | 660 | 1,545 | 11,761 | 5,370 | 33,555 |
| 2022 | 2,700 | 2,013 | 2,880 | 555 | 1,377 | 2,419 | 2,299 | 660 | 1,548 | 11,785 | 5,414 | 33,650 |
| 2023 | 2,702 | 2,015 | 2,886 | 555 | 1,379 | 2,423 | 2,304 | 662 | 1,551 | 11,807 | 5,464 | 33,748 |
| 2024 | 2,704 | 2,017 | 2,891 | 555 | 1,382 | 2,426 | 2,309 | 665 | 1,553 | 11,830 | 5,501 | 33,833 |
| 2025 | 2,706 | 2,018 | 2,896 | 555 | 1,384 | 2,430 | 2,314 | 665 | 1,557 | 11,851 | 5,550 | 33,926 |
| 2026 | 2,708 | 2,019 | 2,901 | 555 | 1,386 | 2,433 | 2,320 | 668 | 1,564 | 11,907 | 5,595 | 34,056 |

# 2016 RNA Assumptions: GB2016 Baseline Solar PV BTM Impacts

Forecast of Reductions in Coincident Summer Peak Demand by Zone - MW

| Year | $\mathbf{A}$ | В  | C  | D | E  | F  | G   | H  | I  | J   | K   | NYCA |
|------|--------------|----|----|---|----|----|-----|----|----|-----|-----|------|
| 2016 | 10           | 6  | 15 | 2 | 9  | 31 | 30  | 3  | 6  | 25  | 121 | 258  |
| 2017 | 14           | 7  | 20 | 2 | 13 | 41 | 37  | 5  | 8  | 43  | 173 | 363  |
| 2018 | 16           | 10 | 24 | 2 | 14 | 47 | 46  | 5  | 10 | 52  | 195 | 421  |
| 2019 | 18           | 12 | 28 | 3 | 16 | 52 | 54  | 5  | 11 | 62  | 210 | 471  |
| 2020 | 21           | 15 | 33 | 3 | 18 | 57 | 63  | 5  | 12 | 69  | 222 | 518  |
| 2021 | 24           | 18 | 37 | 4 | 20 | 62 | 71  | 7  | 13 | 78  | 231 | 565  |
| 2022 | 27           | 21 | 41 | 4 | 23 | 66 | 80  | 7  | 14 | 89  | 234 | 606  |
| 2023 | 30           | 24 | 45 | 4 | 25 | 69 | 87  | 7  | 16 | 101 | 237 | 645  |
| 2024 | 32           | 27 | 48 | 5 | 26 | 72 | 93  | 7  | 18 | 114 | 240 | 682  |
| 2025 | 34           | 29 | 51 | 5 | 28 | 74 | 98  | 10 | 20 | 128 | 243 | 720  |
| 2026 | 36           | 31 | 53 | 5 | 29 | 75 | 101 | 10 | 21 | 139 | 247 | 747  |

Note: The actual impact of solar PV varies considerably by hour of day. The hour of the NYCA coincident peak varies yearly. The solar PV peak impact reported here assumes that the NYCA coincident peak occurs from 4 pm to 5 pm EDT in late July.

# 2016 RNA Assumptions: GB2016 Baseline Load Forecast without Solar PV BTM Impacts

|      |              |       |       |     |       |         |       |     |       |        | N     |        |
|------|--------------|-------|-------|-----|-------|---------|-------|-----|-------|--------|-------|--------|
| Year | $\mathbf{A}$ | В     | C     | D   | E     | ${f F}$ | G     | H   | Ι     | J      | K     | NYCA   |
| 2016 | 2,690        | 1,998 | 2,825 | 537 | 1,361 | 2,407   | 2,320 | 659 | 1,542 | 11,720 | 5,559 | 33,618 |
| 2017 | 2,698        | 2,004 | 2,848 | 545 | 1,371 | 2,432   | 2,330 | 661 | 1,544 | 11,739 | 5,554 | 33,726 |
| 2018 | 2,704        | 2,013 | 2,865 | 553 | 1,377 | 2,445   | 2,339 | 663 | 1,548 | 11,769 | 5,549 | 33,825 |
| 2019 | 2,710        | 2,018 | 2,883 | 557 | 1,383 | 2,456   | 2,345 | 665 | 1,555 | 11,818 | 5,558 | 33,948 |
| 2020 | 2,716        | 2,024 | 2,900 | 558 | 1,389 | 2,466   | 2,353 | 665 | 1,557 | 11,829 | 5,562 | 34,019 |
| 2021 | 2,721        | 2,029 | 2,911 | 559 | 1,394 | 2,476   | 2,365 | 667 | 1,558 | 11,839 | 5,601 | 34,120 |
| 2022 | 2,727        | 2,034 | 2,921 | 559 | 1,400 | 2,485   | 2,379 | 667 | 1,562 | 11,874 | 5,648 | 34,256 |
| 2023 | 2,732        | 2,039 | 2,931 | 559 | 1,404 | 2,492   | 2,391 | 669 | 1,567 | 11,908 | 5,701 | 34,393 |
| 2024 | 2,736        | 2,044 | 2,939 | 560 | 1,408 | 2,498   | 2,402 | 672 | 1,571 | 11,944 | 5,741 | 34,515 |
| 2025 | 2,740        | 2,047 | 2,947 | 560 | 1,412 | 2,504   | 2,412 | 675 | 1,577 | 11,979 | 5,793 | 34,646 |
| 2026 | 2,744        | 2,050 | 2,954 | 560 | 1,415 | 2,508   | 2,421 | 678 | 1,585 | 12,046 | 5,842 | 34,803 |

# 2016 vs 2014 RNA: Baseline Load Comparison

#### Comparison of Baseline NYCA Coincident Peak Forecasts - 2014 & 2016 RNA (MW)

| Annual MW              | 2014   | 2015   | 2016   | 2017   | 2018   | 2019   | 2020   | 2021   | 2022   | 2023   | 2024   | 2025   | 2026   |
|------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| 2014 RNA Baseline Load | 33,666 | 34,066 | 34,412 | 34,766 | 35,111 | 35,454 | 35,656 | 35,890 | 36,127 | 36,369 | 36,580 |        |        |
| 2016 RNA Baseline Load |        |        | 33,360 | 33,363 | 33,404 | 33,477 | 33,501 | 33,555 | 33,650 | 33,748 | 33,833 | 33,926 | 34,056 |
| Change from 2014 RNA   |        |        | -1,052 | -1,403 | -1,707 | -1,977 | -2,155 | -2,335 | -2,477 | -2,621 | -2,747 | NA     | NA     |

# 2016 RNA: Transmission Additions

 Major firm transmission projects modeled in the 2016 RNA Base Case:

| Owner                | Major Proposed Transmission Project    | 2016 RNA: I/S Year | 2016 RNA Status | 2014 RNA Status |
|----------------------|--|--------------------|-----------------|-----------------|
| NYPA/RGE             | Station 255                            | 2019/2020          | I/S             | I/S             |
| NYPA/NYSEG/O&R/ConEd | TOTS (except ConEd's cooling project)  | 2016               | I/S             | I/S             |
| O&R/ConEd            | North Rockland                         | 2018               | I/S             | O/S             |
| Central Hudson       | Leeds-Hurley 345kV Series Compensation | 2018               | I/S             | O/S             |
| National Grid        | Packard Series Reactors                | 2016 (I/S)         | I/S             | O/S             |
| RGE                  | Station 80/Pannell ("GRTA")            | 2017               | I/S             | I/S             |
| ConEd                | 345 kV Rainey - 138 kV Corona PAR      | 2019               | I/S             | O/S             |

## 2016 RNA: Deactivations

| OWNER / OPERATOR                    | STATION UNIT             | ZONE          | CRIS  | 2016 RNA Status           | 2014 RNA/CRP status      |
|-------------------------------------|--------------------------|---------------|-------|---------------------------|--------------------------|
| Erie Blvd. Hydro - Seneca Oswego    | Seneca Oswego Fulton 1   | С             | 0.7   | O/S                       | O/S                      |
| Erie Blvd. Hydro - Seneca Oswego    | Seneca Oswego Fulton 2   | С             | 0.3   | O/S                       | O/S                      |
| Long Island Power Authority         | Montauk Units #2, #3, #4 | K             | 6.0   | O/S                       | O/S                      |
| NRG Power Marketing LLC             | Dunkirk 1                | Α             | 96.2  | O/S                       | I/S                      |
| NRG Power Marketing LLC             | Dunkirk 3                | Α             | 201.4 | O/S                       | I/S                      |
| NRG Power Marketing LLC             | Dunkirk 4                | Α             | 199.1 | O/S                       | I/S                      |
| ReEnergy Chateaugay LLC             | Chateaugay Power         | D             | 18.6  | O/S                       | O/S                      |
| Rochester Gas and Electric Corp.    | Station 9                | В             | 15.8  | O/S                       | O/S                      |
| Syracuse Energy Corporation         | Syracuse Energy ST1      | С             | 11.0  | O/S                       | O/S                      |
| Syracuse Energy Corporation         | Syracuse Energy ST2      | С             | 58.9  | O/S                       | O/S                      |
| TC Ravenswood, LLC                  | Ravenswood 07            | J             | 16.5  | O/S                       | O/S                      |
| TC Ravenswood, LLC                  | Ravenswood 3-3           | J             | 37.7  | O/S                       | O/S                      |
| Erie Blvd. Hydro - North Salmon     | Hogansburg               | D             | 0.3   | O/S                       | I/S                      |
| Niagara Generation LLC              | Niagara Bio-Gen          | Α             | 50.5  | O/S                       | I/S                      |
| NRG Power Marketing LLC             | Astoria GT 05            | J             | 16.0  | O/S                       | I/S                      |
| NRG Power Marketing LLC             | Astoria GT 07            | J             | 15.5  | O/S                       | I/S                      |
| NRG Power Marketing LLC             | Astoria GT 12            | J             | 22.7  | O/S                       | I/S                      |
| NRG Power Marketing LLC             | Astoria GT 13            | J             | 24.0  | O/S                       | I/S                      |
| NRG Power Marketing LLC             | Dunkirk 2                | А             | 97.2  | O/S                       | O/S starting May 2015    |
| NRG Power Marketing LLC             | Huntley 67               | Α             | 196.5 | O/S                       | I/S                      |
| NRG Power Marketing LLC             | Huntley 68               | Α             | 198.0 | O/S                       | I/S                      |
| Cayuga Operating Company, LLC       | Cayuga 1                 | С             | 154.1 | O/S starting July 1, 2017 | O/S starting July 1, 201 |
| Cayuga Operating Company, LLC       | Cayuga 2                 | С             | 154.7 | O/S starting July 1, 2017 | O/S starting July 1, 201 |
| Entergy Nuclear Power Marketing LLC | Fitzpatrick 1            | С             | 858.9 | O/S                       | I/S                      |
| R.E. Ginna Nuclear Power Plant, LLC | Ginna                    | В             | 582.0 | O/S                       | I/S                      |
| NRG Power Marketing LLC             | Astoria GT 08            | J             | 15.3  | O/S                       | I/S                      |
| NRG Power Marketing LLC             | Astoria GT 10            | J             | 24.9  | O/S                       | I/S                      |
| NRG Power Marketing LLC             | Astoria GT 11            | J             | 23.6  | O/S                       | I/S                      |
| TC Ravenswood, LLC                  | Ravenswood 04            | J             | 15.2  | O/S                       | I/S                      |
| TC Ravenswood, LLC                  | Ravenswood 05            | J             | 15.7  | O/S                       | I/S                      |
| TC Ravenswood, LLC                  | Ravenswood 06            | J             | 16.7  | O/S                       | I/S                      |
|                                     |                          | Total         | 3,144 |                           |                          |
|                                     | New deactivations        | from 2014 RNA | 2,573 |                           |                          |

#### 2016 RNA: Generation Additions

| Project Name                 | Zone             | Requested CRIS<br>MW | Summer Peak<br>MW | Min (CRIS,<br>SummerPeak) | 2016 RNA<br>(1 <sup>st</sup> year of Base<br>Case inclusion) | <b>2014 RNA</b><br>Status |
|------------------------------|------------------|----------------------|-------------------|---------------------------|--|---------------------------|
| CPV Valley Energy Center     | G                | 680                  | 677.6             | 677.6                     | 2018   | O/S                       |
| Taylor Biomass               | G                | 19                   | 19                | 19                        | 2018   | I/S                       |
| Copenhagen Wind              | E                | 79.9                 | 79.9              | 79.9                      | 2018   | O/S                       |
| East River 1 Uprate          | J                | 12.1                 | 12.1              | 12.1                      | 2017   | O/S                       |
| East River 1 Uprate          | J                | 12.1                 | 12.1              | 12.1                      | 2017   | O/S                       |
| Black Oak Wind               | С                | 0                    | 12.5              | 0                         | 2017   | O/S                       |
| Sithe Independence Uprate    | С                | 43                   | 43                | 43                        | 2017   | O/S                       |
| Marble River Wind            | D                | 215.2                | 215.2             | 215.2                     | 2017   | O/S                       |
| HQ-US (External CRIS Rights) | E                | 20                   | 20                | 20                        | 2017   | O/S                       |
| Stony Creek Uprate           | С                | 5.9                  | 5.9               | 5.9                       | 2017   | O/S                       |
| Bowline 2 Uprate             | G                | 10                   | 10                | 10                        | 2017   | O/S                       |
|                              | Total            | 1,097                | 1,107             | 1,095                     |  |                           |
| Addition                     | ns from 2014 RNA | 1,078                | 1,088             | 1,076                     |  |                           |

#### 2016 RNA: Load and Capacity Table

|         | Year                        | 2017   | 2018   | 2019          | 2020              | 2021   | 2022   | 2023     | 2024   | 2025   | 2026   |
|---------|-----------------------------|--------|--------|---------------|-------------------|--------|--------|----------|--------|--------|--------|
|         |                             |        |        | Peak Load (MV | V) - Table I-2a G | B 2016 |        |          |        |        |        |
|         | NYCA*                       | 33,363 | 33,404 | 33,477        | 33,501            | 33,555 | 33,650 | 33,748   | 33,833 | 33,926 | 34,056 |
|         | Zone J*                     | 11,696 | 11,717 | 11,756        | 11,760            | 11,761 | 11,785 | 11,807   | 11,830 | 11,851 | 11,907 |
|         | Zone K*                     | 5,381  | 5,354  | 5,348         | 5,340             | 5,370  | 5,414  | 5,464    | 5,501  | 5,550  | 5,595  |
|         | Zone G-J                    | 16,181 | 16,206 | 16,251        | 16,255            | 16,260 | 16,292 | 16,324   | 16,357 | 16,387 | 16,459 |
|         |                             | 7.7    |        |               |                   | 1947   |        | <u> </u> |        | 7 7/   |        |
|         |                             |        |        | Reso          | urces (MW)        |        |        |          |        |        |        |
|         | Capacity**                  | 36,867 | 37,644 | 37,644        | 37,644            | 37,644 | 37,644 | 37,644   | 37,644 | 37,644 | 37,644 |
|         | Net Purchases & Sales       | 1,849  | 1,584  | 1,593         | 2,255             | 2,255  | 2,255  | 2,255    | 2,255  | 2,255  | 2,255  |
|         | SCR                         | 1,248  | 1,248  | 1,248         | 1,248             | 1,248  | 1,248  | 1,248    | 1,248  | 1,248  | 1,248  |
| NYCA    | Total Resources             | 39,965 | 40,476 | 40,485        | 41,147            | 41,147 | 41,147 | 41,147   | 41,147 | 41,147 | 41,147 |
|         | Capacity/Load Ratio         | 110.5% | 112.7% | 112.4%        | 112.4%            | 112.2% | 111.9% | 111.5%   | 111.3% | 111.0% | 110.59 |
|         | Cap+NetPurch/Load Ratio     | 116.0% | 117.4% | 117.2%        | 119.1%            | 118.9% | 118.6% | 118.2%   | 117.9% | 117.6% | 117.29 |
|         | Cap+NetPurch+SCR/Load Ratio | 119.8% | 121.2% | 120.9%        | 122.8%            | 122.6% | 122.3% | 121.9%   | 121.6% | 121.3% | 120.89 |
|         |                             |        |        |               |                   |        |        |          |        |        |        |
|         | Capacity**                  | 9,554  | 9,554  | 9,554         | 9,554             | 9,554  | 9,554  | 9,554    | 9,554  | 9,554  | 9,554  |
|         | UDR Awarded                 | 975    | 975    | 975           | 975               | 975    | 975    | 975      | 975    | 975    | 975    |
| Zone J  | SCR                         | 384    | 384    | 384           | 384               | 384    | 384    | 384      | 384    | 384    | 384    |
|         | Total Resources             | 10,913 | 10,913 | 10,913        | 10,913            | 10,913 | 10,913 | 10,913   | 10,913 | 10,913 | 10,913 |
|         | Capacity/Load Ratio         | 81.7%  | 81.5%  | 81.3%         | 81.2%             | 81.2%  | 81.1%  | 80.9%    | 80.8%  | 80.6%  | 80.2%  |
|         | Cap+UDR/Load Ratio          | 90.0%  | 89.9%  | 89.6%         | 89.5%             | 89.5%  | 89.3%  | 89.2%    | 89.0%  | 88.8%  | 88.4%  |
|         | Cap+UDR+SCR/Load Ratio      | 93.3%  | 93.1%  | 92.8%         | 92.8%             | 92.8%  | 92.6%  | 92.4%    | 92.2%  | 92.1%  | 91.7%  |
|         |                             |        |        | A.C.          |                   |        |        |          |        |        |        |
|         | Capacity**                  | 5,287  | 5,287  | 5,287         | 5,287             | 5,287  | 5,287  | 5,287    | 5,287  | 5,287  | 5,287  |
|         | UDR Awarded                 | 990    | 990    | 990           | 990               | 990    | 990    | 990      | 990    | 990    | 990    |
| Zone K  | SCR                         | 67     | 67     | 67            | 67                | 67     | 67     | 67       | 67     | 67     | 67     |
| Zone K  | Total Resources             | 6,343  | 6,343  | 6,343         | 6,343             | 6,343  | 6,343  | 6,343    | 6,343  | 6,343  | 6,343  |
|         | Capacity/Load Ratio         | 98.2%  | 98.7%  | 98.9%         | 99.0%             | 98.4%  | 97.6%  | 96.8%    | 96.1%  | 95.3%  | 94.5%  |
|         | Cap+UDR/Load Ratio          | 116.6% | 117.2% | 117.4%        | 117.5%            | 116.9% | 115.9% | 114.9%   | 114.1% | 113.1% | 112.29 |
|         | Cap+UDR+SCR/Load Ratio      | 117.9% | 118.5% | 118.6%        | 118.8%            | 118.1% | 117.2% | 116.1%   | 115.3% | 114.3% | 113.49 |
|         |                             |        |        |               |                   |        |        |          |        |        |        |
|         | Capacity**                  | 14,659 | 15,356 | 15,356        | 15,356            | 15,356 | 15,356 | 15,356   | 15,356 | 15,356 | 15,350 |
|         | UDR Awarded                 | 975    | 975    | 975           | 975               | 975    | 975    | 975      | 975    | 975    | 975    |
| one G-J | SCR                         | 464    | 464    | 464           | 464               | 464    | 464    | 464      | 464    | 464    | 464    |
|         | Total Resources             | 16,099 | 16,795 | 16,795        | 16,795            | 16,795 | 16,795 | 16,795   | 16,795 | 16,795 | 16,795 |
|         | Capacity/Load Ratio         | 90.6%  | 94.8%  | 94.5%         | 94.5%             | 94.4%  | 94.3%  | 94.1%    | 93.9%  | 93.7%  | 93.3%  |
|         | Cap+UDR/Load Ratio          | 96.6%  | 100.8% | 100.5%        | 100.5%            | 100.4% | 100.2% | 100.0%   | 99.8%  | 99.7%  | 99.2%  |
|         | Cap+UDR+SCR/Load Ratio      | 99.5%  | 103.6% | 103.3%        | 103.3%            | 103.3% | 103.1% | 102.9%   | 102.7% | 102.5% | 102.0% |

<sup>\*</sup>NYCA load values represent baseline coincident summer peak demand. Zones J and K load values represent non-coincident summer peak demand. Aggregate Zones G-J values represent G-J coincident peak, which is non-coincident with NYCA.

<sup>\*\*</sup>NYCA Capacity values include resources electrically internal to NYCA, additions, reratings, and retirements (including proposed retirements and mothballs). Capacity values reflect the lesser of CRIS and DMNC values. NYCA resources include the net purchases and sales as per the Gold Book. Zonal totals include the awarded UDRs for those capacity zones.


# 2016 RNA: Load and Resources Comparison for Year 5 (2021)

| Year 2021                   | 2016 RNA        | 2014 RNA       | Delta  |
|-----------------------------|-----------------|----------------|--------|
| Baseline Load               | 33,555          | 35,890         | -2,335 |
| SCR                         | 1,248           | 1,189          | 59     |
| Total Capacity without SCRs | 39,899          | 39,322         | 577    |
| Net Cha                     | nge in Capacity | less Load (MW) | 2,971  |


# 2016 RNA: Resource Adequacy (RA) Updates to Assumptions Matrix

| #                    | Parameter          | 2016 IRM Model<br>Assumptions  | 2017 IRM Model<br>Assumptions                                      | Basis for IRM<br>Recommendation  | 2016 RNA Assumptions                          |
|----------------------|--------------------|--|--|--|---|
| <b>Transaction -</b> | Imports / Exports  |  |  |  |   |
| 1                    | Capacity Purchases | PJM – 1080 MW HQ – 1090 MW +20 MW if awarded through Class Year 2015. Total HQ 1110 MW  All contracts modeled as | PJM – 1080 MW HQ – 1090 MW HQ TO 1110 MW  All contracts modeled as | Grandfathered Rights, ETCNL, and other awarded long-term rights including 20 MW CRIS potentially awarded to HQUS | Modeled as explicit contracts                 |
| 2                    | Capacity Sales     | Long Term firm sales Summer 286.6 MW   | Long Term firm sales Summer yyy MW                                 | These are long-term contracts filed with FERC  | Modeled as equivalent contracts sold from ROS |
| 3                    | FCM Sales          | No Sales within study period   | Xxxx MW  | Sensitivity based on Examination of Neighbor's FCM auction results   | Modeled as equivalent contracts sold from ROS |
| 4                    | New UDRs           | No new UDR projects  | No new UDR projects  | Existing UDR elections are made by August 1 <sup>st</sup> and will be incorporated into the model                | Same  |


#### 2016 RNA: RA Updated Topology Year 1 - NYCA



#### 2016 RNA: RA Updated Topology, Year 2 to Year 10 - NYCA



#### 2016 RNA: RA Updated Topology Year 1 to Year 10 - Zones G to J Detail



(PJM East to RECO) + (PJM East to J) + (PJM East to J3) + (PJM East to J4) + (PJM East to G) Grouped Interface Limited to 2,000 MW

#### 2016 RNA: RA Preliminary Results

• Base Case LOLE Preliminary ("1st pass") Results:

| RA Base Case |           |
|--------------|-----------|
| Study Year   | NYCA_LOLE |
| Y2017        | 0.039     |
| Y2018        | 0.031     |
| Y2019        | 0.035     |
| Y2020        | 0.020     |
| Y2021        | 0.022     |
| Y2022        | 0.022     |
| Y2023        | 0.028     |
| Y2024        | 0.031     |
| Y2025        | 0.034     |
| Y2026        | 0.042     |

 RA 1<sup>st</sup> pass conclusion: LOLE < 0.1 criterion; therefore, no resource adequacy Reliability Needs identified as result of this assessment.



## 2016 RNA: Preliminary Results Transmission Security

Kevin DePugh

Manager - Transmission Studies New York Independent System Operator


**Electric System Planning Working Group** 

June 22, 2016 Rensselaer, NY

# 2016 RNA: Preliminary Transmission Security Reliability Needs

| Year of Need | Transmission Security Violations (Transmission District/LBMP Zone/Transmission Owner) |
|--------------|---|
| - 0          | Buffalo Area in West (Zone A), served by NYSEG  |
|              | Binghamton Area in Central (Zone C), served by NYSEG                                  |
| 2017         | Syracuse Area in Central (Zone C), served by N. Grid                                  |
|              | Utica Area in Mohawk Valley (Zone E), served by N. Grid                               |
|              | Western Long Island Area in Long Island (Zone K), served by Long Island/PSEG          |
| 2018         | No additional violations  |
| 2019         | No additional violations  |
| 2020         | No additional violations  |
| 2021         | No additional violations  |
| 2022         | Additional Syracuse Area in Central (Zone C), served by N. Grid                       |
| 2023         | No additional violations  |
| 2024         | No additional violations  |
| 2025         | Additional Syracuse Area in Central (Zone C), served by N. Grid                       |
| 2026         | No additional violations  |

Map of Transmission Security Preliminary Reliability Needs



## Transmission Security: Thermal

| Zone | Owner               | Monitored Element                                    | _          | LTE<br>Rating<br>(MVA) | _          |      | 2021<br>Flow<br>(MVA) | 2026<br>Flow<br>(MVA) | First Contingency                 | Second Contingency              |
|------|---------------------|--|------------|------------------------|------------|------|-----------------------|-----------------------|-----------------------------------|---------------------------------|
| Α    | NYSEG               | Stolle-Gardenville(#66) 230                          | 474        | 478                    | 478        | 509  | 515                   | 520                   | Packard-Gardenville<br>(#182) 115 | TWR Packard-Huntley 230         |
| Α    | N.Grid              | Packard-Huntley (#77) 345                            | 556        | 644                    | 746        | 646  | 646                   | 646                   | Stolle-Gardenville (#66) 230      | SB Packard 230                  |
| C/B  | NYPA, RG&E, N. Grid | Clay-Pannell (#1) 345                                | 1195       | 1195                   | 1195       | 1238 | 1245                  | 1264                  | Stolle-Gardenville (#66) 230      | SB Clay 345                     |
| C/B  | NYPA, RG&E, N. Grid | Clay-Pannell (#2) 345                                | 1195       | 1195                   | 1195       | 1240 | 1247                  | 1266                  | Stolle-Gardenville (#66) 230      | SB Clay 345                     |
| С    | NYSEG               | Oakdale 345/115 2TR                                  | 428        | 556                    | 600        | 565  | 586                   | 605                   | Packard-Huntley (#77) 230         | SB Oakdale 345                  |
| С    | N.Grid              | Elbridge 345/115 1TR                                 | 470        | 557                    | 717        |      |                       | 569                   | Pannell-Clay (#1) 345             | SB Clay 345                     |
| С    | N.Grid              | Clay-Lockheed Martin (#14) 115<br>(Clay-Wetzel)      | 220        | 252                    | 280        |      |                       | 255                   | Clay-Woodard (#17) 115            | SB Lafayette 345                |
| С    | N.Grid              | Clay-Woodard (#17) 115<br>(Clay-Euclid)              | 220        | 252                    | 280        |      |                       | 256                   | Clay-Lockheed Martin<br>(#14) 115 | SB Lafayette 345                |
| С    | N.Grid              | Clay-Teall (#10) 115<br>(Clay-Bartell Rd-Pine Grove) | 116<br>220 | 120<br>252             | 145<br>280 | 126  |                       |                       | Clay-Teall<br>(#11) 115           | SB Dewitt 345                   |
| С    | N.Grid              | Clay-Dewitt (#3) 115<br>(Clay-Bartell Rd)            | 116<br>220 | 120<br>252             | 145<br>280 | 131  |                       |                       | Clay-Dewitt<br>(#13) 345          | Oswego-Lafayette (#17) 345      |
| E    | N.Grid              | Porter-Yahnundasis (#3) 115<br>(Porter-Kelsey)       | 116        | 120                    | 145        | 138  |                       |                       | Stolle-Gardenville(#66) 230       | Porter Bus D 115                |
| E    | N.Grid              | Porter-Oneida (#7) 115<br>(Porter-W. Utica)          | 116        | 120                    | 145        | 125  | 3/1                   |                       | Porter-Yahnundasis (#3) 115       | SB Oswego 345                   |
| K    | Long Island         | East Garden City-Valley Stream (262) 138             | 211        | 291                    | 504        | 293  | 302                   | 316                   | Barrett-Valley Stream (292) 138   | Barrett-Valley Stream (291) 138 |

# Transmission Security Reliability Need Year

| Zone | Owner               | Monitored Element                                    | Year of Need |
|------|---------------------|--|--------------|
| Α    | NYSEG               | Stolle Road-Gardenville (#66) 230                    | 2017         |
| Α    | N.Grid              | Packard-Huntley (#77) 345                            | 2017         |
| C/B  | NYPA, RG&E, N. Grid | Clay-Pannell (#1) 345                                | 2017         |
| C/B  | NYPA, RG&E, N. Grid | Clay-Pannell (#2) 345                                | 2017         |
| C    | NYSEG               | Oakdale 345/115 2TR                                  | 2017         |
| С    | N.Grid              | Clay-Teall (#10) 115<br>(Clay-Bartell Rd-Pine Grove) | 2017         |
| С    | N.Grid              | Clay-Dewitt (#3) 115<br>(Clay-Bartell Rd)            | 2017         |
| Е    | N.Grid              | Porter-Yahnundasis (#3) 115<br>(Porter-Kelsey)       | 2017         |
| E    | N.Grid              | Porter-Oneida (#7) 115<br>(Porter-W. Utica)          | 2017         |
| K    | Long Island         | East Garden City-Valley Steam (#262) 138             | 2017         |
| С    | N.Grid              | Elbridge 345/115 1TR                                 | 2022         |
| С    | N.Grid              | Clay-Woodard (#17) 115<br>(Clay-Euclid)              | 2022         |
| С    | N.Grid              | Clay-Lockheed Martin (#14) 115                       | 2025         |

#### 2016 RNA: Next Steps

- Stakeholders to report updates before the new July 5, 2016 lock-down date.
- NYISO to evaluate the updates against the inclusion rules and their relevance to the preliminary ("1st pass") RN identified in this presentation.
- NYISO to finalize the Base Cases and identify the final ("2<sup>nd</sup> pass") RN.
- In parallel with the 2<sup>nd</sup> pass, NYISO to finalize the scenarios on the original Base Cases.

## 2016 RNA: Next Steps, cont.

 July: NYISO to provide draft reports beginning in July to allow stakeholders the opportunity to comment.

 End of August: NYISO to provide final RN report, including scenarios, and start the approval process. The Mission of the New York Independent System Operator, in collaboration with its stakeholders, is to serve the public interest and provide benefit to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policy makers, stakeholders and investors in the power system

www.nyiso.com