

**2009 CARIS Potential Generic Solution
Transmission Cost Matrix
Order of Magnitude Unit Prices**

Project Comparison

Upstate

Quanta Original	Sargent and Lundy	NYSEG Concurrence	NG Concurrence	NYRI	Leeds- PV	Quanta Revised	Average
\$2.6	\$2.6	\$2.6	\$2.6	\$11.0	\$4.8	\$5.7	\$4.6

Downstate

Quanta Original	Sargent and Lundy	M29 Cable	Quanta Revised	Average
\$11.8	\$27.0	\$22.6	\$21.2	\$20.7

Con Ed felt original estimate was too low.

Long Island

Quanta Original	Sargent and Lundy	Neptune Cable	Quanta Revised	Average
\$10.8	\$12.2	\$9.2	\$19.8	\$13.0

LIPA felt the original estimate is too low.

 Indicates NYISO's Recommendation

Recommendation

Item #	Location	Transmission				Transmission Cost (\$M/Mile)	Substation	System Upgrade Facilities (\$M)
		Line System Voltage (kV)	Block Ampacity (Amp)	Block Capacity (MVA)	Construction Type		Line Terminal Addition per Substation (\$M)	
T-1	Upstate	345	1673	1000	Overhead	\$5.7	\$3.2	\$2.9
T-2	Downstate	345	1673	1000	Undergrd	\$22.6	\$5.3	\$3.7
T-3	Long Island	138	2092	500	Undergrd	\$12.2	\$3.1	\$2.9

Assumptions

- Lines constructed within Zones A through G will be comprised of single circuit overhead construction utilizing steel construction, 600' span lengths and 200' wide ROW.
- Lines constructed within Zones H through K will be comprised of underground cable construction of PPP (paper/polypropylene/paper) insulated cable and HPFF (high pressure fluid filled) pipe cooled with 5 manholes per mile.
- The transmission line will be interconnected into an existing 345kV substation for Upstate and Downstate and 138kV for Long Island.
- The cost for lines that cross between Zones G and Zones H or I will be pro-rated as overhead or underground based on the mileage of the line included within each Zone.
- The line can be permitted and constructed utilizing the shortest distance between the two selected substations.
- The cost per mile includes the cost for new right of way and permitting.
- The existing substation selected as the interconnection point consists of open air construction and has sufficient space within the fenced yard for adding a new breaker and a half bay for the new line terminal.
- The control house at the existing substations selected as the interconnection point has sufficient space for installing the new protection and communication equipment for the new line terminal.
- The substation line terminal costs include the necessary protection and communication equipment.
- System Upgrade Facilities will consist of line terminal relay upgrades and replacement of overdutied breakers.
- Estimates include costs for material, construction labor, engineering labor, permits, testing and commissioning.