NYSRC Fall Forecast Update – Preliminary

2017 Weather Normalization

Arthur Maniaci

Supervisor, Load Forecasting & Energy Efficiency

Load Forecasting Task Force

September 15, 2017



Overview

- 1. Summary of 2017 Weather Normalized Peaks
- 2. Weather-Normalization Models
- 3. Update of Ratios of Non-Coincident Peaks to Coincident Peaks



1. Summary of Weather-Normalized Peaks



Acronyms used in this presentation

CE (or Con Ed) Consolidated Edison

CH (or Cen Hudson) Central Hudson
CP Coincident Peak

CTHI Cumulative Temperature Humidity Index

LI (or LIPA) Long Island
N Grid (or Nat Grid) National Grid

NYPA New York Power Authority

New York State Electric & Gas

OR (or O & R) Orange & Rockland

RGE (or RG & E) Rochester Gas & Electric

NCP Non-Coincident Peak

NYCA New York Control Area



Actual and 20-Year Normal Peak-Producing CTHI Statistics – 1998-2017

Statistic	CE	СН	LI	N Grid	NYPA	NYSEG	OR	RGE	NYCA
Max	91.61	90.18	91.70	86.53	87.86	87.47	90.18	88.33	88.26
20 Yr Avg	86.22	85.38	85.21	82.08	81.92	82.21	85.38	83.31	84.01
Min	81.55	81.83	78.98	77.35	77.26	78.00	81.83	78.50	79.19
StDev	2.86	2.78	3.48	2.66	3.12	2.71	2.78	2.74	2.71
50th	86.22	85.38	85.21	82.08	81.92	82.21	85.38	83.31	84.01
67th	87.45	86.58	86.71	83.23	83.27	83.38	86.58	84.50	85.18
90th	89.88	88.94	89.67	85.49	85.93	85.68	88.94	86.83	87.49
2017	83.81	81.83	82.22	77.83	77.52	78.00	81.83	79.22	80.79
Percentile	20%	10%	19%	6%	8%	6%	10%	7%	12%
z (2017)	-0.84	-1.28	-0.86	-1.59	-1.41	-1.55	-1.28	-1.49	-1.19
CTHI Delta	-2.41	-3.55	-2.99	-4.25	-4.40	-4.21	-3.55	-4.09	-3.22

 $Z = \underbrace{(CTHI - Avg)}_{Std Dev}$

Peak-producing CTHI is the Cumulative Temperature-Humidity Index that occurs on the day of the NYCA peak each year.

Con-Ed and 0&R use the 67^{th} percentile for design conditions. All others use the 50^{th} percentile.



Two Models for Weather Normalization

- Pooled models (2013, 2016 & 2017)
 - Select the most recent year with weather above design conditions (2013)
 - Exclude 2014 and 2015 because weather in those years was below normal and will not provide much information about recent trends
- Single Year Models (2017)
 - Review weather response only for the current year



Two Methods for Weather Normalization

Load Level Method

Obtain a regression equation f(CTHI) and evaluate at design condition.

Weather-Response Method

- 1. Obtain a regression equation and take its derivative f'(CTHI) (i.e, the slope of the regression line).
- Evaluate derivative at design condition. Multiply by difference of (Normal – Actual) CTHI.
- Add this change in load to the actual observed MW value.



Summary of 2017 Preliminary Weather Normalization

Model Results for Each Method & Composite Results

Transmission	Load Leve	el Method	Weather Resp	onse Method	Average of Four	2016 WN CP
District	Y 2017	Pooled	Y 2017	Pooled	2017 Estimates	MW
Con Edison	13,182	13,088	13,240	13,300	13,203	13,340
Central Hudson	1,012	1,040	1,070	1,099	1,055	1,069
LIPA	5,125	5,283	5,316	5,474	5,300	5,419
National Grid	6,992	6,817	6,877	7,089	6,944	7,155
NYPA	334	337	332	332	334	314
NYSEG	3,063	3,170	3,114	3,232	3,145	3,228
O&R	1,028	1,058	1,070	1,113	1,067	1,163
RG&E	1,607	1,558	1,657	1,592	1,604	1,562
NYCA TOTAL	32,343	32,351	32,676	33,231	32,650	33,250

Notes

- 1. Con-Edison & O&R are at 67th percentile design conditions.
- 2. Con-Edison models are for its non-coincident peak, not its NYCA coincident peak.



Summary of 2017 Preliminary Weather Normalization Transmission District Weather Normalized Peak Loads NYCA Coincident Peaks

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9a)	(9b)	(10)=(9b)-(6)	(11)=(10)/(9b)
Transmission District	2017 Actual MW, 8/11/2017 HB 16	Estimated Muni Self- Gen	Demand Response Estimate MW	Weather Adjustment MW	2017 Weather Normalized MW	Loss Reallocation MW	2017 WN MW, Adj for Losses	2017 ICAP Market Forecast MW	2017 Forecast, Without Loss Adjustment	TO Forecast, Over /Under MW	TO Forecast Error, Percent Over /Under
Con Edison	11,864	0	0	1,179	13,043	149	13,192	13,534	13,360	317	2.4%
Cen Hudson	1,000	0	0	55	1,055	-10	1,045	1,043	1,050	-5	-0.5%
LIPA	4,989	10	0	311	5,310	43	5,353	5,427	5,384	74	1.4%
Nat. Grid	6,202	56	0	742	7,000	-213	6,787	6,891	7,108	108	1.5%
NYPA	322	0	0	12	334	4	338	305	301	-33	-10.9%
NYSEG	2,878	0	0	267	3,145	0	3,145	3,223	3,241	96	3.0%
O&R	975	0	0	92	1,067	13	1,080	1,177	1,167	100	8.6%
RG&E	1,413	0	0	191	1,604	14	1,618	1,577	1,567	-38	-2.4%
Grand Total	29,643	66	0	2,849	32,558	0	32,558	33,178	33,179	621	1.9%

Weather normalization based upon composite model results.



Summary of 2017 Preliminary Weather Normalization Transmission District Weather Normalized Peak Loads Locality Peaks


(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Locality	Date and Time (Hr Beginning)	2017 Actual MW	Estimated Muni Self- Gen	Demand Response Estimate MW	Locality Weather Adjustment MW	2017 Adjusted MW	2017 ICAP Market Forecast MW	Over/Under MW	Percent Over/Under
Zone J - NYC	7/20/17 HB 16	10,668	0	0	790	11,458	11,670	212	1.8%
Zone K - LI	7/20/17 HB 16	5,137	10	0	317	5,464	5,427	-37	-0.7%
Zone GHIJ	7/20/17 HB 16	12,321	0	0	3,379	15,700	16,061	361	2.3%

Weather normalization based upon coincident peak results and NCP/CP ratios for each Locality.




2. Weather Normalization Models

















































































3. Ratios of Non-Coincident to Coincident Peaks



Update of Ten-Year Rolling Average of Coincident and Locality Peaks To Obtain NCP/CP Ratios for 2018

NY	NYCA Coincident Peak Dates & Times & Zonal MW						G	-to-J Locali	ty Peak	Dates &	Times &	Zonal M	W
Year	NYCA Date	Hr Beg	Zone G	Zones H+I	Zone J	NYCA CP	Year	G-to-J Date	Hr Beg	Zone G	Zones H+I	Zone J	G-J NCP
2008	6/9/2008	17	2,277	2,056	10,979	15,311	2008	6/10/2008	17	2,338	2,101	11,262	15,701
2009	8/17/2009	16	2,159	1,875	10,366	14,400	2009	8/21/2009	15	2,117	1,879	10,661	14,657
2010	7/6/2010	17	2,399	2,187	11,600	16,186	2010	7/6/2010	17	2,399	2,187	11,600	16,186
2011	7/22/2011	16	2,482	2,239	11,826	16,546	2011	7/22/2011	16	2,482	2,239	11,826	16,546
2012	7/17/2012	14	2,282	2,082	11,405	15,769	2012	7/18/2012	13	2,288	2,071	11,424	15,783
2013	7/19/2013	17	2,384	2,253	11,736	16,373	2013	7/19/2013	17	2,384	2,253	11,736	16,373
2014	9/2/2014	16	2,036	1,917	10,567	14,520	2014	9/2/2014	17	2,046	1,933	10,572	14,551
2015	7/29/2015	16	2,070	1,930	10,455	14,455	2015	7/20/2015	16	2,059	1,996	10,675	14,730
2016	8/11/2016	16	2,069	1,993	11,006	15,068	2016	8/11/2016	16	2,069	1,993	11,006	15,068
2017	7/19/2017	17	2,011	1,898	10,249	14,158	2017	7/20/2017	16	2,046	1,936	10,722	14,704

All data is from DSS.



Update of Ten-Year Rolling Average of Coincident and Locality Peaks To Obtain NCP/CP Ratios for 2018

Z	ne J Locali	ty Peak	Dates &	Times &	Zonal M	W
Year	Zone J Date	Hr Beg	Zone G	Zones H+I	Zone J	G-J NCP
2008	6/10/2008	17	2,338	2,101	11,262	15,701
2009	8/21/2009	15	2,117	1,879	10,661	14,657
2010	7/6/2010	17	2,399	2,187	11,600	16,186
2011	7/22/2011	12	2,375	2,107	11,876	16,358
2012	7/18/2012	15	2,115	2,002	11,438	15,554
2013	7/19/2013	17	2,384	2,253	11,736	16,373
2014	9/2/2014	17	2,046	1,933	10,572	14,551
2015	7/20/2015	16	2,059	1,996	10,675	14,730
2016	8/11/2016	16	2,069	1,993	11,006	15,068
2017	7/20/2017	17	2,046	1,936	10,722	14,704

	Zone K Locality Peak Dates & Times & Zonal MW									
Year	Zone K Date	Hr Beg	Coincident Peak	Non- Coin. Peak	NCP/CP Ratio	Differ- ence				
2008	6/10/2008	16	5,139	5,276	1.0268	138				
2009	8/21/2009	15	5,059	5,191	1.0260	132				
2010	7/6/2010	16	5,755	5,822	1.0115	66				
2011	7/22/2011	15	5,896	5,914	1.0030	18				
2012	6/21/2012	16	5,079	5,510	1.0848	431				
2013	7/18/2013	16	5,589	5,764	1.0314	175				
2014	9/2/2014	16	5,054	5,054	1.0000	-				
2015	7/20/2015	16	5,136	5,247	1.0216	111				
2016	8/12/2016	16	5,190	5,411	1.0426	221				
2017	7/20/2017	16	4,989	5,137	1.0297	148				

All data is from DSS.



Calculation of G-to-J NCP/CP Ratio

	Coincident Peaks							
Period	Zone G	Zone H+I	Zone J	G-to-J CP				
3 Yr Avg	2,050	1,940	10,570	14,560				
5 Yr Avg	2,114	1,998	10,803	14,915				
10 Yr Avg	2,217	2,043	11,019	15,279				

15,430/15,279 = 1.0099

	G-t	o-J Locality Pe	aks					
Period	Zone G	Zone H+I	Zone J	G-to-J NCP				
3 Yr Avg	2,058	1,975	10,801	14,834				
5 Yr Avg	2,121	2,022	10,942	15,085				
10 Yr Avg	2,223	2,059	11,148	15,430				
Period	Zone G	Zone H+I	Zone J	G-to-J NCP				
3 Yr Avg	8	35	231	274				
5 Yr Avg	7	24	140	170				
10 Yr Avg	6	16	129	151				
_								
Period	Zone G	Zone H+I	Zone J	G-to-J NCP				
3 Yr Avg	1.0039	1.0178	1.0218	1.0188				
5 Yr Avg	1.0033	1.0120	1.0129	1.0114				
10 Yr Avg	1.0027	1.0077	1.0117	1.0099				



Calculation of Zone J NCP/CP Ratio

	Coincident Peaks								
Period	Zone G	Zone H+I	Zone J	G-to-J CP					
3 Yr Avg	2,050	1,940	10,570	14,560					
5 Yr Avg	2,114	1,998	10,803	14,915					
10 Yr Avg	2,217	2,043	11,019	15,279					

11,155/11,019 = 1.0123

	Zon	e J Locality Pe	aks	
Period	Zone G	Zone H+I	Zone J	G-to-J NCP
3 Yr Avg	2,058	1,975	10,801	14,834
5 Yr Avg	2,121	2,022	10,942	15,085
10 Yr Avg	2,195	2,039	11,155	15,388
Period	Zone G	Zone H+I	Zone J	G-to-J NCP
3 Yr Avg	8	35	231	274
5 Yr Avg	7	24	140	170
10 Yr Avg	(22)	(4)	136	110
Period			Zone J	
3 Yr Avg			1.0218	
5 Yr Avg			1.0129	
10 Yr Avg			1.0123	



Calculation of Zone K NCP/CP Ratio

Period	K CP	K NCP	Ratio
3 Yr Avg	5,105	5,265	1.0314
5 Yr Avg	5,191	5,323	1.0253
10 Yr Avg	5,289	5,433	1.0272
Period			Diff.
3 Yr Avg			160
5 Yr Avg			131
10 Yr Avg			144

5,433/5,289 = 1.0272



The Mission of the New York Independent System Operator, in collaboration with its stakeholders, is to serve the public interest and provide benefits to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policy makers, stakeholders and investors in the power system



www.nyiso.com

