

NYISO Major Emergency Report

At 0216 on 10/04/2005

A Major Emergency was declared by the NYISO Shift Supervisor

69 LINE ERIE-SOUTH RIPLEY

ACTUAL FLOW EXCEEDED LTE

ONE MINUTE

This was caused when:

IESO EXPERIENCED COMPUTER PROBLEMS WHICH CAUSED THEM TO INCORRECTLY BACK DOWN 1000MW OF GENERATION. UPON INITIAL CONVERSATION WITH IESO THEY WERE AWARE OF COMPUTER PROBLEMS. UPON DISCOVERING THEIR PROBLEM, GENERATION RECOVERED AND IESO PLACED A MESSAGE ON THE RCIS.

To correct this, the ISO Shift Supervisor:

NYISO WAS ALREADY TAKING ACTIONS TO REMOVE POST CONTINGENCY VIOLATIONS ON THIS LINE CAUSED BY A LARGE SCHEDULE CHANGE TO IESO. NY WAS CUTTING CONTRACTS FROM PJM AND TO HQ, ALSO TAP MOVES WERE ALSO BEING TAKEN ON THE 5018 AND L33/34.

Load Relief Was Not Required.

The Major Emergency was terminated at 0217