

# NYISO Major Emergency Report

At **1552** On **Friday 7/ 5/02** a Major Emergency was declared by the NYISO Shift Supervisor

**M51 Sprainbrook-W49st  
exceeded its LTE Rating**

This was caused when: **A fire in the Sprainbrook substation on the 2N2 reactor caused the following lines to trip: Y49, W75, X28, W78 and W85.**

To correct this, the ISO Shift Supervisor: **requested CONED and LI to initiate fast load pickup. CONED was able to close W75 back in.**

**The NYCA was taken out of merit, UPNY units and imports were backed down to reduce over generation condition due to the fast load pickup.**

Load Relief Was Not Required.

The Major Emergency was terminated at **1618**