

NYISO Major Emergency Report

At **0710** On **Saturday 3/ 30/02** a Major Emergency was declared by the NYISO Shift Supervisor

when the power flow on Central East; NE Gen Volt Limit exceeded its Voltage Transfer Limit by more than 105%

This was caused when:

ISONE began increasing Phase 2 imports towards 1650 MW, NYPA Holtsville Unit tripped loaded at 150 mws.

To correct this, the ISO Shift Supervisor:

Requested ISONE to reduce Phase 2 Imports, removed a Gilboa pump, reduce Western NY Generation and cut NY Imports.

Load Relief Was Not Required.

The Major Emergency was terminated at **0718**