

NYISO Major Emergency Report

At **1617** On **Saturday 4/ 5/03** a Major Emergency was declared by the NYISO Shift Supervisor

**when the power flow on Central East
exceeded its Voltage Transfer Limit
by more than 105%**

This was caused when: **EF24-40 Edic-Fraser 345 Kv tripped.**

To correct this, the ISO
Shift Supervisor:

**Generation was taken OOM, ConEd requested to initiated fast
load pickup, taps taken on the following PARs:
Branchburg-Ramapo to NY, taps on A2253/B3402/C3403 to NY
and L33P/L34P to Ontario.**

Load Relief Was Not Required.

The Major Emergency was terminated at **1625**