

## NYISO Major Emergency Report

At 1216 on 12/11/2007

A Major Emergency was declared by the NYISO Shift Supervisor

when the power flow on Central East

exceeded its Voltage Transfer Limit

by more than 105%

This was caused when:

Marcy-New Scotland (18) 345 kV line tripped, lowering the Central East Voltage Transfer limit below actual Central East Flows.

To correct this, the ISO Shift Supervisor:

NYISO cut transactions to ISONE, order Eastern NY hydro generation on-line and reduced Western NY hydro generation to reduce flows on Central East.

NYISO also moved phase angle regulators in Southeastern New York to reduce Central East flows.

Load Relief Was Not Required.

The Major Emergency was terminated at 1225