

To: NYS Public Service Commission
NYISO Operating Committee
NYISO System Operating Advisory Subcommittee
NYS Reliability Council

From: Rick Gonzales
Manager, Scheduling & Commitment

Date: August 23, 2000

Subject: **Major Emergency Report**

At **0856** On **Wednesday 8/ 23/00** a Major Emergency was declared by the NYISO Shift Supervisor

**71 DUNWOODIE-RAINEY ACTUAL POWER FLOW
EXCEEDED ITS LTE RATING**

This was caused when: **AT 0855 THE 72 LINE DUNWOODIE-RAINEY
TRIPPED**

To correct this, the
NYISO Shift Supervisor: **CONED MOVED PAR TAPS TO INCREASE FLOW INTO NY ON C3403
HUDSON- FARRAGUT LINE; CONED INITIATED A FAST LOAD
GENERATION PICKUP; CONED ATTEMPTED TO RECLOSE 72 LINE
FAILED, CONED THEN INITIATED MAX GENERATION PICKUP.**

Load Relief Was Not Required.

The Major Emergency was terminated at **0907**