

To: NYS Public Service Commission
NYISO Operating Committee
NYISO System Operating Advisory Subcommittee
NYS Reliability Council

From: Rick Gonzales
Manager, Scheduling & Commitment

Date: July 20, 2000

Subject: **Major Emergency Report**

At **0943** On **Thursday 7/ 20/00** a Major Emergency was declared by the NYISO Shift Supervisor

**when the power flow on Central East
exceeded its Transient Stability Limit
by more than 105%**

This was caused when:

**New Scotland 345kV #77 bus tripped, resulting in
the loss of #14 Edic-New Scotland, #93 New
Scotland-Leeds and New Scotland 345/115kV Bk
#2. (The #2 New Scotland-Alps was out at the time
for scheduled work.)**

To correct this, the
NYISO Shift Supervisor:

**Activated Maximum Generation pickup in SENY companies. Curtailed
400MW HQ imports. Ordered on 2 Gilboa units. Moved St. Lawrence
L33/L34 phase angle regulators 100MW north.**

Load Relief Was Not Required.

The Major Emergency was terminated at **0949**