

To: NYS Public Service Commission
NYISO Operating Committee
NYISO System Operating Advisory Subcommittee
NYS Reliability Council

From: Rick Gonzales
Manager, Scheduling & Commitment

Date: January 24, 2001

Subject: **Major Emergency Report**

At **0748** On **Monday 1/ 22/01** a Major Emergency was declared by the NYISO Shift Supervisor

**Contingency overload on East 13th St Bk's 12,13,14,15
exceeded its Post Contingency STE Rating**

This was caused when:

**A fire at Con Ed's East 13th St oil pumping station
required the emergency outages of Poletti
generation loaded at 350MW in addition to
outages of the Q35M&L, B47 & 48 Farragut-East
13th St and East 13th St Bk's 10,11,16,17
transmission facilities.**

To correct this, the
NYISO Shift Supervisor:

**B47 & 48 Farragut-East 13th St, and East 13th Bk's 10 & 11 were restored
to service.**

Load Relief Was Not Required.

The Major Emergency was terminated at **0934**