

NYISO Major Emergency Report

At **1246** On **Thursday 8/ 9/01** a Major Emergency was declared by the NYISO Shift Supervisor

Shortage of Operating Reserve

This was caused when:

Peak load conditions were observed, in addition to exports from NY ICAP resources resulted in a shortage of Operating Reserves.

To correct this, the ISO Shift Supervisor:

- Various load relief measures were implemented**
- A portion of the NY ICAP sales to outside the Control Area were cut to meet Op Reserve**
- at 1512 the NY initiated 5% V/R in Eastern NY to assist PJM voltage**
- at 1816 NY came out of 5% V/R**

Load Relief Was Not Required.

The Major Emergency was terminated at **1840**