

To: NYS Public Service Commission
NYISO Operating Committee
NYISO System Operating Advisory Subcommittee
NYS Reliability Council

From: Rick Gonzales
Manager, Scheduling & Commitment

Date: April 27, 2001

Subject: **Major Emergency Report**

At **1257** On **Friday 4/ 27/01** a Major Emergency was declared by the NYISO Shift Supervisor

**Line 72 Dunwoodie-Rainey 345kv
exceeded its LTE Rating**

This was caused when: **Line 71 Dunwoodie-Rainey Tripped**

To correct this, the
NYISO Shift Supervisor: **ConEd initiated a max generation pickup**

Load Relief Was Not Required.

The Major Emergency was terminated at **1304**