

To: NYS Public Service Commission  
NYISO Operating Committee  
NYISO System Operating Advisory Subcommittee  
NYS Reliability Council

From: Rick Gonzales  
Manager, Scheduling & Commitment

Date: April 1, 2001

Subject: **Major Emergency Report**

At **2309** On **Saturday 3/ 31/01** a Major Emergency was declared by the NYISO Shift Supervisor

**PV-20 Plattsburgh-Vermont  
exceeded its LTE Rating**

This was caused when: **The Highgate HVdc tie in ISONE ran back 150MW.**

To correct this, the  
NYISO Shift Supervisor: **NYPA took taps on the PAR at Plattsburgh to reduce the PV-20 loading.**

Load Relief Was Not Required.

The Major Emergency was terminated at **2312**