

NYISO Major Emergency Report

At **1500** On **Wednesday 8/ 8/01** a Major Emergency was declared by the NYISO Shift Supervisor

Shortage of operating reserve

This was caused when:

Peak load conditions were observed, in addition to exports from NY ICAP resources resulted in a shortage of Operating Reserves.

To correct this, the ISO Shift Supervisor:

Various load relief measures were implemented. The Major Emergency was declared to recall a portion of the NY ICAP sales to outside the Control Area

Load Relief Was Not Required.

The Major Emergency was terminated at **2000**