

ATTACHMENT G

EMERGENCY DEMAND RESPONSE PROGRAM

I. EFFECTIVE DATE

The Emergency Demand Response Program shall become effective on May 1, 2001~~and shall remain in effect until October 31, 2005~~. At the end of each Capability Period, the ISO will review the Emergency Demand Response Program's performance and will propose appropriate changes as necessary.

II. QUALIFICATION REQUIREMENTS FOR CURTAILMENT SERVICES PROVIDERS

Curtailed Services Providers must be Customers or, in the case of entities that would become Customers solely for the purpose of participating in the Emergency Demand Response Program, must become Limited Customers. The requirements for becoming a Limited Customer are set forth in the ISO Procedures.

Customers and Limited Customers seeking to become Curtailed Service Providers must: (i) comply with the registration requirements set forth in the ISO Procedures; and (ii) as discussed in ISO procedures, be capable of reducing at least 100 kW of NYCA Load in a single Load Zone within two hours of receiving notice of the ISO's activation of the Emergency Demand Response Program. The required Load reduction may be accomplished by Curtailing Load and/or by serving Load