Operations Performance Metrics Monthly Report









September 2011 Report

Operations & Reliability Department New York Independent System Operator

Prepared by NYISO Operations Analysis and Services, based on settlements initial invoice data collected on or before October 10, 2011.



Table of Contents

- Highlights
 - Operations Performance

• Reliability Performance Metrics

- Alert State Declarations
- Major Emergency State Declarations
- IROL Exceedance Times
- Balancing Area Control Performance
- Reserve Activations
- Disturbance Recovery Times
- Load Forecasting Performance
- Wind Forecasting Performance
- Lake Erie Circulation and ISO Schedules

Market Performance Metrics

- RTM Congestion Residuals Monthly Trend
- RTM Congestion Residuals Daily Costs
- RTM Congestion Residuals Event Summary
- RTM Congestion Residuals Cost Categories
- DAM Congestion Residuals Monthly Trend
- DAM Congestion Residuals Daily Costs
- DAM Congestion Residuals Cost Categories
- NYCA Unit Uplift Components Monthly Trend
- NYCA Unit Uplift Components Daily Costs
- Local Reliability Costs Monthly Trend & Commitment Hours
- ICAP Spot Market Clearing Price
- UCAP Awards





September 2011 Operations Performance Highlights

- Peak load of 25,360 MW occurred on 9/13/2011 HB 16
- All-time summer capability period peak load of 33,939 MW occurred on 8/2/2006 HB13
- 17 hours of Thunder Storm Alerts were declared.
- Continued Levels of Clockwise Lake Erie Loop Flows
 - 35 hours of NERC TLR level 3 curtailments
- Simultaneous, Beck Niagara and Beck Packard outages are scheduled for Fall 2011, expected to begin December 5
- Local reliability costs and commitment hour charts are now included




Reliability Performance Metrics












For IROL exceedances leading to Major Emergency State declarations, the maximum IROL exceedence time is identified. IROL exceedances of less than thirty minutes are considered NERC compliant.








NYISO Reserve Activations are indicators of the need to respond to unexpected operational conditions within the NYISO Area or to assist a neighboring Area (Shared Activation of Reserves) by activating an immediate resource and demand balancing operation.



For NYISO initiated Reportable Disturbances, the maximum ACE recovery time is identified. Recovery times of less than 15 minutes are considered NERC compliant.







<u>Hourly Error MW</u> - Absolute value of the difference between the hourly average actual load demand and the average hour ahead forecast load demand.


Average Hourly Error % - Average value of the ratio of hourly average error magnitude to hourly average actual load demand

<u>Day-Ahead Average Hourly Error %</u> - Average across all hours of the month of the absolute value of the difference between actual load demand and the Day-Ahead forecast load demand, divided by the actual load demand.

























Market Performance Metrics







Day's	investigated	in September: 4,12,14,15,29	
Event	Date (yyyyr	Hours	Description
	9/4/2011	12,13	Thunder Storm Alert
9/4/2011 14			HQ_CHAT-NY Scheduling Limit
9/12/2011 13,20			Derate Dunwoodie-Shore Road 345kV (#Y50)
9/12/2011 20			Derate GowanusS-Greenwood 138kV (#42232)
	9/12/2011		Derate Leeds-New Scotland 345kV (#93) for I/o Leeds-New Scotland 345kV (#94)
	9/12/2011		Lake Erie Clockwise Circulation, DAM-RTM exceeds 125MW; Leeds-New Scotland (#93)
	9/14/2011		Uprate Central East
	9/14/2011		Derate Dunwoodie-Shore Road 345kV (#Y50)
	9/14/2011		Derate GowanusS-Greenwood 138kV (#42232)
	9/14/2011		Uprate GowanusS-Greenwood 138kV (#42232) for I/o TWR:Goethals
	9/14/2011		Derate Leeds-New Scotland 345kV (#93) for I/o Leeds-New Scotland 345kV (#94)
	9/14/2011		Lake Erie Clockwise Circulation, DAM-RTM exceeds 125MW; Leeds-New Scotland (#93)
	9/15/2011		Forced outage Freshkills-Goethals S 345kV (#21)
9/15/2011			Derate Astoria West/Queensbridge/Vernon
	9/15/2011 7,16		Derate Dunwoodie-Shore Road 345kV (#Y50)
	9/15/2011 7,9-17		Derate Dunwoodie-Shore Road 345kV (#Y50) for I/o SCB (#RNS2)
11 11 1		16-17	Derate Greenwood/Staten Island
		8,9,11	Derate Leeds-New Scotland 345kV (#93) for I/o Leeds-New Scotland 345kV (#94)
	9/15/2011		NYCA DNI Ramp Limit
	9/15/2011	11	Lake Erie Clockwise Circulation, DAM-RTM exceeds 125MW; Leeds-New Scotland (#93)
	9/29/2011	13,14,19,20	Thunder Storm Alert

Real-Time Balancing Market Congestion Residual (Uplift Cost) Categories							
<u>Category</u> Storm Watch	<u>Cost Assignment</u> Zone J	<u>Events Types</u> Thunderstorm Alert (TSA)	<u>Event Examples</u> TSA Activations				
Unscheduled Transmission Outage	Market-wide	Reduction in DAM to RTM transfers related to unscheduled transmission outage	Forced Line Outage, Unit AVR Outages				
Interface Derate - NYISO Security	Market-wide	Reduction in DAM to RTM transfers not related to transmission outage	Interface Derates due to RTM voltages				
Interface Derate - External Security	Market-wide	Reduction in DAM to RTM transfers related to External Control Area Security Events	TLR Events, External Transaction Curtailments				
Unscheduled Loop Flows	Market-wide	Changes in DAM to RTM unscheduled loop flows impacting NYISO Interface transmission constraints	DAM to RTM Clockwise Lake Erie Loop Flows greater than 125 MW				

- 2) At a minimum triose days with \$ 100 K/HK, snortfall of \$200 K/Day or more, or surplications.
 3) Uplift costs associated with multiple event types are apportioned equally by hour.
 4) Investigations began with Dec 2008. Prior months are reported as Not Investigated.









Day-Ahead Market Congestion Residual Categories								
<u>Category</u> NYTO Outage Allocation	<u>Cost Assignment</u> Responsible TO	<u>Events Types</u> Direct allocation to NYTO's responsible for transmission equipment status change.	Event Examples DAM scheduled outage for equipment modeled inservice for the TCC Auction.					
Unscheduled Loop Flows	All TO by Monthly Allocation Factor	Residual impact of Lake Erie circulation, MW difference between the DAM and TCC Auction.	Lake Erie Loop Flow Assumptions					
External Outage Allocation	All TO by Monthly Allocation Factor	Direct allocation to transmission equipment status change caused by change in status of external equipment.	Tie line required out-of- service by TO of neighboring control area.					
Central East Commitment Derate	All TO by Monthly Allocation Factor	Reductions in the DAM Central East_VC limit as compared to the TCC Auction limit, which are not associated with transmission line outages.						



