

Tie Meter Stats for 2004 December 1, 2005

Type	Mask ID	Total Annual Flow (GWhr)	Avg Change 4M T/U (%)	Max Change 4M T/U (%)	# 4M Changes	Avg Change 12M T/U (%)	Max Change 12M T/U (%)	# 12M Changes	Avg PTS Error (%)	Max PTS Error (%)	Meets RMRM
TIE	1003	3,305.38	0.00%	0.00%	1	0.00%	0.00%	0	0.06%	0.14%	N
TIE	1011	1,103.10	0.00%	0.00%	0	0.00%	0.00%	0	7.36%	11.57%	Y
TIE	1012	29.38	0.01%	0.13%	1	0.00%	0.00%	0	7.37%	14.08%	N
TIE	1013	0.04	0.00%	0.00%	0	1.47%	13.27%	1	0.00%	0.00%	Y
TIE	1025	3.80	16.67%	199.99%	1	22.57%	203.14%	1	0.00%	0.00%	Y
TIE	1030	2,356.44	0.00%	0.00%	1	0.00%	0.00%	0	0.20%	0.41%	Y
TIE	1033	8.24	0.00%	0.00%	0	0.00%	0.00%	0	.	.	N
TIE	1034	0.36	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1036	1,087.70	0.00%	0.05%	3	0.00%	0.00%	0	50.72%	55.32%	N
TIE	1038	89.48	0.22%	2.03%	2	0.01%	0.12%	1	0.30%	1.82%	N
TIE	1039	56.43	0.03%	0.17%	2	0.00%	0.00%	0	.	.	Y
TIE	1040	0.00	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	N
TIE	1043	0.00	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	N
TIE	1047	340.17	0.00%	0.01%	1	0.00%	0.02%	1	0.13%	0.70%	N
TIE	1056	90.79	0.00%	0.00%	0	0.00%	0.00%	0	15.84%	61.70%	Y
TIE	1063	58.21	0.54%	6.19%	4	0.00%	0.00%	0	5.87%	30.94%	N
TIE	1065	0.43	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1067	222.84	0.14%	1.60%	4	0.00%	0.00%	0	25.32%	205.26%	Y
TIE	1070	566.81	0.01%	0.07%	4	0.00%	0.00%	0	2.25%	5.76%	N
TIE	1073	506.63	0.00%	0.01%	1	0.00%	0.00%	0	3.29%	6.62%	N
TIE	1075	4.38	8.65%	71.84%	11	0.00%	0.00%	0	336.85%	918.32%	Y
TIE	1076	646.64	0.00%	0.05%	2	0.03%	0.24%	3	0.02%	0.05%	N
TIE	1079	91.49	0.00%	0.01%	1	0.00%	0.00%	0	0.96%	4.13%	N
TIE	1080	95.64	3.15%	27.12%	5	0.00%	0.00%	0	.	.	Y
TIE	1085	794.93	0.00%	0.02%	3	0.00%	0.00%	0	1.33%	4.70%	Y
TIE	1096	843.27	0.00%	0.02%	3	0.00%	0.00%	0	0.81%	4.49%	Y
TIE	1097	792.83	0.00%	0.01%	3	0.00%	0.00%	0	1.15%	4.68%	Y
TIE	1100	3,886.43	0.00%	0.02%	1	0.00%	0.01%	1	1.51%	4.29%	Y

Tie Meter Stats for 2004 December 1, 2005

Type	Mask ID	Total Annual Flow (GWhr)	Avg Change 4M T/U (%)	Max Change 4M T/U (%)	# 4M Changes	Avg Change 12M T/U (%)	Max Change 12M T/U (%)	# 12M Changes	Avg PTS Error (%)	Max PTS Error (%)	Meets RMRM
TIE	1103	13.50	0.00%	0.00%	0	0.00%	0.00%	0	1.20%	3.95%	N
TIE	1105	232.72	0.00%	0.00%	0	0.00%	0.00%	0	0.30%	0.70%	Y
TIE	1112	1,251.54	0.01%	0.09%	3	0.00%	0.00%	0	0.22%	0.80%	N
TIE	1120	354.54	0.01%	0.06%	1	0.00%	0.00%	0	5.23%	21.36%	N
TIE	1126	48.86	100.00%	100.01%	12	0.00%	0.00%	0	0.00%	0.00%	N
TIE	1129	356.11	0.00%	0.01%	1	0.00%	0.00%	0	0.31%	0.41%	Y
TIE	1131	605.26	0.11%	1.33%	1	0.34%	2.73%	2	3.16%	11.17%	Y
TIE	1137	745.64	0.00%	0.00%	0	0.00%	0.00%	0	.	.	N
TIE	1143	14.56	9.75%	58.19%	7	0.29%	2.06%	2	22.48%	137.96%	N
TIE	1145	0.00	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	N
TIE	1151	69.73	0.35%	4.17%	1	0.78%	7.02%	1	5.71%	17.38%	N
TIE	1153	111.32	0.01%	0.03%	3	0.00%	0.00%	0	0.78%	4.39%	Y
TIE	1160	4,984.61	0.00%	0.03%	1	0.00%	0.00%	3	0.02%	0.14%	N
TIE	1162	1.13	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1164	89.19	0.06%	0.30%	4	0.00%	0.00%	0	.	.	Y
TIE	1167	3,819.83	0.00%	0.00%	0	0.00%	0.00%	1	0.52%	0.64%	Y
TIE	1171	126.94	0.02%	0.16%	4	0.00%	0.00%	0	3.19%	10.32%	N
TIE	1172	539.27	0.00%	0.00%	0	0.00%	0.00%	0	0.05%	0.32%	N
TIE	1173	0.30	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1175	4.95	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1176	1,327.85	0.06%	0.46%	2	0.03%	0.20%	2	0.49%	1.50%	Y
TIE	1183	194.82	0.05%	0.15%	4	0.00%	0.00%	0	4.63%	12.81%	N
TIE	1190	515.78	0.00%	0.00%	1	0.00%	0.00%	0	0.33%	0.44%	Y
TIE	1195	212.44	0.01%	0.15%	1	0.00%	0.00%	0	0.59%	1.18%	N
TIE	1199	905.74	0.00%	0.00%	0	0.00%	0.00%	0	0.90%	5.47%	Y
TIE	1202	365.80	0.00%	0.00%	0	0.00%	0.00%	0	0.44%	1.89%	Y
TIE	1210	27.27	2.33%	21.80%	8	0.91%	4.33%	2	.	.	N

Tie Meter Stats for 2004 December 1, 2005

Type	Mask ID	Total Annual Flow (GWhr)	Avg Change 4M T/U (%)	Max Change 4M T/U (%)	# 4M Changes	Avg Change 12M T/U (%)	Max Change 12M T/U (%)	# 12M Changes	Avg PTS Error (%)	Max PTS Error (%)	Meets RMRM
TIE	1212	26.45	0.02%	0.14%	2	0.00%	0.00%	0	.	.	Y
TIE	1216	405.44	0.00%	0.04%	1	0.00%	0.00%	0	1.06%	2.45%	N
TIE	1222	280.41	0.01%	0.08%	2	0.00%	0.00%	0	6.58%	14.45%	N
TIE	1230	637.67	0.00%	0.00%	0	0.00%	0.00%	0	0.02%	0.04%	N
TIE	1231	232.97	0.01%	0.14%	1	0.00%	0.00%	0	16.30%	132.12%	Y
TIE	1233	749.82	0.01%	0.07%	1	0.00%	0.00%	0	1.05%	1.11%	Y
TIE	1239	478.73	0.00%	0.03%	1	0.00%	0.00%	0	0.54%	1.03%	Y
TIE	1243	201.89	0.01%	0.09%	3	0.00%	0.00%	0	2.96%	12.05%	Y
TIE	1245	610.03	0.00%	0.01%	5	0.00%	0.00%	2	0.51%	4.01%	N
TIE	1254	0.00	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	N
TIE	1256	5,103.18	0.00%	0.02%	1	0.20%	0.40%	6	0.01%	0.04%	N
TIE	1258	5,185.52	0.00%	0.00%	0	0.00%	0.00%	0	2.39%	2.73%	Y
TIE	1259	4,388.15	0.00%	0.00%	3	0.00%	0.00%	0	0.37%	0.98%	Y
TIE	1261	88.66	0.00%	0.00%	0	0.00%	0.00%	0	32.49%	70.62%	N
TIE	1263	94.80	0.00%	0.01%	1	0.00%	0.00%	0	0.21%	0.43%	Y
TIE	1269	3,643.25	0.00%	0.01%	3	0.00%	0.00%	1	0.02%	0.06%	N
TIE	1273	411.23	0.00%	0.00%	0	0.00%	0.00%	0	6.55%	16.55%	Y
TIE	1278	5,141.79	0.00%	0.01%	2	0.00%	0.00%	1	1.42%	2.12%	N
TIE	1281	14.24	0.30%	3.60%	1	0.00%	0.00%	0	.	.	N
TIE	1284	77.58	0.01%	0.13%	1	0.00%	0.00%	0	1.73%	2.19%	Y
TIE	1297	123.34	0.02%	0.12%	4	0.00%	0.00%	0	1.13%	4.10%	Y
TIE	1298	567.67	0.00%	0.05%	1	0.00%	0.00%	0	0.77%	0.88%	Y
TIE	1299	323.61	0.01%	0.09%	2	0.00%	0.00%	0	0.48%	0.91%	Y
TIE	1300	2,539.75	0.00%	0.00%	0	0.00%	0.00%	0	0.74%	1.68%	Y
TIE	1302	66.04	0.04%	0.17%	3	0.00%	0.00%	0	.	.	Y
TIE	1304	1,226.31	0.00%	0.00%	0	0.00%	0.00%	0	0.83%	1.18%	Y
TIE	1313	14.41	1.09%	6.57%	3	0.00%	0.00%	0	.	.	Y

Tie Meter Stats for 2004 December 1, 2005

Type	Mask ID	Total Annual Flow (GWhr)	Avg Change 4M T/U (%)	Max Change 4M T/U (%)	# 4M Changes	Avg Change 12M T/U (%)	Max Change 12M T/U (%)	# 12M Changes	Avg PTS Error (%)	Max PTS Error (%)	Meets RMRM
TIE	1315	373.13	0.00%	0.01%	1	0.00%	0.00%	0	0.27%	0.41%	Y
TIE	1317	0.00	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	N
TIE	1323	6,372.55	0.00%	0.00%	0	0.00%	0.00%	0	0.61%	1.49%	Y
TIE	1327	567.58	0.00%	0.02%	1	0.00%	0.00%	0	0.95%	2.97%	Y
TIE	1334	6.99	43.07%	100.00%	9	0.00%	0.00%	0	0.00%	0.00%	N
TIE	1335	0.02	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1342	79.05	0.02%	0.18%	3	0.00%	0.00%	0	18.34%	88.04%	Y
TIE	1344	2,656.23	0.00%	0.04%	2	0.00%	0.00%	0	0.07%	0.09%	Y
TIE	1346	305.62	0.00%	0.00%	0	0.00%	0.00%	0	0.17%	0.49%	N
TIE	1351	4,946.59	0.00%	0.00%	0	0.00%	0.02%	1	0.01%	0.04%	N
TIE	1356	5,083.71	0.00%	0.03%	1	0.00%	0.01%	3	0.01%	0.08%	N
TIE	1362	63.09	0.04%	0.33%	4	0.00%	0.00%	0	22.14%	96.59%	Y
TIE	1366	246.50	0.00%	0.00%	1	0.00%	0.00%	0	1.54%	6.97%	Y
TIE	1367	3,494.12	0.00%	0.01%	1	0.00%	0.00%	0	0.71%	3.11%	N
TIE	1370	55.97	0.15%	0.49%	8	0.00%	0.00%	0	.	.	N
TIE	1379	507.28	0.02%	0.17%	2	0.00%	0.00%	0	0.13%	0.66%	N
TIE	1380	486.72	0.00%	0.00%	0	0.00%	0.00%	0	0.65%	1.07%	Y
TIE	1385	585.89	0.00%	0.00%	0	0.00%	0.00%	0	0.60%	3.38%	Y
TIE	1388	557.61	0.00%	0.03%	1	0.00%	0.00%	0	1.18%	10.69%	Y
TIE	1389	244.60	0.00%	0.00%	0	0.00%	0.00%	0	0.15%	0.23%	Y
TIE	1396	598.65	0.01%	0.08%	1	0.00%	0.00%	0	0.22%	0.31%	N
TIE	1397	1,133.99	0.14%	1.64%	1	0.00%	0.00%	0	49.96%	63.20%	Y
TIE	1398	1.82	193.18%	2255.56%	5	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1401	120.68	0.00%	0.00%	0	0.00%	0.00%	0	0.55%	2.51%	N
TIE	1403	134.60	0.02%	0.21%	1	0.00%	0.00%	0	0.80%	2.03%	Y
TIE	1405	403.66	0.01%	0.13%	1	0.00%	0.03%	2	0.15%	0.73%	N
TIE	1410	145.63	0.04%	0.16%	4	0.00%	0.00%	0	.	.	Y

Tie Meter Stats for 2004 December 1, 2005

Type	Mask ID	Total Annual Flow (GWhr)	Avg Change 4M T/U (%)	Max Change 4M T/U (%)	# 4M Changes	Avg Change 12M T/U (%)	Max Change 12M T/U (%)	# 12M Changes	Avg PTS Error (%)	Max PTS Error (%)	Meets RMRM
TIE	1416	0.00	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1424	244.27	0.00%	0.02%	2	0.00%	0.00%	0	1.35%	4.02%	Y
TIE	1427	60.76	0.42%	2.83%	8	0.00%	0.00%	0	6.98%	43.95%	N
TIE	1428	71.16	0.00%	0.00%	0	0.00%	0.00%	0	3.84%	14.21%	Y
TIE	1430	135.28	0.00%	0.00%	0	0.00%	0.00%	0	0.25%	1.08%	Y
TIE	1442	481.42	0.00%	0.00%	0	0.00%	0.00%	0	73.36%	79.08%	N
TIE	1447	518.47	0.00%	0.02%	2	0.00%	0.01%	2	5.52%	49.62%	N
TIE	1450	171.52	0.34%	3.22%	8	0.00%	0.00%	0	6.05%	51.88%	N
TIE	1455	98.34	0.09%	1.08%	1	0.03%	0.25%	1	0.36%	2.55%	N
TIE	1457	2.87	42.42%	100.04%	9	0.00%	0.00%	0	0.00%	0.00%	N
TIE	1459	1,095.80	0.00%	0.00%	0	0.00%	0.00%	0	4.46%	15.72%	Y
TIE	1461	5,525.26	0.76%	9.06%	2	0.00%	0.01%	2	0.02%	0.08%	N
TIE	1463	0.00	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1465	182.18	0.00%	0.00%	0	0.00%	0.00%	0	1.05%	5.10%	N
TIE	1471	1,199.45	0.01%	0.05%	4	0.00%	0.00%	0	1.22%	3.13%	Y
TIE	1484	2.85	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1487	266.40	0.01%	0.07%	4	0.00%	0.00%	0	1.38%	8.80%	Y
TIE	1489	1,659.65	0.00%	0.00%	1	0.00%	0.00%	1	0.02%	0.15%	N
TIE	1491	23.69	0.02%	0.20%	1	0.00%	0.00%	0	8.92%	15.69%	N
TIE	1495	5,152.03	0.01%	0.03%	10	0.00%	0.00%	0	3.48%	3.82%	N
TIE	1497	121.57	0.00%	0.00%	0	0.00%	0.00%	0	17.75%	82.39%	N
TIE	1500	827.12	0.00%	0.00%	1	0.00%	0.00%	0	15.06%	81.60%	Y
TIE	1502	448.23	0.00%	0.04%	3	0.03%	0.24%	1	1.70%	4.05%	Y
TIE	1503	346.99	0.00%	0.00%	0	0.00%	0.00%	0	0.47%	1.41%	Y
TIE	1507	279.91	0.03%	0.20%	7	0.00%	0.00%	0	2.95%	11.55%	N
TIE	1509	3,450.55	1.03%	7.31%	5	0.00%	0.01%	2	2.08%	12.21%	Y
TIE	1513	38.54	0.09%	0.39%	5	0.00%	0.00%	0	.	.	Y

Tie Meter Stats for 2004 December 1, 2005

Type	Mask ID	Total Annual Flow (GWhr)	Avg Change 4M T/U (%)	Max Change 4M T/U (%)	# 4M Changes	Avg Change 12M T/U (%)	Max Change 12M T/U (%)	# 12M Changes	Avg PTS Error (%)	Max PTS Error (%)	Meets RMRM
TIE	1518	547.42	0.00%	0.01%	2	0.01%	0.06%	2	1.90%	22.61%	N
TIE	1521	0.06	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1536	482.98	0.00%	0.00%	0	0.00%	0.00%	0	5.02%	27.42%	N
TIE	1552	0.36	91.60%	100.67%	11	11.22%	101.01%	1	0.00%	0.00%	N
TIE	1556	7,366.01	0.00%	0.00%	0	0.00%	0.00%	0	0.29%	1.81%	Y
TIE	1560	5,760.91	0.00%	0.03%	2	0.00%	0.02%	1	0.50%	0.91%	Y
TIE	1565	0.00	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	N
TIE	1569	5,749.13	0.00%	0.00%	0	0.00%	0.00%	0	43.91%	48.03%	Y
TIE	1570	92.85	0.04%	0.16%	3	0.00%	0.00%	0	.	.	Y
TIE	1585	1,488.83	0.00%	0.00%	1	0.00%	0.00%	0	0.50%	5.81%	N
TIE	1591	44.30	100.00%	100.01%	12	0.00%	0.00%	0	0.00%	0.00%	N
TIE	1595	201.71	0.00%	0.00%	0	0.00%	0.00%	0	0.56%	3.21%	N
TIE	1597	61.73	0.00%	0.04%	1	0.00%	0.00%	0	1.21%	5.53%	N
TIE	1599	20.64	0.00%	0.00%	0	0.00%	0.00%	0	.	.	N
TIE	1600	501.91	0.01%	0.07%	1	0.00%	0.00%	0	1.42%	1.60%	Y
TIE	1603	131.82	0.28%	3.36%	1	0.00%	0.00%	0	.	.	Y
TIE	1607	4,076.68	0.08%	0.54%	3	0.10%	0.33%	4	0.39%	0.83%	Y
TIE	1613	2,419.22	0.00%	0.00%	0	0.00%	0.00%	0	3.71%	21.14%	Y
TIE	1618	230.96	0.18%	2.14%	1	0.00%	0.00%	0	5.30%	17.94%	Y
TIE	1625	99.67	0.00%	0.02%	1	0.00%	0.00%	0	125.94%	1207.23%	Y
TIE	1626	152.18	1.16%	3.93%	5	0.00%	0.00%	0	.	.	Y
TIE	1627	48.82	0.02%	0.24%	1	0.00%	0.00%	0	2.21%	15.33%	N
TIE	1630	0.77	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	N
TIE	1644	1.91	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1645	2.63	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1649	150.08	0.05%	0.17%	4	0.00%	0.00%	0	.	.	Y
TIE	1650	779.52	0.00%	0.05%	1	0.00%	0.00%	0	0.81%	0.99%	Y

Tie Meter Stats for 2004 December 1, 2005

Type	Mask ID	Total Annual Flow (GWhr)	Avg Change 4M T/U (%)	Max Change 4M T/U (%)	# 4M Changes	Avg Change 12M T/U (%)	Max Change 12M T/U (%)	# 12M Changes	Avg PTS Error (%)	Max PTS Error (%)	Meets RMRM
TIE	1651	4,499.66	0.00%	0.00%	0	0.00%	0.00%	0	0.35%	0.65%	Y
TIE	1654	2,981.90	0.00%	0.01%	2	0.00%	0.00%	0	0.08%	0.22%	Y
TIE	1655	634.65	0.00%	0.00%	5	0.00%	0.00%	2	0.06%	0.09%	N
TIE	1660	376.12	0.00%	0.01%	1	0.00%	0.00%	0	1.34%	5.33%	N
TIE	1661	604.88	0.00%	0.05%	1	0.03%	0.23%	3	3.55%	42.43%	N
TIE	1662	1,037.77	0.00%	0.02%	1	0.00%	0.00%	0	0.37%	0.56%	Y
TIE	1663	108.20	0.18%	1.01%	3	0.00%	0.00%	0	.	.	Y
TIE	1671	61.87	0.00%	0.03%	1	0.00%	0.00%	0	0.34%	0.65%	Y
TIE	1677	3.50	59.37%	199.69%	6	0.00%	0.00%	0	0.00%	0.00%	N
TIE	1684	403.54	1.12%	4.27%	4	0.00%	0.00%	0	.	.	Y
TIE	1686	41.39	1.13%	6.51%	4	0.00%	0.00%	0	.	.	Y
TIE	1695	366.39	0.00%	0.00%	0	0.00%	0.00%	0	0.07%	0.43%	N
TIE	1702	4,798.65	0.00%	0.01%	4	0.00%	0.00%	0	0.15%	0.39%	Y
TIE	1705	1.40	8.33%	100.00%	1	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1706	1.32	0.00%	0.00%	0	0.00%	0.00%	0	0.00%	0.00%	Y
TIE	1711	2,706.00	0.00%	0.00%	0	0.00%	0.00%	0	0.83%	1.00%	Y
TIE	1712	54.77	0.17%	1.15%	4	0.00%	0.00%	0	10.22%	24.07%	N
TIE	1714	397.50	0.00%	0.00%	0	0.00%	0.00%	0	0.54%	0.85%	N
TIE	1718	1,625.07	0.00%	0.00%	0	0.00%	0.00%	0	0.09%	0.18%	Y
TIE	1719	4.73	0.33%	3.82%	2	0.00%	0.00%	0	1.53%	9.52%	N
TIE	1721	476.44	0.00%	0.03%	1	0.00%	0.00%	0	0.55%	0.81%	Y
TIE	1723	3,610.84	0.00%	0.01%	2	0.00%	0.00%	2	0.02%	0.10%	N
TIE	1725	505.72	0.00%	0.01%	1	0.00%	0.00%	0	11.58%	22.37%	N
TIE	1728	1.52	0.00%	0.00%	0	0.00%	0.00%	0	41.60%	100.00%	N
TIE	1729	5,187.84	0.00%	0.01%	1	0.00%	0.00%	0	0.60%	4.18%	N
TIE	1730	41.19	0.04%	0.17%	3	0.00%	0.00%	0	.	.	Y
TIE	1732	1,688.10	0.00%	0.00%	3	0.00%	0.00%	0	2.25%	9.32%	Y

Tie Meter Stats for 2004 December 1, 2005

Type	Mask ID	Total Annual Flow (GWhr)	Avg Change 4M T/U (%)	Max Change 4M T/U (%)	# 4M Changes	Avg Change 12M T/U (%)	Max Change 12M T/U (%)	# 12M Changes	Avg PTS Error (%)	Max PTS Error (%)	Meets RMRM
TIE	1736	344.53	0.00%	0.02%	1	0.00%	0.00%	0	1.33%	4.70%	Y
TIE	1738	128.36	0.19%	1.88%	2	0.01%	0.05%	1	0.29%	1.84%	N
TIE	1741	781.58	0.00%	0.03%	4	0.00%	0.00%	0	1.36%	4.46%	Y
TIE	1743	144.12	8.35%	100.00%	5	44.87%	100.00%	5	46.63%	88.07%	Y
TIE	1746	6.18	50.00%	100.00%	6	55.56%	100.05%	5	0.00%	0.00%	Y
TIE	1753	0.85	2.18%	26.19%	1	0.00%	0.00%	0	0.00%	0.00%	N
TIE	1755	265.50	0.01%	0.07%	4	0.00%	0.00%	0	1.33%	9.14%	Y
TIE	1756	0.31	33.40%	200.09%	3	0.00%	0.00%	0	0.00%	0.00%	N
TIE	1764	1,375.45	0.01%	0.10%	2	0.00%	0.00%	0	1.35%	5.10%	Y
TIE	1766	363.17	0.02%	0.20%	4	0.00%	0.00%	0	2.43%	13.02%	N
TIE	1775	100.37	0.04%	0.41%	4	0.00%	0.00%	0	13.23%	120.21%	N
TIE	1776	628.38	1.11%	13.36%	1	0.00%	0.00%	0	7.20%	24.65%	Y
TIE	1779	134.60	0.07%	0.30%	4	0.00%	0.00%	0	.	.	Y
TIE	1783	879.20	0.00%	0.00%	0	0.00%	0.00%	0	1.02%	2.37%	Y
TIE	1784	3.62	1.38%	6.58%	3	0.00%	0.00%	0	.	.	Y
TIE	1809	228.15	0.00%	0.00%	0	0.00%	0.00%	0	1.78%	2.63%	Y