

Heat Wave Operations June 20-22, 2012


Wes Yeomans

Vice President - Operations
New York Independent System Operator


Operating Committee

July 12, 2012 Krey Corporate Center










^{*}Demand response reflects backcasting methodology





Wednesday - June 20, 2012

Statewide System Demand:

- Actual peak NYCA system load was 31, 296 MW
- EDRP/SCR estimated value as provided by RIPs was 616MW
- ISO Day-Ahead load forecast was 31, 700MW

Transmission Operations:


- HQ Chateauguay Massena 765kV Interconnection forced out from 6/19 HB17 through 6/20 HB13
- PJM Neptune HVdc Interconnection forced out

Generation Operations:

- Over 1100MW of Southeast NY (SENY) capacity was unavailable for operation resulting in the need for SENY Demand Response at lower statewide demand levels than prior years
- ISO SRE of Danskammer 1&2 for SENY transmission security
- ISO SRE of Oswego 6 for statewide capacity needs following forced outage of HQ Chateauguay-Massena 765kV Interconnection

Demand Response Operations:

- EDRP and SCR resources were activated in Zones G- J from HB14 through HB17
 - Activated for SENY transmission security (requirement to restore system power flows to within normal operating limits within 30 minutes)
- EDRP and SCR resources were activated in Zone C from HB14 through HB17
 - Activated for Oakdale 345kV voltage





Thursday - June 21, 2012

Statewide System Demand:

- Actual peak NYCA system load was 32, 127 MW
- EDRP/SCR estimated value as provided by RIPs was 1703 MW
- ISO Day-Ahead load forecast was 33, 700MW

Transmission Operations:


- HQ Chateauguay Massena 765kV Interconnection forced out from 6/21 HB10 through 6/21 HB14
- PJM Neptune HVdc Interconnection forced out
- Dysinger East interface was limited to maintain pre-contingency Oakdale 345kV voltage following the forced reduction of Zone C generation

Generation Operations:

- Over 1100MW of Southeast NY capacity was unavailable for operation at peak
- ISO SRE of Oswego 6 and Kintigh for statewide capacity needs
 - Day-Ahead SREs in response to unknown return of HQ 765kV interconnection on 6/20 and start-up notification requirement

Demand Response Operations:

- EDRP and SCR resources were activated in Zones G K from HB13 through HB17
 - Activated for Zones G-K transmission security operations
 - Zone J activated beginning at HB12 at Con Edison's request
- EDRP/SCR resources were activated for Zones A-F from HB13 through HB17
 - Activated Zone B for Rochester 345/115kV transformer loadings
 - Activated Zone C for Oakdale 345kV voltage
 - Activated Zone A, D, E, F for statewide capacity requirements in response to the loss of over 800MW of upstate generating capacity





Friday - June 22, 2012

Statewide System Demand:

- Actual peak NYCA system load was 29,932 MW
- EDRP/SCR estimated value as provided by RIPs was 656 MW
- ISO Day-Ahead load forecast was 30, 500MW
- Thunderstorms developed earlier than forecasted and reduced SENY load

Transmission Operations:

PJM Neptune HVdc Interconnection forced out

Generation Operations:


- Over 1500MW of Southeast NY capacity was unavailable for operation at peak
- ISO SRE of Roseton 1 for SENY transmission security

Demand Response Operations:

- EDRP and SCR resources were activated in Zones G –K from HB13 through HB17
 - Activated for Zones G-K for forecasted reserve shortages needed to maintain transmission security operations



The New York Independent System Operator (NYISO) is a not-for-profit corporation responsible for operating the state's bulk electricity grid, administering New York's competitive wholesale electricity markets, conducting comprehensive long-term planning for the state's electric power system, and advancing the technological infrastructure of the electric system serving the Empire State.



www.nyiso.com