Operations Performance Metrics Monthly Report



September 2012 Report

Operations & Reliability Department New York Independent System Operator



Table of Contents

- Highlights
 - Operations Performance
- Reliability Performance Metrics
 - Alert State Declarations
 - Major Emergency State Declarations
 - IROL Exceedance Times
 - Balancing Area Control Performance
 - Reserve Activations
 - Disturbance Recovery Times
 - Load Forecasting Performance
 - Wind Forecasting Performance
 - Lake Erie Circulation and ISO Schedules

Market Performance Metrics

- RTM Congestion Residuals Monthly Trend
- RTM Congestion Residuals Daily Costs
- RTM Congestion Residuals Event Summary
- RTM Congestion Residuals Cost Categories
- DAM Congestion Residuals Monthly Trend
- DAM Congestion Residuals Daily Costs
- DAM Congestion Residuals Cost Categories
- NYCA Unit Uplift Components Monthly Trend
- NYCA Unit Uplift Components Daily Costs
- Local Reliability Costs Monthly Trend & Commitment Hours
- TCC Monthly Clearing Price with DAM Congestion
- ICAP Spot Market Clearing Price
- UCAP Awards




September 2012 Operations Performance Highlights


- Peak load of 28,127 MW occurred on 9/7/2012 HB 16
- All-time summer capability period peak load of 33,939 MW occurred on 8/2/2006 HB13
- 19 hours of Thunder Storm Alerts were declared
- No hours of NERC TLR level 3 curtailments




Reliability Performance Metrics





































Market Performance Metrics






Day's investigated in September:7,8,18								
Event	Date (yyyymm Hours		Description					
9/7/2012 17-18		17-18	Thuderstorm Alert					
9/8/2012 11-18 9/8/2012 17,18		18	Derate FreshKills-Willow Brook 345kV (#29212)					
		11-18	Thuderstorm Alert					
		17,18	Derate Farragut-Hudson Avenue 138kV (#32077)					
		17,18	Derate FreshKills-Willow Brook 345kV (#29212)					
	9/8/2012	17,18	Derate Gowanus-Greenwood 138kV (#42232)					
	9/8/2012	8	NYCA DNI Ramp Limit					
	9/8/2012	19	NE_AC DNI Ramp Limit					
	9/8/2012 8 NE_AC-NY Scheduling Limit 9/8/2012 17 PJM_AC DNI Ramp Limit		NE_AC-NY Scheduling Limit					
			PJM_AC DNI Ramp Limit					
	9/18/2012	21	Uprate Gowanus-GoethalsN 345kV (#26)					
			Lake Erie Clockwise Circulation, DAM-RTM exceeds 125MW; Pleasant Valley-Athens 345kV (#91) SCB LEEDS R93 W/ 99K					
	9/18/2012	11,17	BUS O/S					

Real-Time Balancing Market Congestion Residual (Uplift Cost) Categories								
<u>Category</u> Storm Watch	<u>Cost Assignment</u> Zone J	<u>Events Types</u> Thunderstorm Alert (TSA)	<u>Event Examples</u> TSA Activations					
Unscheduled Transmission Outage	Market-wide	Reduction in DAM to RTM transfers related to unscheduled transmission outage	Forced Line Outage, Unit AVR Outages					
Interface Derate - NYISO Security	Market-wide	Reduction in DAM to RTM transfers not related to transmission outage	Interface Derates due to RTM voltages					
Interface Derate - External Security	Market-wide	Reduction in DAM to RTM transfers related to External Control Area Security Events	TLR Events, External Transaction Curtailments					
Unscheduled Loop Flows	Market-wide	Changes in DAM to RTM unscheduled loop flows impacting NYISO Interface transmission constraints	DAM to RTM Clockwise Lake Erie Loop Flows greater than 125 MW					
Monthly Balancing Market Congestion Report Assumptions/Notes								
 Storm Watch Costs are identified as daily total uplift costs At a minimum those days with \$100 K/HR, shortfall of \$200 K/Day or more, or surplus of \$100 K/Day or more are investigated Uplift costs associated with multiple event types are apportioned equally by hour 								

3) Uplift costs associated with multiple event types are apportioned equally by hour4) Investigations began with Dec 2008. Prior months are reported as Not Investigated.







Day-Ahead Market Congestion Residual Categories

<u>Category</u> NYTO Outage Allocation	<u>Cost Assignment</u> Responsible TO	<u>Events Types</u> Direct allocation to NYTO's responsible for transmission equipment status change.	<u>Event Examples</u> DAM scheduled outage for equipment modeled in- service for the TCC Auction.
Unscheduled Loop Flows	All TO by Monthly Allocation Factor	Residual impact of Lake Erie circulation, MW difference between the DAM and TCC Auction.	Lake Erie Loop Flow Assumptions
External Outage Allocation	All TO by Monthly Allocation Factor	Direct allocation to transmission equipment status change caused by change in status of external equipment.	Tie line required out-of- service by TO of neighboring control area.
Central East Commitment Derate	All TO by Monthly Allocation Factor	Reductions in the DAM Central East_VC limit as compared to the TCC Auction limit, which are not associated with transmission line outages.	



