### LI Reserve Modeling

#### Ethan D. Avallone

SENIOR MARKET DESIGN SPECIALIST - ENERGY MARKET DESIGN, NYISO

#### **Market Issues Working Group**

November 27, 2017 Rensselaer, NY



### **Agenda**

- Background
- Analysis
- Conclusion



# Background



### **Background**

- The NYISO implemented a limit to the amount of reserve held on LI with the implementation of Comprehensive Shortage Pricing on the November 4, 2015 market day
- This change increased the likelihood that reserve procured on LI would be deliverable to the rest of the NYCA



#### **NYISO** Review

- The NYISO continuously reviews many aspects of its operational procedures to ensure reliability
- Recent retirements on Long Island and shifting of load led the NYISO to reevaluate the LI reserve limitation
- The NYISO concluded that no change to the LI reserve modeling is necessary



### Current LI Reserve Limitation/ Reserve Requirements

	LI Reserve		
	Limitation		
Hour Beginning	(Requirement)		
HB00	324		
HB01	270		
HB02	270		
HB03	270		
HB04	270		
HB05	270		
HB06	374		
HB07	378		
HB08	432		
HB09	432		
HB10	486		
HB11	486		
HB12	486		
HB13	486		
HB14	486		
HB15	486		
HB16	540		
HB17	540		
HB18	540		
HB19	540		
HB20	540		
HB21	486		
HB22	432		
HB23	378		



# Analysis



#### **Analysis**

- Resource Energy production on LI can be increased to offset imports into LI over Y50/Y49/901 & 903, and thus deliver LI 30 minute reserve.
- The NYISO considered 660 MW a reasonable amount to evaluate as a possible new limitation to LI reserve



### **Analysis**

- The NYISO analyzed a data set for the time period of 1/1/2017 to 9/1/2017.
- This evaluation showed the current on peak\* LI 30 minute reserve limitation, ranging from 378 MW to 540 MW was, on average, deliverable 75.7% of the time
  - The off peak reserve limitation, ranging from 270 MW to 378 MW was, on average, deliverable 92.9% of the time.
- Increasing the LI reserve limitation to 660 on peak would mean the reserve was deliverable on peak only 46% of the time
  - Increasing the LI reserve limitation to 660 off peak would mean the reserve was deliverable off peak only 44.5% of the time




### **Analysis Summary**

This table shows the percent of the time the respective reserve limitation is deliverable in the given data set.

	Reserve Limit	Percent of Time Deliverable			
On Peak	660	46.0%		Reserve Limit Range	Average Percent of
				_	Time Deliverable
Off Peak	660	44.5%	On Peak	378 through 540	75.7%
			Off Peak	270 through 378	92.9%

NEW YORK INDEPENDENT SYSTEM OPERATOR

### **Aggregate LI Flows 1/1/2017 to 9/1/2017**





### Conclusion



#### **Conclusion**

- If the LI reserve limitation were to be increased, then more reserve would often be held on LI than was actually deliverable to the NYCA.
- The NYISO will continue to use the LI reserve limitation of 270 MW to 540 MW, depending upon the hour, that is currently in effect.
  - This limitation is equal to the reserve requirement that is in effect for each hour.
- The NYISO will continue to monitor LI operating reserve deliverability to the rest of the NYCA



# The Mission of the New York Independent System Operator is to:

- Serve the public interest and
- Provide benefit to stakeholders by
  - Maintaining and enhancing regional reliability
  - Operating open, fair and competitive wholesale electricity markets
  - Planning the power system for the future
  - Providing factual information to policy makers,
     stakeholders and investors in the power system



www.nyiso.com

