

# **Fuel Assurance & Pipeline Adequacy Study Presentation of Results**

**Electric-Gas Coordination Working Group  
New York Independent System Operator**

***October 23, 2013***

**R.L. Levitan, P.L. Curlett, S.Wilmer**

**LEVITAN & ASSOCIATES, INC.**  
MARKET DESIGN, ECONOMICS AND POWER SYSTEMS

# Task 1

## Fuel Assurance Study

# Study Objectives

- ◆ Identify dual-fuel capacity in NYCA
- ◆ Assess the cost of providing fuel assurance through dual-fuel capability and oil supply provisions
- ◆ Derive the incremental cost for primary FT entitlement(s) along discrete pathways to four zones
- ◆ Perform an economic comparison of dual-fuel capability v. pipeline transportation under a range of scenarios

# Existing Dual Fuel Capacity – Zones F through K



# Cost of Dual Fuel Capability

- ◆ Incremental costs for a 600 MW CC and a 200 MW SC were developed
- ◆ Capital cost categories include:
  - Power Island scope – manifold and burners, atomizing air, water injection, purge system, fuel conditioning skid, related instrumentation and controls
  - Fuel receiving and storage facilities – receiving bays (truck or barge), transfer pumps, storage tanks with containment walls, etc.
  - Balance of plant, i.e., demineralized water, receiving and storage systems

# Cost of Dual Fuel Capability (Cont'd)

- ◆ Operating costs include:
  - Fixed operating costs, i.e., fuel and water quality staff, property taxes, and insurance
  - Variable operating costs, i.e., higher gas turbine overhaul accrual rates, water costs for injection water (CC only)
  - Costs of ULSD supply, delivery and storage
    - High cost of fuel
    - Potential reservation charges for delivery capacity
    - Volumetric delivery charges
    - Inventory carrying cost

# Cost of Dual Fuel Capability – Combined Cycle

(2013\$)

Zone	Capital District	LHV	NYC	Long Island
<b>Capital Costs (\$ million)</b>				
Power Island	\$ 5.1	\$ 5.1	\$ 5.1	\$ 5.1
Field Erected Tanks	\$ 2.8	\$ 2.8	\$ 2.8	\$ 2.8
Balance of Plant	<u>\$ 9.8</u>	<u>\$11.0</u>	<u>\$14.4</u>	<u>\$13.7</u>
Subtotal	\$17.7	\$18.9	\$22.3	\$21.6
Financing Costs	<u>\$ 1.3</u>	<u>\$ 1.4</u>	<u>\$ 1.7</u>	<u>\$ 1.6</u>
Total Incremental Cost	\$19.0	\$20.3	\$24.0	\$23.3
<i>Incremental Unit Cost</i>	<i>\$29/kW</i>	<i>\$31/kW</i>	<i>\$37/kW</i>	<i>\$36/kW</i>
<b>Fixed O&amp;M Cost</b>				
(\$ 1,000 / year)	\$ 563	\$ 593	\$1,508	\$ 691
<i>Incremental Unit Cost</i>	<i>\$0.86/kW-yr</i>	<i>\$0.90/kW-yr</i>	<i>\$2.30/kW-yr</i>	<i>\$1.05/kW-yr</i>

# Cost of Dual Fuel Capability – Simple Cycle

(2013\$)

Zone	Capital District	LHV	NYC	Long Island
<b>Capital Costs (\$ million)</b>				
Power Island	\$ 3.1	\$ 3.1	\$ 3.1	\$ 3.1
Field Erected Tanks	\$ 1.1	\$ 1.1	\$ 1.1	\$ 1.1
Balance of Plant	<u>\$ 3.2</u>	<u>\$ 3.6</u>	<u>\$ 4.5</u>	<u>\$ 4.4</u>
Subtotal	\$ 7.4	\$ 7.8	\$ 8.7	\$ 8.6
Financing Costs	<u>\$ 0.5</u>	<u>\$ 0.5</u>	<u>\$ 0.6</u>	<u>\$ 0.6</u>
Total Incremental Cost	\$ 7.9	\$ 8.3	\$ 9.3	\$ 9.2
<i>Incremental Unit Cost</i>	<i>\$44/kW</i>	<i>\$45/kW</i>	<i>\$52/kW</i>	<i>\$50/kW</i>
<b>Fixed O&amp;M Cost</b>				
(\$1000 / year)	\$ 250	\$ 259	\$ 665	\$ 295
<i>Incremental Unit Cost</i>	<i>\$1.38/kW-yr</i>	<i>\$1.41/kW-yr</i>	<i>\$3.68/kW-yr</i>	<i>\$1.61/kW-yr</i>




# Unitized Cost of Firm Transportation Entitlements


Zone	Selected Path	100% Load Factor Rate (\$/Dth)	Combined Cycle		Simple Cycle	
			Annual Fixed Charges (\$MM/yr)	Unitized Variable Charge (\$/MWh)	Annual Fixed Charges (\$MM/yr)	Unitized Variable Charge (\$/MWh)
F	Dominion (from South Point)	\$0.6159	\$23.8	\$0.16	\$9.7	\$0.22
G-H-I	Millennium → Algonquin	\$1.0920	\$43.6	\$0.04	\$17.8	\$0.05
J	Tennessee → Texas Eastern (→ NYFS)	\$1.1255	\$45.0	\$0.03	\$18.4	\$0.03
K	Millennium → Algonquin → Iroquois (→ NYFS)	\$1.6325	\$65.2	\$0.05	\$26.7	\$0.07

# Incremental Cost of Firm Transportation to NYC





Levelized Annual Cost (2013 \$/kW-yr)




# Pipelines Serving NYC and Long Island




# Pipeline Utilization Levels Serving NYC and Long Island



# Financial Results – 600 MW CC



# Financial Results – 200 MW SC



# Fuel Assurance Conclusions

- ◆ Total incremental cost to add dual-fuel capability
  - CC: ~\$19 million in Capital District / LHV, ~\$24 million in NYC / Long Island
  - Peaker: ~\$8 million in Capital District / LHV, ~\$9 million in NYC / Long Island
- ◆ For new CC plants:
  - FT strategy is economic in relation to non-firm gas + ULSD in Capital District and LHV
  - FT upstream of the NYFS is economic for NYC, neutral for Long Island
- ◆ For new peakers:
  - FT strategy is economic in relation to non-firm transportation + ULSD for Capital District, uneconomic in LHV
  - FT to NYC / Long Island is uneconomic

# Fuel Assurance Conclusions (cont'd)

- ◆ Most gas-fired generators across NYCA rely on short-term capacity releases and/or IT
- ◆ Generator reliance on non-firm transportation coupled with oil back-up promotes, but does not guarantee, fuel adequacy during critical conditions
- ◆ Major new P/L resources sure to improve “quality” of non-firm transportation in the Capital District & NYC
- ◆ Known and potential retirements in LHV heighten concerns re infrastructure adequacy for new CCs
- ◆ Timing of new P/L receipt point capability on Long Island into the NYFS remains uncertain
- ◆ Energy / capacity price signals and penalty structure for non-performance appear insufficient to induce generators to hold maximum oil inventory



# Task 2

## Pipeline Congestion and Infrastructure Adequacy Assessment


# Study Objectives

- ◆ Analyze historical pipeline congestion patterns across NYCA
- ◆ Forecast supply / demand to determine available capacity to serve gas-fired generation
- ◆ Assess the impact of pipeline additions over a five-year study horizon into and across New York State
- ◆ Identify potentially disruptive gas-side contingencies across the supply chain from the producing area to the market center (CEII)


# Historical Congestion Analysis Key Findings

- ◆ Infrastructure serving NYFS and NYCA-at-large has been frequently constrained, Nov - March
- ◆ High oil-to-gas price ratios and environmental restrictions have increased NYC's reliance on natural gas during the summer
- ◆ Utilization levels on Empire, Algonquin and Tennessee are increasingly high, reflecting downstream demand for shale gas (core and non-core) in Ontario and New England
- ◆ Planned maintenance scheduled during shoulder months minimizes disruption to FT shippers, but can cause short term disruptions for non-core
- ◆ Forced outages rare / short duration


# Heating Season Peak Day Congestion (Current)




# Cooling Season Peak Day Congestion (Current)




# NYFS Deliveries Into NYFS



# Tennessee Station 245




# Regional Supplies – Production & Storage






# Peak Day Boundary Flows Into and Out of NYCA




# Canadian Boundary Flow Dynamics

- ◆ Previously, gas delivered into NYCA at Niagara (Tennessee), Chippawa (Empire) and Waddington (Iroquois)
  - Niagara is now an export point
  - Chippawa poised for exports not imports
  - Waddington operating at full capacity only on peak days
- ◆ Canadian gas into New England materially lower
  - Decline from western Canada into Tennessee and Iroquois
  - Decline from Atlantic Canada from Sable Island
  - Very low exports from Deep Panuke
  - Low utilization of Repsol Canaport LNG terminal
  - Destination flexible LNG cargoes headed to EU / Asia


# Pipeline Expansion Projects




# Boundary Flow Changes Over Study Horizon




# In-State Storage and Production




# Total Supply Available to Serve Demand



# Core (LDC) Demand Forecast




# LDC Service Territories







# Supply Relative to Core Demand




# Non-Core Demand Forecast



# Supply v. Non-Core Demand (Base Case)



# NYFS Deliverability (Base Case)



# State-Wide Infrastructure Adequacy Results

- ◆ Infrastructure and supplies sufficient to meet non-core demand
  - Intra-state constraint point analysis not part of study scope
- ◆ Generation demand differential between Base and +1,000-MW Cases does not significantly impact results
- ◆ New P/L facilities to come online 11/13 will relieve downstate infrastructure constraints, but not on the NYFS
  - During January 2013 cold snap, over 500 MW of generation experienced fuel-related de-rates (Jan 22<sup>nd</sup>)

# Contingency Analysis

- ◆ Active coordination between pipelines and LDCs to manage contingency response
- ◆ Identification of potential anomalies during shoulder season inspections reduces contingency occurrence during peak demand periods
- ◆ Compressor station contingencies generally resolved much faster than P/L contingencies
- ◆ Repair times were consistently underestimated

# Contingency Event Durations and Causes

