

Task 7

Congestion Analysis and Transmission System Upgrades

Task 7 – Methodology

- ◆ **Evaluation of Transmission Limitations**
 - *Review projects' actual capacity factor vs. perfect production to determine level of bottling*
 - *Identify specific transmission constraints (limiting element/contingency) for each project (or group of projects)*
 - *Consistent with TOs local Planning Criteria, Rules, Standards and Operating Procedures*
 - *Identify possible upgrades on limiting elements/transmission facilities*

Transmission Upgrades

- ◆ Considerations
 - ***Scope of upgrades***
 - Single project
 - Small group of projects
 - General system (wide-area) projects
 - ***Types of upgrade***
 - Terminal limitations
 - Conductor limitations
 - Complete rebuild
 - Reconfiguration
- ◆ Upgrades included in project facility studies are assumed available

Transmission Constraints


- ◆ Major transmission constraints identified in three local areas:
 - Corning/Elmira
 - Willis/Plattsburgh
 - Watertown/Thousand Islands
- ***Limiting elements are primarily local 115kV***
- ***Limiting contingencies include***
 - EHV contingencies (d/c tower, stuck breaker)
 - Parallel path EHV
 - 115kV double circuit (d/c) tower
 - Parallel path 115kV

Summary of Energy Bottling

- ◆ Wind Resource Energy bottling is based on a project's actual capacity factor vs. "perfect production" capacity factor
 - ***Identify transmission constraint(s) causing the capacity factor reduction***
 - ***Identify project(s) constrained by limitation***
- ◆ Modify simulation model with upgrade(s) and repeat simulation to measure benefit

Upgrade Scenario Results

Zone	Wind Capacity	Base	Step 1	Step 2	Step 3	Step 4	Step 5	Step 6	Step 7
A	1309	0.1%	0.1%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
B	281	0.1%	0.1%	0.0%	0.1%	0.0%	0.0%	0.0%	0.0%
C	1591	6.1%	4.5%	3.9%	1.2%	0.2%	0.0%	0.0%	0.0%
D	1068	15.0%	12.0%	2.5%	1.7%	1.7%	1.7%	1.7%	1.7%
E	1648	15.8%	15.1%	14.0%	11.1%	10.4%	11.0%	8.0%	3.3%
F	70	0.1%	0.1%	0.1%	0.1%	0.2%	0.1%	0.1%	0.2%
Total	5967	8.8%	7.7%	5.4%	3.7%	3.2%	3.4%	2.5%	1.2%



System Limitations

- ◆ EHV constraints identified in the simulations
 - ***These are (historical) constraints that are not unique to the addition of wind generation***
 - ***Leeds – Pleasant Valley 345kV***
 - ***Rock Tavern – Ramapo 345kV***
 - ***Existing contingencies – New constraints***
 - ***Oakdale 345kV (exit) tower, stuck breaker***
 - ***Hillside 230kV (exit) tower***

Evaluation of Upgrades

- ◆ Identify specific transmission line(s) and needed capacity (rating)
 - ***Review upgrades with Transmission Owner(s)***
 - Identify line terminal upgrades that will allow operation up to conductor ampacity
 - Determine feasibility of reconductoring as remediation option vs. rebuilding
 - ***Identify projects' benefit***
- ◆ Other considerations
 - ***Timing of wind projects***
 - ***TO plans for facility upgrade/renewal***

Simulation of Upgrades

- ◆ Develop a sequence of upgrades to address the identified wind resource bottling
 - *Up to 7 simulation scenarios were developed to quantify the upgrades to reduce bottled energy <2% within any Zone*
 - *Used production cost simulations to identify the limiting contingency(ies) and elements and “needed relief” to size the upgrade (and quantify benefit)*

Southern Tier

- ◆ *NYSEG portion of Zone C*
- ◆ Existing capacity 364MW
- ◆ Proposed additional capacity 586MW
- ◆ Identified constraints in several locations
 - ***Locations potentially limited by local 115kV (pre-contingency loading)***
 - *Bennett – Bath 115kV*
 - *Meyer – Greenidge 115kV*
 - ***Pre-contingency loading limitations may be resolved by line terminal upgrades and/or reconductoring***


Zone C Constraints

- ◆ **Pre-contingency loading**
 - **Bennett – Bath – Montour Falls 115kV**
 - **Bennett – Moraine Rd – Meyer 115kV**
 - **Eel Pot Rd – Flat St – Greenidge 115kV**

- ◆ **Contingency overloads**
 - **Avoca – Hillside 230kV**
 - **Montour Falls – Ridge Rd 115kV**
 - **Eel Pot Rd – Flat St – Greenidge 115kV**
 - **Hillside – No. Waverly 115kV**

- ◆ **Mitigations**
 - **Upgrade 230kV to design conductor rating**
 - **Reconductor 115kV**

Southern Tier Constraints (west)



Southern Tier (2)

- ◆ **Larger group of projects limited by 115kV line for EHV contingencies**
 - ***(preceding group + additional 490MW)***
 - ***Hillside 230kV tower***
 - ***Oakdale 345kV transmission***
 - ***Oakdale 345kV tower***
 - ***Oakdale 345kV stuck breaker***
 - ***EHV station exit reconfiguration to mitigate tower contingencies at Hillside, Oakdale***
 - ***Reconductor/rebuild limiting elements:***
 - ***Montour Falls – Ridge Road 115kV (2 circuits)***
 - ***Hillside – No. Waverly 115kV***

Southern Tier (3)

- ◆ **Zone E Constraint impacts all projects in So. Tier (Zone C) and project in Zone E:**
 - ***Generally limits west-to-east transfers***
 - ***Delhi – Fraser Tap 115kV limiting for Contingencies:***
 - ***Oakdale – Fraser 345kV***
 - ***Oakdale 345kV stuck breakers***
 - ***Upgrade to conductor design rating:***
 - ***Delhi – Fraser Tap section of Delhi – Colliers 115kV***

Southern Tier Constraints (east)



Zone C Upgrade Projects

Step	Zone	Upgrade Project	Cost k\$
1	C	Reconfigure Hillside 230kV exit	2000
1	C	Reconfigure Oakdale 345kV exit	3000
2	C	Reconductor (2) Montour Falls-Hillside 115kV	20900
2	C	Reconductor Hillside-N.Waverly 115kV	17500
2	C	Upgrade Hillside line#68 terminal	1000
2	E	Upgrade protections Delhi-Colliers	750
3	C	Upgrade terminals Bennett-Howard-Bath 115kV	1000
3	C	Upgrade terminals Bath Montour Falls 115kV	2000
3	C	Upgrade terminals Bennett-Moraine Rd-Meyer 115kV	2000
4	C	Upgrade terminals Meyer-Greenidge 115kV	250
5	C	Reconductor Eel Pot Rd-Greenidge 115kV	15400
		Total	65800

Zone D Constraints

- ◆ **Pre-contingency loading**
 - (none)

- ◆ **Contingency overloads**
 - **Moses – Willis 230kV**
 - **Duley/Ryan – Plattsburgh 230kV**
 - **Plattsburgh 230/115kV**
 - **Willis – Colton 115kV**

Zone D Constraints (continued)


◆ Mitigations

- **Reconfigure Moses 230kV exit tower**
 - *115kV no longer limiting*
- **Upgrade 230kV to design conductor rating**
 - *Upgrade terminal equipment*

Willis/Plattsburgh Area

- ◆ **Existing wind capacity** **387 MW**
- ◆ **Proposed additional capacity** **681 MW**
- ◆ **1st constraint – 115kV Willis-Malone-Colton for loss of d/c 230kV St. Lawrence-Willis (tower)**
 - ***Assume reconfiguration of the Moses/St. Lawrence exit to mitigate the d/c tower contingency***
 - ***Next transmission constraints:***
 - **Plattsburgh 230/115 transformers**
 - **Moses-Willis-Plattsburgh 230kV terminal equipment**

Northern NY Constraints



Zone D Upgrade Projects

Step	Zone	Upgrade Project	Cost k\$
1	D	Reconfigure Moses 230kV exit	2000
2	D	Plattsburgh 230kV terminal upgrades	
3	D	Upgrade terminals Moses-Willis 230kV	2000
4	D	Plattsburgh 230kV ring bus	16000
		Total	20000

Zone E Constraints

◆ Pre-contingency loading

- Rockledge – Coffeen St 115kV
- Coffeen St – Black River 115kV
- Lighthouse Hill – Mallory 115kV

◆ Contingency overloads

- Coffeen St – Black River 115kV
- Black River – Taylorville 115kV
- Taylorville – Boonville 115kV
- Black River – Lighthouse Hill – Mallory 115kV
- Indian River – Black River 115kV

Zone E Constraints (continued)

- ◆ Mitigations

- **Reconductoring Watertown area facilities may not be feasible due to required conductor size and tower design and age**
- **Alternative EHV overbuild may be indicated specifically for the Watertown pocket**

Watertown "Pocket"

- ◆ **Proposed capacity** **716 MW**
- ◆ **Identified constraints**
 - ***Local 115kV radial from projects to Watertown***
 - **Lyme Tap – Coffeen St 115kV (pre-ctg loading)**
 - **Coffeen St – Black River 115kV**
 - ***115kV tower contingencies (east, south) cause severe overload of remaining circuits***
 - **Black River – Taylorville 115kV**
 - **Black River – Lighthouse Hill 115kV**


Watertown "Pocket" (continued)

- ◆ **Proposed capacity** **716 MW**
- ◆ **Identified constraints continued**
 - ***Reconductor/rebuild transmission paths***
 - **Black River – Taylorville 115kV**
 - **Lighthouse Hill – Mallory 115kV**
 - **Coffeen St – Black River 115kV**
 - **Taylorville – Boonville 115kV**

Zone E Upgrade Projects (1)

Step	Zone	Upgrade Project	Cost k\$
2	E	Upgrade protections Delhi-Colliers	750
3	E	Rebuild Lighthouse Hill-Mallory 115kV	41855
3	E	Rebuild Lyme Tap-Coffeen St 115kV #4	9588
3	E	Upgrade Lyme-Lyme Tap 115kV #4	250
7	E	Rebuild Coffeen St-Black River #3	9160
7	E	Upgrade terminals Indian River-Black River 115kV #9	500
7	E	Build 2nd Rockledge-Coffeen St 115kV	24545
		Total	86648


Watertown Area Constraints



Watertown 115kV Upgrade

Step	Zone	Upgrade Project	Cost k\$
5	E	Rebuild Black River-Lighthouse Hill #5 & 6, and Taylorville-Boonville #5 & 6	119868
6	E	Rebuild Black River-Taylorville #1, 2 & 8	38693
		Total	158561

Watertown 230kV Alternate



Watertown 230kV Upgrade

Step	Zone	Upgrade Project	Cost k\$
2	E	Upgrade terminal connections Black River - Taylorville 115kV #1, 2, & 8	600
3	E	Upgrade terminals Coffeen St-Black River 115kV #3	500
4	E	Upgrade terminals Taylorville-Boonville 115kV #5 & 6	1000
8	E	Build new 230kV Coffeen St-Adirondack 230kV	132000
		Total	134100

Summary Results for 6000MW Case

6000 Base Case - Comparison of Watertown Reinforcements					
Zone	Wind Capacity	Base Case	System Upgrades	Watertown 115kV Alt.	Watertown 230kV Alt.
A	1309	0.1%	0.0%	0.0%	0.0%
B	281	0.1%	0.0%	0.0%	0.0%
C	1591	6.2%	0.4%	0.3%	0.5%
D	1068	11.3%	1.7%	1.7%	1.7%
E	1648	13.7%	8.2%	3.2%	3.6%
F	70	0.1%	0.1%	0.1%	0.1%
Total	5967	7.6%	2.7%	1.3%	1.4%

Summary of Upgrades

- ◆ **Existing EHV transmission adequate**
 - *No indication of major EHV capacity needs*

- ◆ **EHV Transmission upgrades**
 - ***Limited mitigations necessary to relieve constraints***
 - Double-circuit tower contingencies
 - Line terminal upgrades

- ◆ **Similar results for 8000MW buildout case**

Summary Results for 8000MW Case

8000 Base Case - Comparison of Watertown Reinforcements					
Zone	Wind Capacity	Base Case	System Upgrades	Watertown 115kV Alt.	Watertown 230kV Alt.
A	1510	0.1%	0.1%	0.1%	0.1%
B	418	0.1%	0.0%	0.0%	0.0%
C	1860	6.2%	0.5%	0.5%	0.6%
D	1068	11.6%	1.7%	1.7%	1.7%
E	1648	13.5%	7.7%	3.0%	2.9%
F	70	0.2%	0.4%	0.4%	0.4%
J	700	0.0%	0.0%	0.0%	0.0%
K	700	0.0%	0.0%	0.0%	0.0%
Total	7974	5.8%	1.9%	1.0%	1.0%

Summary of Upgrades (2)

- ◆ Local 115kV Transmission Upgrades
 - *Impact groups of projects*
 - *Certain projects necessary only if all projects in a constrained group are realized*
- ◆ Watertown most significantly constrained
 - *5 proposed projects impacted by very limited capacity double circuit transmission network*
 - *Tower design and age and conductor size precludes re-conductoring*
 - Will require complete rebuilding to accommodate the projected wind resources proposed
 - Alternative 230kV upgrade could be economically attractive and benefit local reliability

Summary of “Bottled Energy”

6000 Base Case - Bottled Energy (MWhr)					
Zone	Wind Capacity	Base Case	System Upgrades	Watertown 115kV Alt.	Watertown 230kV Alt.
A	1309	1,965	1,720	1,708	1,684
B	281	682	310	226	398
C	1591	286,368	16,380	16,093	21,438
D	1068	365,160	53,504	53,459	53,278
E	1648	647,623	390,202	153,768	171,055
F	70	217	247	244	295
Total	5967	1,302,014	462,363	225,498	248,149

Summary of Upgrades (3)

- ◆ **Bottom line – estimated cost of upgrades and net energy production from wind:**
 - **Zone C** **\$ 65.8 M**
 - *Net wind energy production increase: 259.4 GWhr*

 - **Zone D** **\$ 20.0 M**
 - *Net wind energy production increase: 311.6 GWhr*

Summary of Upgrades (continued)

- ◆ **Bottom line – estimated cost of upgrades and net energy production from wind:**
 - **Zone E** **\$ 220.748 – 245.209 M**
 - System **\$ 86.648M**
 - *Net wind energy production increase: 257.4 GWhr*
 - Watertown Alternates
 - Watertown 115kV **\$158.561M**
 - *Net wind energy production increase: 246.4 GWhr*
 - Watertown 230kV **\$134.1 M**
 - *Net wind energy production increase: 219.1 GWhr*

Task 7

Stability Analysis Update

Off-Peak / High Wind Case

- ◆ **Central East level 3399 MW based on Oswego Complex commitment (3/5, 4/6 Site)**
 - ***Total Wind generation dispatch 6572 MW***
 - ***NYCA load+losses 17202 MW***
 - ***Total NYCA generation (net) 14796 MW***
 - ***Total pump/gen -1555 MW***

Off-Peak / High Wind Case (continued)

◆ Interface flows

- *Dysinger East* *1602 MW*

- *West Central* *887 MW*

- *Moses-South* *1587 MW*

- *Total East* *7494 MW*

- *UPNY-SENY* *4789 MW*

- *UPNY-ConEd* *2264 MW*

Peak Load / High Wind Case (continued)

◆ Interface flows

- *Dysinger East* **2048 MW**
- *West Central* **943 MW**
- *Moses-South* **1689 MW**
- *Total East* **7671 MW**
- *UPNY-SENY* **6872 MW**
- *UPNY-ConEd* **4145 MW**

Contingency Tests

- ◆ **Central East contingencies**
 - ***CE01 – 3ph NC Edic-N.Scotland #14***
 - ***CE02 – 3ph NC Marcy-N.Scotland #18***
 - ***CE07 – LLG NC Edic/Marcy EF40/UCC41***
 - ***CE08 – LLG NC Coopers Corners #33/UCC41***
 - ***CE15 – SLG-stk Marcy #19/UE1-7***
 - ***CE18 – LLG NC Rock Tavern CCRT34/CCRT42***
- ◆ ***Responses of key indicators compared in each of the tested cases***

Stability Analysis

- ◆ **Summary of base case set-up**
 - ***Import data from GV simulation***
 - Generation commitment and dispatch
 - NYCA load
 - External schedules
 - ***Primary testing: Central East interface***
 - ***Increase available generation in western NY to margin transfer test level ~ 3400 MW***
- ◆ **Detailed analyses of results discussed at previous Workshops**

Stability Results

- ◆ **System exhibits stable response at tested transfer levels**
 - *No indication of adverse impact on unit or system stability*
 - *No potential transfer limitations*
- ◆ **Wind projects' performance acceptable**
 - *No indication of over/under voltage tripping*
 - *No indication of over/under frequency tripping*
- ◆ **System response is stable and well damped**