

# 2018 RNA Preliminary Reliability Needs

---

Laura Popa

Manager, Resource Planning

**ESPWG/TPAS**

June 22, 2018, KCC

DRAFT – FOR DISCUSSION PURPOSES ONLY

©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED



# Goals

- **This presentation summarizes the 2018 RNA preliminary Base Case results**
  - No scenario results complete at this time
  - The scenarios will be finalized based on the original (“preliminary”) RNA Base Case
  - The 2018 RNA major assumptions were presented at ESPWG/TPAS meetings from February through June 1, 2018
- **The objective of providing the stakeholders preliminary (“1st pass”) Reliability Needs (RN) is to offer another opportunity prior to the final RNA for stakeholders’ input regarding updates in projects and plans which may mitigate any identified RN**
  - To minimize unnecessary solutions solicitation

DRAFT – FOR DISCUSSION PURPOSES ONLY

# Preliminary vs Final RN: Process Description

- In finalizing the RN, system changes that occurred since the initial lock down date of the RNA assumptions will be considered, such as:
  - Updated LTPs that may impact the Reliability Needs
    - If any pertinent LTP updates, then the Transmission Owner will present updates at either June 28 or July 2 ESPWG/TPAS meetings
  - Changes in BPTFs
  - Change in resources such as generating unit status, load forecast, or demand response that may impact the Reliability Needs

# 2018 RPP Background

- **The 2018 Reliability Planning Process (RPP) starts with the 2018 Reliability Needs Assessment (2018 RNA) followed by the Comprehensive Reliability Plan (CRP)**
  - 2018 RNA Study Period: year 1 = 2019 through year 10 = 2028
- **The RPP is part of the Comprehensive System Planning Process and is performed pursuant to the Attachment Y of the NYISO OATT; see Section 31.2.**
  - Additional implementation details, including recently updated RNA Base Case inclusion rules, are captured in the RPP Manual #26
- **2018 RNA is based on the information from the Gold Book 2018, the 2018 FERC 715 filing (power flow cases and auxiliary files), historical data, and market participant data**

# 2018 RNA Base Case Development Background

- Based on the RNA Base Case, the NYISO identifies Reliability Needs of the New York State Bulk Power Transmission Facilities (BPTFs) in accordance with applicable Reliability Criteria (*i.e.*, NERC, NPCC, and NYSRC)
- Reliability evaluations consist of resource adequacy and transmission security evaluations of the New York Bulk Power Transmission Facilities over a ten-year Study Period
- **2018 RNA Base Case:**
  - For the transmission security evaluations, the NYISO uses the 2018 FERC Form 715 filing and the information from the 2018 Gold Book as a starting point for developing the base case system models with the application of the inclusion rules.
  - For the resource adequacy evaluation, the models are developed starting with prior resource adequacy models, and are updated with information from the 2018 Gold Book and historical data, with the application of the inclusion rules. Information on modeling of neighboring systems is based on the input received from the NPCC CP-8 working group.
- In January 2018, an updated Manual 26 was approved and posted with the only change being in Section 3; mainly related to the RNA Base Case development and its inclusion rules
- The inclusion rules are used as guidelines to determine what proposed projects will be included in the RNA Base Case, and also how to treat generator deactivations

# RNA Major Assumptions

# 2018 RNA Summer Peak Load Forecast Assumptions

## Topline (former Econometric), Baseline and Adjusted Summer Peak Forecast

Annual MW	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
<b>2018 Topline* Forecast</b>	33,763	34,099	34,367	34,554	34,727	34,946	35,132	35,442	35,750	35,982	36,154
<b>2018 Gold Book Baseline**</b>	32,904	32,857	32,629	32,451	32,339	32,284	32,276	32,299	32,343	32,403	32,469
<b>+ 2018 Solar PV</b>	440	566	689	774	843	889	928	963	989	1,017	1,038
<b>2018 RNA RA Base Case***</b>	33,344	33,423	33,318	33,225	33,182	33,173	33,204	33,262	33,332	33,420	33,507

## Comparison of Base Case Peak Forecasts - 2016 & 2018 RNA (MW)

Annual MW	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
<b>2016 RNA RA Base Case***</b>	33,618	33,726	33,825	33,948	34,019	34,120	34,256	34,393	34,515	34,646	34,803		
<b>2018 RNA RA Base Case***</b>			33,344	33,423	33,318	33,225	33,182	33,173	33,204	33,262	33,332	33,420	33,507
<b>Change from 2016 RNA</b>			-481	-525	-701	-895	-1,074	-1,220	-1,311	-1,384	-1,471	NA	NA

\* The topline forecast will be used for the resource adequacy scenario

\*\* The transmission security power flow RNA base cases use this Gold Book baseline forecast

\*\*\*For the resource adequacy (RA) study RNA Base Case, the 2018 Gold Book baseline load forecast was modified by removing the behind-the-meter solar PV impacts in order to model the solar PV explicitly as a generation resource to account for the intermittent nature of its availability

The Gold Book 2018 contains additional details on the load forecast:

[http://www.nyiso.com/public/webdocs/markets\\_operations/services/planning/Documents\\_and\\_Resources/Planning\\_Data\\_and\\_Reference\\_Docs/Data\\_and\\_Reference\\_Docs/2018-Load-Capacity-Data-Report-Gold-Book.pdf](http://www.nyiso.com/public/webdocs/markets_operations/services/planning/Documents_and_Resources/Planning_Data_and_Reference_Docs/Data_and_Reference_Docs/2018-Load-Capacity-Data-Report-Gold-Book.pdf)

Queue #	Project Name	Zone	CRIS Request	SP MW	Interconnection Status
<b>Proposed Generation Additions</b>					
251	CPV Valley Energy Center	G	680.0	677.6	CY11
349	Taylor Biomass	G	19.0	19.0	CY11
395	Copenhagen Wind	E	79.9	79.9	CY15
403	Bethlehem Energy Center Uprate	F	78.1	72.0	CY15
387	Cassadaga Wind	A	126.0	126.0	CY17
421	Arkwright Summit	A	78.4	78.0	CY17
444	Cricket Valley Energy Center II	G	1020.0	1020.0	CY17
461	East River 1 Uprate	J	n/a	2.0	CY17
462	East River 2 Uprate	J	n/a	2.0	CY17
467	Shoreham Solar	K	24.9	25.0	CY17
510	Bayonne Energy Center II	J	120.4	120.4	CY17
511	Ogdensburg	E	79.0	79.0	CY17
N/A	Nine Mile Point 2	C	63.4	63.4	CY17 (CRIS only)
N/A	East River 6	J	8.0	N/A	CY17 (CRIS only)
<b>MW additions from 2016 RNA</b>			<b>1,598</b>	<b>1,588</b>	
<b>Total MW gen. additions</b>			<b>2,377</b>	<b>2,364</b>	

# Proposed Generation Projects Included in the 2018 RNA preliminary Base Case

Also included in the  
2016 RNA



# Proposed Transmission Projects Included in the 2018 RNA Base Case

- All firm LTPs from the Gold Book 2018 were included in the 2018 RNA preliminary Base Case
- The Q545A Western NY - Empire State Line is also included

# Assumed Generation Deactivations

Owner/Operator	Plant Name	Zone	CRIS	2018 RNA Base Case Status*	2016 RNA Base Case Status
Helix Ravenswood LLC	Ravenswood 04	J	15.2	out	out
	Ravenswood 05	J	15.7	out	out
	Ravenswood 06	J	16.7	out	out
International Paper Company	Ticonderoga	F	7.6	out	in
Niagara Generation LLC	Niagara Bio-Gen	A	50.5	out	out
NRG Power Marketing LLC	Dunkirk 2	A	97.2	out	out
	Huntley 67	A	196.5	out	out
	Huntley 68	A	198.0	out	out
	Astoria GT 05	J	16.0	out	out
	Astoria GT 07	J	15.5	out	out
	Astoria GT 08	J	15.3	out	out
	Astoria GT 10	J	24.9	out	out
	Astoria GT 11	J	23.6	out	out
	Astoria GT 12	J	22.7	out	out
	Astoria GT 13	J	24.0	out	out
	ReEnergy Black River LLC	Fort Drum	E	55.6	out
Chateaugay Power		D	18.6	out	out
Binghamton BOP, LLC	Binghamton	C	43.8	out	in
Helix Ravenswood, LLC	Ravenswood 09	J	21.7	out	in
Entergy Nuclear Power Marketing, LLC	Indian Point 2	H	1027.0	out	in
	Indian Point 3	H	1040.0	out	in
Selkirk Cogen Partners, LP	Selkirk 1	F	82.1	out	in
	Selkirk 2	F	291.3	out	in
J- Power USA Generation, LP Edgewood Energy, LLC	PPL Pilgrim ST GT1	K	45.6	out	in
	PPL Pilgrim ST GT2	K	46.2		
Helix Ravenswood, LLC	Ravenswood 2-1	J	40.4	out	in
	Ravenswood 2-2	J	37.6		
	Ravenswood 2-3	J	39.2		
	Ravenswood 2-4	J	39.8		
	Ravenswood 3-1	J	40.5		
	Ravenswood 3-2	J	38.1		
	Ravenswood 3-4	J	35.8		
Lyonsdale Biomass, LLC	Lyonsdale (Burrows)	E	20.2	out	in
R.E. Ginna Nuclear Power Plant, LLC	Ginna	B	582.0	in	out
Cayuga Operating Company, LLC	Cayuga 1	C	154.1	in	out
	Cayuga 2	C	154.7	in	out
Entergy Nuclear Power Marketing LLC	Fitzpatrick 1	C	858.9	in	out
change in status	<b>Changes in deactivations since 2016 RPP</b>		<b>1,203</b>		
	<b>Total 2018 RNA MW assumed as deactivated</b>		<b>3,703</b>		

\* Consistent with the deactivation dates



DRAFT - FOR DISCUSSION PURPOSES ONLY

Year		2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
		<b>Peak Load (MW) -Gold Book 2018 NYCA Baseline</b>									
	NYCA*	32,857	32,629	32,451	32,339	32,284	32,276	32,299	32,343	32,403	32,469
	Zone J*	11,474	11,410	11,363	11,336	11,328	11,335	11,350	11,372	11,399	11,429
	Zone K*	5,323	5,278	5,246	5,231	5,229	5,237	5,251	5,268	5,287	5,306
	Zone G-J*	15,815	15,715	15,639	15,594	15,574	15,576	15,591	15,616	15,648	15,685
		<b>Resources (MW)</b>									
	Capacity**	39,230	39,358	38,339	38,339	38,339	38,339	38,339	38,339	38,339	38,339
	Net Purchases & Sales	1,279	1,785	1,800	1,942	1,942	1,942	1,942	1,942	1,942	1,942
	SCR	1,219	1,219	1,219	1,219	1,219	1,219	1,219	1,219	1,219	1,219
	Total Resources	41,728	42,362	41,358	41,500	41,500	41,500	41,500	41,500	41,500	41,500
	Cap+NetPurch+SCR/Load Ratio	127.0%	129.8%	127.4%	128.3%	128.5%	128.6%	128.5%	128.3%	128.1%	127.8%
	Capacity**	9,562	9,562	9,562	9,562	9,562	9,562	9,562	9,562	9,562	9,562
	UDR Awarded	975	975	975	975	975	975	975	975	975	975
	SCR	392	392	392	392	392	392	392	392	392	392
	Total Resources	10,929	10,929	10,929	10,929	10,929	10,929	10,929	10,929	10,929	10,929
	Cap+UDR+SCR/Load Ratio	95.2%	95.8%	96.2%	96.4%	96.5%	96.4%	96.3%	96.1%	95.9%	95.6%
	Capacity**	5,220	5,220	5,220	5,220	5,220	5,220	5,220	5,220	5,220	5,220
	UDR Awarded	990	990	990	990	990	990	990	990	990	990
	SCR	48.13	48.13	48.13	48.13	48.13	48.13	48.13	48.13	48.13	48.13
	Total Resources	6,258	6,258	6,258	6,258	6,258	6,258	6,258	6,258	6,258	6,258
	Cap+UDR+SCR/Load Ratio	117.6%	118.6%	119.3%	119.6%	119.7%	119.5%	119.2%	118.8%	118.4%	117.9%
	Capacity**	15,371	15,373	14,354	14,354	14,354	14,354	14,354	14,354	14,354	14,354
	UDR Awarded	975	975	975	975	975	975	975	975	975	975
	SCR	475	475	475	475	475	475	475	475	475	475
	Total Resources	16,821	16,823	15,804	15,804	15,804	15,804	15,804	15,804	15,804	15,804
	Cap+UDR+SCR/Load Ratio	106.4%	107.0%	101.1%	101.3%	101.5%	101.5%	101.4%	101.2%	101.0%	100.8%

# 2018 RNA Load and Capacity Summary

## Notes:

\*NYCA load values represent baseline coincident summer peak demand (which includes reductions due to energy efficiency programs, building codes, BtM solar, and non-solar distributed energy generation). Zones J and K load values represent non-coincident summer peak demand. Aggregate Zones G-J values represent G-J coincident peak, which is non-coincident with NYCA.

\*\*NYCA Capacity values include resources electrically internal to NYCA, additions, re-ratings, and retirements (including proposed retirements and mothballs). Capacity values reflect the lesser of CRIS and DMNC values. NYCA resources include the net purchases and sales as per the Gold Book. Zonal totals reflect the awarded UDRs for those capacity zones



DRAFT – FOR DISCUSSION PURPOSES ONLY

# 2018 RNA: Load and Resources Comparison for Study Year 5 (2023)

Year 2023	2018 RNA	2016 RNA	Delta
Baseline* Load	32,284	33,748	-1,464
Total Resources**	41,500	41,147	353
Net Margin: Change in (net capacity - net load)			<b>1,817</b>

Notes:

\*includes the reductions due to projected energy efficiency programs, building codes and standards, distribution energy resources and behind-the-meter solar photovoltaic power; it also reflects expected impacts (increases) from projected electric vehicle usage.

\*\*includes the total Special Case Resources (SCR), and net capacity purchases and sales from the Gold Book 2018

DRAFT – FOR DISCUSSION PURPOSES ONLY

# Resource Adequacy Preliminary Results

# 2018 Preliminary RNA LOLE Results

- RNA Base Case LOLE preliminary results:

Year	NYCA LOLE <i>days/year</i>
2019	0.01
2020	0.00
2021	0.01
2022	0.01
2023	0.01
2024	0.01
2025	0.01
2026	0.01
2027	0.01
2028	0.01

- RA conclusion: LOLE < 0.1 criterion; therefore, no resource adequacy Reliability Needs are identified as result of this assessment

# Transmission Security Preliminary Results

# Transmission Security Preliminary Conclusions

- Evaluated Year 1 (2019), Year 5 (2023), Year 10 (2028) summer peak baseline power flow cases
- No Reliability Needs identified for Year 1 and Year 5
- Year 10 showed a 3 MW deficiency in Eastern Long Island
  - A 1% overload on Brookhaven to Riverhead 138 kV (Line 864)
  - Contingency is the loss of Wildwood to Riverhead 138 kV (Line 890) and returning the system to Normal Criteria (N-1-0 criteria violation)



# Next Steps

# Next Steps

- June 22 ESPWG/TPAS: Present preliminary (“1<sup>st</sup> pass”) RNA results
- June 28 ESPWG and/or July 2 TPAS: Stakeholders’ presentations of projects updates, as related to the preliminary Reliability Needs identified in this presentation
- *July 6, 2018: lock down assumptions for final (“2<sup>nd</sup> pass”) RNA*
- July 19, Aug 8, Aug 22 ESPWG: review draft RNA reports
- Aug 22 ESPWG/TPAS: recommendation for approval of the 2018 RNA
- September 12 OC: Market Monitoring Unit review and OC vote
- September 28 MC: vote
- October: NYISO Board approval

DRAFT – FOR DISCUSSION PURPOSES ONLY

©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

# Questions?

We are here to help. Let us know if we can add anything.

# The Mission of the New York Independent System Operator, in collaboration with its stakeholders, is to serve the public interest and provide benefits to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policy makers, stakeholders and investors in the power system



[www.nyiso.com](http://www.nyiso.com)

DRAFT – FOR DISCUSSION PURPOSES ONLY

©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED