

Project Costs and Status Tracking

deliver the executed Interconnection Facilities Study Agreement to the NYISO within thirty (30) Calendar Days after its receipt, together with the required technical data and the greater of \$100,000 or Developer's portion of the estimated monthly cost of conducting the Interconnection Facilities Study.

8.1.1 NYISO shall invoice Developer on a monthly basis for the work to be conducted on the Interconnection Facilities Study each month. Developer shall pay invoiced amounts within thirty (30) Calendar Days of receipt of invoice. NYISO shall continue to hold the amounts on deposit until settlement of the final invoice.

8.2 Scope of Interconnection Facilities Study.

The Interconnection Facilities Studies for a Class Year of Developers, as that Class Year is determined in accordance with Attachment S of the NYISO OATT, shall be performed concurrently as a combined Interconnection Facilities Study for that Class Year to fulfill the requirements of this Section 8, and the requirements of the Annual Transmission Reliability Assessment called for by Attachment S.

Issued by: William J. Museler, President

Effective: August 6, 2004

Issued on: ~~April 26~~October 5, 2004

Filed to comply with ~~Order No. 2003~~ of the Federal Energy Regulatory Commission, Docket No. ~~RM02-1~~ER04-449-000, -001 and -002, issued ~~July 24~~August 6, 20034, 1048 FERC

¶ 61,40359 (20034).

New York Independent System Operator, Inc.
FERC Electric Tariff
Original Volume No. 1
Attachment X

First Revised Sheet No. 782
Superseding Substitute First Revised Sheet No. 782

The combined Interconnection Facilities Study shall specify and estimate the cost of the equipment, engineering and design work, permitting, site acquisition, procurement and construction work and commissioning needed to implement the conclusions of the Interconnection System Reliability Impact Studies for the Class Year in accordance with Good Utility Practice and, for each of these cost categories, shall specify and estimate the cost of the work to be done at each substation and/or on each feeder to physically and electrically connect each Large Facility in the Class Year to the Transmission System. The combined Interconnection Facilities Study shall also identify the electrical switching configuration of the connection equipment, including, without limitation: the transformer, switchgear, meters, and other station equipment; the nature and estimated cost of any Transmission Owners' Attachment Facilities and System Upgrade Facilities necessary to accomplish the interconnection of each Large Facility in the Class Year; ~~and an estimate of the time required to complete the construction and installation of such facilities~~ shall include a schedule showing the estimated time required to complete the engineering and design, permitting, site acquisition, procurement, construction, installation and commissioning phases

Issued by: William J. Museler, President
Issued on: ~~April 26~~October 5, 2004

Effective: August 6, 2004

Filed to comply with ~~Order No. 2003~~ of the Federal Energy Regulatory Commission, Docket No. ~~RM02-1~~ER04-449-000, -001 and -002, issued ~~July 24~~August 6, 20034, 1048 FERC ¶ 61,40359 (20034).

of the Large Facility interconnection projects. The schedule shall contain major milestones to facilitate the tracking of the progress of each Large Facility interconnection project.

8.2.1 Following commencement of the activities described in this schedule, each

Developer and that Developer's interconnecting Transmission Owner shall
~~provide monthly~~ reports every other month on the progress of their
respective activities to the NYISO and to each other. Such reports shall be
in a format consistent with, and include the content required by, applicable
ISO Procedures. In these bi-monthly reports, each Developer and
interconnecting Transmission Owner shall report any material variance
from earlier ~~cost or~~ schedule estimates for their respective activities, and
the reasons for such variance. In addition, the interconnecting
Transmission Owner shall report any material variance from earlier cost
estimates for its activities, and the reasons for such variance.

8.3 Interconnection Facilities Study Procedures.

The NYISO shall coordinate the Class Year Interconnection Facilities Study with the Transmission Owners and any Affected System pursuant to Section 3.5 above.

The NYISO shall utilize existing studies to the extent practicable in performing

the Class Year Interconnection Facilities Study. The NYISO shall follow the procedures set forth in Attachment S of the NYISO OATT and shall use Reasonable Efforts to complete the study and issue a Class Year Interconnection

New York Independent System Operator, Inc.
FERC Electric Tariff
Original Volume No. 1
Attachment X

First Revised Sheet No. 782B
Superseding Substitute First Revised Sheet No. 782

Facilities Study report to the Developers within the timeframe called for in Attachment S.

Issued by: William J. Museler, President

Effective: August 6, 2004

Issued on: ~~April 26~~October 5, 2004

Filed to comply with ~~Order No. 2003~~ of the Federal Energy Regulatory Commission, Docket No. ~~RM02-1~~ER04-449-000, -001 and -002, issued ~~July 24~~August 6, 2003, 1048 FERC ¶ 61,40359 (20034).