

Updates to the Consolidated Edison Long-Range Transmission Plan For 2012

Matt Koenig

Presentation at the NYISO


October 24, 2012

Consolidated Edison Company of New York, Inc.

Long-Range Transmission Plan

- Driver of Plan is maintaining local reliability
- 10-year planning horizon
- Order 890 (and Order 1000) compliance
 - Criteria, assumptions and methodology have been posted
 - http://www.coned.com/tp/transmission_planning_process.asp
 - Plan posted on the Con Edison website prior to presentations at NYISO
 - <http://www.coned.com/tp/Long-Term-Transmission-Plan-2012-2021.pdf>

Transmission Load Area



Transmission Load Areas

| | Transmission Load Areas | Contingency Level |
|----|--|-------------------|
| 1 | New York City - 345 kV | 2 |
| 2 | West 49th Street - 345 kV | 2 |
| 3 | New York City - 138 kV | 2 |
| 4 | Astoria - 138 kV | 2 |
| 5 | East 13th Street - 138 kV | 2 |
| 6 | Astoria East / Corona - 138 kV | 2 |
| 7 | Astoria West / Queensbridge - 138 kV | 2 |
| 8 | Vernon - 138 kV | 2 |
| 9 | East River - 138 kV | 2 |
| 10 | Greenwood / Staten Island- 138 kV | 1 |
| 11 | Corona / Jamaica - 138 kV | 1 |
| 12 | Bronx- 138 kV | 1 |
| 13 | Eastview - 138 kV | 1 |
| 14 | Staten Island - 138 kV | 1 |
| 15 | Dunwoodie North / Sherman Creek - 138 kV | 1 |
| 16 | Dunwoodie South - 138 kV | 1 |
| 17 | Millwood / Buchanan - 138 kV | 1 |

Physical Changes in 2012

- Gowanus established as a Ring Bus with connection to BEC Generation (500 MW)
- In response to the mothballing of the US PowerGen units Astoria 2 and Astoria 4, Con Edison established new transmission line 34091 with associated Phase Angle Regulator and Transformer, between the Astoria Annex 345 kV Substation to the Astoria East 138 kV Substation.
- Hudson Transmission Project (HTP) under construction, slated for completion by June, 2013
- Goethals 345 kV Ring Bus under construction, slated for completion by June, 2014.
- Studies for the 2012 Long Range Plan were performed with the assumption that the US Power Gen Gowanus barges 1 and 4 were available at rated capability. This is in agreement with current practice at the NYISO.

2012 Assessment Assumptions

| Study Year | Assumptions |
|------------|---|
| 2012 | <ul style="list-style-type: none">• Con Edison Load (Coincident Peak) = 13,225 MW• 138 kV Transmission Line 34091, with associated Phase Angle Regulator and Transformer, connecting the Astoria Annex 345 Kv Substation with the Astoria East 138 kV Substation |
| 2016 | <ul style="list-style-type: none">• Con Edison Load (Coincident Peak) = 13,900 MW• 138 kV Transmission Line 34091, with associated Phase Angle Regulator and Transformer, connecting the Astoria Annex 345 Kv Substation with the Astoria East 138 kV Substation |
| 2021 | <ul style="list-style-type: none">• Con Edison Load (Coincident Peak) = 14,850MW• 138 kV Transmission Line 34091, with associated Phase Angle Regulator and Transformer, connecting the Astoria Annex 345 Kv Substation with the Astoria East 138 kV Substation |


2011 TLA Assessment Results

- Two TLAs show need for system reinforcements:
 - 2017: Corona / Jamaica 138 kV TLA
 - 2018: Greenwood / Staten Island 138 kV TLA
 - The subsequent 2012 study indicated that the need for this reinforcement fell beyond the 10 year range of the study.

2012 TLA Assessment Results

- Two TLAs show need for system reinforcements:
 - 2018: Corona / Jamaica 138 kV TLA
 - Deferred for one year due to a reduction in the forecasted load.
 - 2018: Astoria East / Corona 138 kV TLA
 - This is due to the impact from the mothballing of the US PowerGen units Astoria 2 and 4. It represents an additional requirement above and beyond the establishment of transmission feeder 34091.

Area Served by Astoria East / Corona and Corona / Jamaica 138 kV TLAs



2012 Assessment of Corona / Jamaica 138 kV TLA

| | | | | |
|------------------------------|-------------------|--|--|--|
| Geographic Coverage | Queens | | | |
| Design Criteria | First Contingency | | | |
| Planned Changes In Load Area | None | | | |
| | | | | |
| Assessment | 2012 | First Contingency | Failed breakers 1, 2, 9, or 18 resulting in the loss of feeder 901, 702 and transformer bank 4 at Jamaica 138 kV | None required. |
| | 2016 | First Contingency | Failed breakers 1, 2, 9, or 18 resulting in the loss of feeder 901, 702 and transformer bank 4 at Jamaica 138 kV | None required. |
| | 2018 | First Contingency | Failed breakers 1, 2, 9, or 18 resulting in the loss of feeder 901, 702 and transformer bank 4 at Jamaica 138 kV | Deficit Forecast for 2018 See Planning Solution |
| | 2018 - 2020 | First Contingency | Failed breakers 1, 2, 9, or 18 resulting in the loss of feeder 901, 702 and transformer bank 4 at Jamaica 138 kV | None required. |
| | | | | |
| Operational Remediation | 2012 | None required | | |
| | 2016 | None required | | |
| | 2021 | None required | | |
| | | | | |
| Planning Solution | 2012 | None required | | |
| | 2016 | None required | | |
| | 2018 | Establish Transmission Feeder with associated transformer and phase angle regulator, connecting Rainey 345 kV Substation with Corona 138 kV Substation | | |
| | 2021 | No Further Actions Required | | |
| | | | | |
| Short Circuit Considerations | None | | | |

2012 Assessment of Astoria E / Corona 138 kV TLA

| | | | | |
|------------------------------|--------------------|--|--|-----------------------|
| Geographic Coverage | Queens | | | |
| Design Criteria | Second Contingency | | | |
| Planned Changes In Load Area | None | | | |
| Assessment | 2012 | Second Contingency | Loss of Astoria Energy I, followed by loss of feeder 34091 | ~ 12 MVA Deficit |
| | 2016 | Second Contingency | Loss of Astoria Energy I, followed by loss of feeder 34091 | ~ 70 MVA Deficit |
| | 2018 | Second Contingency | Loss of Astoria Energy I, followed by loss of feeder 34091 | See Planning Solution |
| | 2018 - 2020 | Second Contingency | Loss of Astoria Energy I, followed by loss of feeder 34091 | None required. |
| Operational Remediation | 2012 | Utilize 300 hr ratings for feeders 34051/52 and 701/702 until new transmission upgrade in 2018 | | |
| | 2016 | Utilize 300 hr ratings for feeders 34051/52 and 701/702 until new transmission upgrade in 2018 | | |
| | 2021 | None required | | |
| Planning Solution | 2012 | None required | | |
| | 2016 | None required | | |
| | 2018 | Establish Transmission Feeder with associated transformer and phase angle regulator, connecting Rainey 345 kV Substation with Corona 138 kV Substation | | |
| | 2021 | No Further Actions Required | | |
| Short Circuit Considerations | | None | | |

Transmission Substations

- With a lower overall rate of load growth, no new transmission switching stations were identified for this planning horizon.

2018 - Transmission Feeder Upgrade

- Based on the 2012 Long Range Plan, the transmission feeder between Rainey and Corona is anticipated to be established in the year 2018. This will address the deficiencies that have been identified in both the Astoria East / Corona and the Corona / Jamaica Transmission load areas according to their design criteria.