



CARIS I 2011 Preliminary Results

William A. Lamanna New York Independent System Operator

ESPWG

June 22, 2011 Rensselaer, NY

Draft- For Discussion Purposes Only



Stage 1 Selection of Primary Elements

- Step 1 Prioritization
 - Line up historic congested elements and projected elements for a fifteen year period based on Demand\$ Congestion
 - Identify elements that:
 - Are common to both
 - Are missing from one or the other (orphaned)
 - Show negative projected congestion
 - Are exceptions for diminishing returns
 - Calculate Present Value of congestion (using Demand\$ Congestion metric) for common elements, sort and identify top five for candidates for relaxing test
- Step 2 Review the exceptions :
 - Diminishing returns if a congested element shows a significant decline, exclude from list
 - Negative congestion Rank on absolute value and add top two as candidates
 - Orphaned Compare ranking value to just the 10 years of projected above and if greater substitute
- Stage 1 provides for flexibility
 - Given all of the considerations in the above, identify the top five elements as primary

Example of Common Elements



| 2010 Historic Congestion Reporting | | | |
|------------------------------------|------|------------------------------|------------------|
| Monitored Facility Common Eleme | nts💷 | Contingency 🔽 | Sum of 🛛 Deman 🛹 |
| CENTRAL EAST - VC | 1 | Base Case | \$489,887,685 |
| CENTRAL EAST | 1 | Base Case | \$1,516,433 |
| PLSNTVLY 345 LEEDS 345 1 | 2 | ATHENSPLSNTVLY_345_91 | \$223,539,956 |
| PLSNTVLY 345 LEEDS 345 1 | 2 | LEEDSHURLYAVE_345_301 | \$5,837,957 |
| LEEDS 345 HURLYAVE 345 1 | 2 | MTN:RNS4 OR RNS5 O/S PV USB | \$3,378,899 |
| PLSNTVLY 345 LEEDS 345 1 | 2 | MTN:RNS3 OR RNS4 O/S PV USB | \$1,381,687 |
| PLSNTVLY 345 ATHENS 345 1 | 2 | LEEDSPLSNTVLY_345_92 | \$1,322,928 |
| GREENWD 138 VERNON 138 1 | 3 | TWR:GOETHALS 22 21 A2253 | \$61,788,738 |
| GREENWD 138 VERNON 138 1 | 3 | Base Case | \$35,401,988 |
| GREENWD 138 KENTAVE 138 1 | 3 | Base Case | \$20,060,836 |
| FRESHKLS 138 WILLWBRK 138 1 | 3 | Base Case | -\$14,539,954 |
| DUNWODIE 345 SHORE_RD 345 1 | 4 | SPRNBRK-EGRDNCTR-Y49 | \$59,886,281 |
| DUNWODIE 345 SHORE_RD 345 1 | 4 | NEPTUNE HVDC TIE LINE | \$59,068,288 |
| DUNWODIE 345 SHORE_RD 345 1 | 4 | NEPTUNE 501 W/ PJM LOAD | \$19,592,382 |
| DUNWODIE 345 SHORE_RD 345 1 | 4 | Base Case | \$16,783,058 |
| SPRNBRK 345 EGRDNCTR 345 1 | 4 | DUNWODIE-SHORE_RD_345_Y50 | \$16,260,173 |
| EGRDNCTY 345 EGRDNCTY 138 1 | 4 | NEPTUNE HVDC TIE LINE | \$4,642,926 |
| EGRDNCTY 138 VALLYSTR 138 1 | 4 | FREEPORT-NEWBRDGE_138_461 | \$2,493,788 |
| SPRNBRK 345 EGRDNCTR 345 1 | 4 | NEPTUNE HVDC TIE LINE | \$1,778,618 |
| SHORE_RD 345 SHORE_RD 138 1 | 4 | NEPTUNE HVDC TIE LINE | \$1,430,085 |
| RAINEY 138 VERNON 138 1 | 5 | Base Case | \$31,750,896 |
| MOTTHAVN 345 DUNWODIE 345 2 | 6 | DUNWODIE-MOTTHAVN_345_71 | \$18,620,215 |
| MOTTHAVN 345 DUNWODIE 345 1 | 6 | DUNWODIE-MOTTHAVN_345_72 | \$17,320,474 |
| MOTTHAVN 345 RAINEY 345 2 | 6 | MOTTHAVN-RAINEY345_Q11 | \$13,172,692 |
| MOTTHAVN 345 RAINEY 345 1 | 6 | MOTTHAVN-RAINEY345_Q12 | \$11,616,152 |
| MOTTHAVN 345 DUNWODIE 345 1 | 6 | Base Case | \$7,268,516 |
| W49TH_ST 345 SPRNBRK 345 1 | 6 | SCB:SPBK (RS3): W75 99941 | \$6,432,065 |
| MOTTHAVN 345 DUNWODIE 345 2 | 6 | MTN:5 OR 6 O/S DUNWOODIE SCE | \$3,446,119 |
| MOTTHAVN 345 DUNWODIE 345 1 | 6 | MTN:4 OR 7 O/S DUNW SCB 6 OR | \$2,795,892 |
| MOTTHAVN 345 RAINEY 345 1 | 6 | Base Case | \$2,738,098 |
| MOTTHAVN 345 RAINEY 345 1 | 6 | TWR:69 J3410 70 K3411 BK258 | \$1,643,442 |
| LEEDS 345 N.SCTLND 345 1 | 7 | N.SCTLND-LEEDS345_94-LN | \$17,639,250 |
| LEEDS 345 N.SCTLND 345 1 | 7 | TWR:UCC2-41 FCC-33 | \$13,186,089 |
| LEEDS 345 N.SCTLND 345 1 | 7 | GILBOALEEDS345_GL3 | \$1,694,240 |
| RAMAPO 345 ROCKTVRN 345 1 | 8 | TWR:PV F30 F31 W80 W81 BK1 | \$10,399,378 |
| DUNWODIE 345 PLSNTVLE 345 1 | 8 | TWR:PV F30 F31 W80 W81 BK1 | \$2,506,127 |
| EFISHKIL 345 PLSNTVLY 345 1 | 8 | TWR:PV F30 F31 W80 W81 BK1 | \$1,777,831 |
| COOPERS 345 FRASER 345 1 | 9 | TWR:31 UCC2-41 | \$3,277,437 |
| DYSINGER EAST | 10 | Base Case | -\$1,016,429 |
| FARRAGUT 138 HUDS_AVE 138 1 | 11 | Base Case | -\$1,960,418 |
| WESTERN_NY_EXPORT | 12 | Base Case | -\$9,689,343 |
| E179THST 138 HELLTP W 138 1 | 13 | Base Case | -\$20 268 742 |

© 2011 New York Independent System Operator, Inc. All Rights Reserved.

Draft- For Discussion Purposes Only

Future Congestion Ranking



| Demand Congestion \$ | Potential Common | 2011 | 2015 | 2020 |
|--------------------------|------------------|------|------|------|
| CENTRAL EAST | | 1 | 2 | 2 |
| ATHENS_PLTVLLEY_345 | | 2 | 1 | 1 |
| Greenwood | 1 | 3 | 3 | 3 |
| FRKILLS_WILOWBK1_138 | 1 | 4 | 5 | 5 |
| GOTHLSS_GOWANUSS_345 | 2 | 5 | 4 | 4 |
| GOTHN_GOWANN_345 | 2 | 6 | 7 | 10 |
| RAINY8W138_VERNW_138 | | 7 | 8 | 8 |
| DUNWOODIE_SHORRD_345 | | 8 | 6 | 6 |
| TWR:FRSHK_GOTLSN_345_3 | 2 | 9 | 10 | 7 |
| E179 ST 138 15055 SR 138 | | 10 | 9 | 9 |
| SBK:FRSHK_GOTHLN_345 | 2 | 11 | 11 | 11 |
| WEST CENTRAL-OP | | 12 | 12 | 12 |



Stage 2: Grouping Elements for CARIS Studies

- In order to identify additional elements that may have a significant impact on congestion, each primary element being studied will be relieved independently of each other for a mid and horizon year (2015 and 2020).
- The primary element's constraint is relieved by replacing its limit with 9999, and any potential constraint duplicative or redundant with the primary constraint (e.g., two parallel circuits)
- The resultant list of top congested elements from the two years of analysis will be reviewed to determine:
 - The effects on NYCA congestion
 - If any additional new elements become congested
 - Significant increase in the other primary elements' congestion
 - Production cost savings from the relaxation



Stage 2: Grouping Elements for CARIS Studies

- The primary constraint will be assessed for grouping with a new element if the new element
 - is electrically adjacent/close to the primary element, or
 - Is in new top five of congested elements based on Demand\$ Congestion
- If passes above, the new element's limit will also be increased to 9999
 - Elements are grouped if the production cost savings increases
 - Repeat process if other additional elements pass above criteria
- If after an initial grouping, the change in total NYCA production cost is not more than 3 million dollars, consider removing the original primary constraint from the list
- If more than three groupings are revealed, the three groupings with the highest improvement in production cost savings will be selected as the three studies.



The New York Independent System Operator (NYISO) is a not-for-profit corporation responsible for operating the state's bulk electricity grid, administering New York's competitive wholesale electricity markets, conducting comprehensive long-term planning for the state's electric power system, and advancing the technological infrastructure of the electric system serving the Empire State.



www.nyiso.com