New York's DG Rule

Requirements for Demand Response Sources

Draft – for discussion purposes only

Existing Sources

 Sources that commenced operation prior to effective date of Part 222 (Fall 2006).

 Does not apply to sources subject to an NSPS rule.

Demand Response Sources

- Must be permitted.
- Emergency Use (500 hours/year)
 - or as limited due to New Source Review
 - operated when usual supply of electricity is not available
 - routine maintenance (one hour per week)

 In addition – may operate for up to 30 hours per year when called upon by a Demand Response Program Sponsor.

Demand Response Sources

- Emission Limits:
 - Effective Date: January 1, 2009
 - NOx: 9.0 g/bhp-h
 - PM: 0.10 lb/mmBtu or 85% control
 - Stack Test: by December 31, 2008

Demand Response Sources Capacity Limitations Sources subject to Part 222: NYCMA Upstate – January 1, 2007: 271.9 MW 111.4 MW – January 1, 2011: 150.0 MW 100.0 MW – January 1, 2014: 50.0 MW 50.0 MW

 Sources subject to an NSPS Rule: – not subject to capacity cap

Demand Response Sources

- List of sources that may participate will be maintained on DEC website.
- Guidance Document development and maintenance of the Inventory of Demand Response Sources.

Existing Sources NOx Emission Limits

- Effective January 1, 2008
 - Microturbines: 0.54 g/bhp-h
 - Turbines (CH4): 50 ppmvd @ 15% O2
 - Turbines (oil): 100 ppmvd @ 15% O2
 - Rich Burn Engines (CH4): 3.0 g/bhp-h
 - Lean Burn Engines (CH4): 2.0 g/bhp-h
 - Diesel-fired Engines: 7.5 g/bhp-h
 - Stack Test by December 31, 2007

Emission Limits Particulate Matter (PM) • Oil-fired Sources Only • Effective Date: January 1, 2008

– 0.10 lb/mmBtu Heat Input; or– Ultralow sulfur diesel fuel + 85% Control



Distributed Generation Rule

- New Sources Subject to an EPA New Source Performance Standard (NSPS)
 - 40 CFR 60 Subpart 4I (diesel engines)
 - Effective Date: July 11, 2005
 - 40 CFR 60 Subpart 4J (spark-ignition engines)
 - Effective Date: June 2006 (July 1, 2007)
 - 40 CFR 60 Subpart 4K (turbines)
 - Effective Date: February 18, 2005

Subpart 41

NOx, CO and PM

NOx Emissions: F(engine size, model year)

- 3.0 4.8 g/hp-h (2007)
- 0.3 2.6 g/hp-h (2012)
- 0.3 0.5 g/hp-h (2015)

- PM: G(engine size, model year)

- 0.05 0.1 lb/mmBTU (2008)
- 0.001 0.0074 lb/mmBtu (2015)

Subpart 4J

 NOx, CO, and NMHC -NOx: 2.0 g/hp-h (2007-2009) • 1.0 g/hp-h (2009 -) -CO:• 4.0 g/hp-h (2007-2009) • 2.0 g/hp-h (2009 -) - NMHC: 1.0 g/hp-h (2007-2009) • 0.7 g/hp-h (2009 -)

Subpart 4K

• NOx

-H(turbine size, fuel used)

- 0.15 0.78 g/hp-h (natural gas)
- 0.44 1.86 g/hp-h (other fuels)



NSPS Compliance

Emissions Testing

– Subpart 4I – Manufacturer's Certification

 Subpart 4J – Manufacturer's Certification is optional... if not certified – owner/operator must conduct stack test. Additional tests – every 3 years/8,760 hours operation for large engines (>500 hp).

– Subpart 4K – Annual stack testing or CEMS.

Status of Part 222

Stakeholder Meeting Conference Call format

• Effective Date of Part 222 – January 2007



