

NYISO Voltage-constrained Transfer Limit Analyses

CRPP studies

Summer Operating studies

ATR studies

.....

Issues

- 1. Pre-contingency assessment**
- 2. Post-contingency assessment**
- 3. Design criteria**

Pre-contingency assessment

1. Inaccuracies in the Con Edison system representation

- ✓ A/S over-voltages pre-contingency
- ✓ Approx. 150 MVARs lower capacitive compensation at A/S
- ✓ Substantial overspill on the A line (Linden-Goethals), approx. 200 MW
- Other topography errors in the Astoria pocket

2. NYCA system representation only partially a “level 5” representation, especially in the SENY area (except Zones I and J)

- Does not effectively assess the voltage profile of the entire study area

3. Severe underutilization of installed system resources in supporting system voltages under high transfers

- 375 MVAR of BPS shunt reactors erroneously dispatched I/S in Con Ed
- Some QMAX. Capabilities modeled lower than latest VSS points
- Underutilization of generators VAR support, due to inappropriate choice of GSU taps and/or Vterm
- Flows on regulated feeders of the I-to-J interface artificially held back

Post-contingency voltage assessment

- 1. Lack of clarity as to time frame for monitoring post-contingency voltage:**
 - On-going discussion as to exact monitoring time frame
 - The NYISO has committed to clarify its criteria in writing.
- 2. Use of inaccurate power flow solution:**
 - Transfer limits unnecessarily degraded
- 3. Con Edison's assessment of the NYISO power flow solution:**
 - Benchmark tests of the NYISO's post-contingency system assessment against a fully detailed stability solution shows the NYISO power flow solution technique to be significantly underestimating the strength of the interconnected system
 - Shared results w/ the NYISO on September 16, 2005 asking their comments and requesting an independent evaluation

NYISO Design Criteria

- 1. The NYISO has verbally stated that it designs for “the loss of the largest generating unit when dispatched at its Max. MW capability, while at peak demand and transfer limits”**

- 2. The following issues arise out of the aforementioned NYISO statement:**
 - 1. The written NYSRC criteria does not have any such language.**
 - 2. With its statement, the NYISO is subordinating system performance to deliverability of the largest generating unit(s).**
 - 3. The NYISO is significantly underutilizing other available generating capacity in order to have Ravenswood #3 dispatched at at max.**
 - 4. Unlikely concomitance of the aforementioned three conditions. In fact, operationally, the system would be dispatched to avoid such conditions.**

NYISO Post-Contingency Voltage criteria

- **Voltages monitored 30-60 seconds after the contingency occurs**
- **Recognizes only the automatic response of the system:**
 - Generators' excitation & governor systems
 - SVC contribution
- **Other (slower-acting) controls frozen**
 - PARs and LTC transformers fixed at their pre-contingency solved tap position
 - Transmission switched shunts are locked
 - DC terminals locked
 - Operators' actions (e.g. dispatching/committing generation – ramping steam units, turning on GTs)
 - Area Interchange disabled
- **Load represented as constant power (except for Con Ed loads)**
- **The above conditions describe post-transient conditions best evaluated via 6 stability simulations**

Post-contingency assessment

<u>NYISO voltage criteria</u>	<u>NYISO power flow solution</u>	<u>Stability solution</u>
1. Generators' Excitation system action	<u>Not</u> represented	Represented
2. Generators' Governor system action	<u>Not</u> represented	Represented
3. SVC action	Represented	Represented
4. Load model	Constant MVA	Constant impedance
5. No other operator action	Yes	Yes

Approximate power flow solutions

1. Variety of approaches:
 - INLF
 - FDNS
 - FNSL
2. Good computational speed.
3. Useful as a screening tool.
4. Need to be benchmarked against much more robust stability simulations.
5. Current practice for benchmarking DC thermal analysis with a detailed power flow.


Stability solution

1. Combines power flow with detailed representation of generation sources
 - Stator and rotor parameters
 - Excitation system
 - Governor system
2. Monitors a great variety of system parameters (during and post-events):
 - Frequency
 - Voltage
 - Machines' rotor angles
 - Generators' MW and MVAR output
3. Widely available
4. Used in critical studies by the NYISO
 - ATR
 - Blackout re-construction
 - Establishment of relay protection system for old and new generation projects.
 -
5. More conservative than power flow solution
 - Fault simulation (e.g. 3-phase-to-ground fault)
 - Stability-constrained T-Lims need to be 11% above thermal Limits



2004 ANNUAL TRANSMISSION REVIEW
2009 SUMMER PEAK W/ 2003 NERC/MMWG BASE CASE

FILE: C:\M295p1ro\M295p1roStop\W89-90Tower.out




MON, OCT 17 2005 13:48

VOLTAGE L/O W89&90 TOWER



2004 ANNUAL TRANSMISSION REVIEW
2009 SUMMER PEAK W/ 2003 NERC/MMWG BASE CASE


FILE: C:\M295prj\ro\M295prj\rostop\LDRaw3\France-2-2005.out



WED, OCT 05 2005 11:29

VOLTAGES

Con Edison assessment of "I to J Transfers" Voltage @ Sprain Brook



Summer 2006 - I to J transfers at 3680 MW

Ravenswood #3 at max. output: 972 MW
 (the NYISO calls 3300 MW the limit on I-to_J transfers)

Pre-contingency

Post-contingency

L/O Rav 3 at 972 MW

L/O W89/W90 common tower

$V_{\text{Sprain Brook}}$

343.3 kV

332.6 kV

333.3 kV

SVC_{Leeds}

81 MVARs

270 MVARs

200 MVARs

SVC_{Frazer}

42 MVARs

247 MVARs

51 MVARs

Note: SVC_{Frazer} 's $Q_{\text{max}} = 325$ MVARs, SVC_{Leeds} ' $Q_{\text{max}} = 270$ MVARs

Post-contingency solution used is the NYISO's approximate power flow solution.