



December 14, 2020

Hon. Kathleen H. Burgess
Secretary to the Commission
New York State Public Service Commission
Agency Building 3
Albany, NY 12223-1350
Email: secretary@dps.ny.gov

BY ELECTRONIC MAIL ONLY

RE: Notice of ICAP Ineligible Forced Outage (IIFO) of Eastern Generation, LLC Gowanus Gas Turbine Facility Unit 1-8

Dear Secretary Burgess,

Eastern Generation, LLC is providing notice to the New York State Public Service Commission, the New York Independent System Operator, the Consolidated Edison Company of New York, Inc. and the New York State Reliability Council that it is placing unit 1-8 of the Gowanus Gas Turbine Facility (“GGT”) in an IIFO effective February 1, 2021 in accordance with the 60-day period set forth in NYISO Services Tariff, Section 5.18.2.1.

GGT 1-8 was placed into service in 1970 and is currently in a forced outage. Recent boroscope inspections of GGT 1-8 revealed substantial damage to the compressor stator and rotor. The breadth of the damage necessitates a complete overhaul of the compressor section. Based on the estimated costs of repairs, the forecasted economic viability of the unit, upcoming regulatory rule changes as well as other considerations, GGT 1-8 is being placed into an IIFO as noted above.

Please don’t hesitate to contact me with any questions at (212) 792-0816.

Sincerely yours,

A handwritten signature in black ink that reads "Liam T. Baker".

Liam T. Baker
Vice President
Eastern Generation, LLC

Cc: Shaun Johnson (NYISO)
David Drexler, Esq. (NYPSC)
Paul Goia, Esq. (NYSRC)
Neil Butterklee, Esq. (Con Edison)

Eastern Generation, LLC