

CECONY's Local Transmission Plan (LTP)

ESPWG Update
October 23, 2020

CECONY's Local Transmission Plan (LTP)

CECONY is proposing to update the database utilized in the NYISO Short-Term Assessment of Reliability (2020 Quarter 3) as follows:

CECONY's 345 kV Series Reactors	Current Operating Protocol	Assumed Operating Protocol in 2020 STAR	LTP Update Operating Protocol
41	By-passed	In-Service	By-passed
42	By-passed	In-Service	By-passed
Y49	By-passed	In-Service	By-passed
M51	In-Service	By-passed	In-Service
M52	In-Service	By-passed	In-Service
71	In-Service	By-passed	In-Service
72	In-Service	By-passed	In-Service

Thank you!